



ESCALATOR PERIODIC INSPECTION CHECKLIST

(M)= Manual Reset

Date of Inspection:	Inspector's Name:	Badge No.:
Agency:	Agency No.:	Device No.:
Rated Speed: fpm:	Capacity: lbs.:	Elevator Company:

INSPECTOR NOTE: ASME A17.1 –2000 A17.1a 2002-A17.1b 2003 Manuals

S = Satisfactory – meets Code requirements

U = Unsatisfactory

N/A = Not Applicable

EXTERNAL	S	U	N/A
Rule 7			
Geometry			
Ride Escalator (Must hold handrails while riding) Check Handrails			
Entrance & Egress Ends – Safety Zone			
Lighting – Above escalator			
Caution Signs			
Comb plate and landing plate (2 adjacent teeth on a comb plate is a cease use item)			
Deck barricades- ANSIZ97.1 marking: Antislid Devices			
Step Threads			
Operating and Safety Device – Top & Bottom Emergency Stop Switches (<i>right hand side facing newel</i>) Buzzer (Visual Only)			
Egress restriction (rolling shutter) device			
Balustrades <input type="checkbox"/> Left Hand Side <input type="checkbox"/> Right Hand Side ANSIZ97.1 Marking			
Ceiling Intersection Guards			
Step Risers: Step/Skirt Clearances, Panels <input type="checkbox"/> Left Hand Side <input type="checkbox"/> Right Hand Side			
Outdoor Protection			
Maintenance Control Program/Maintenance Log			

EXTERNAL	S	U	N/A
Rule 8: CODE DATA PLATE			
Code Data Tag			