



NEW YORK CITY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
CERTIFIED EMISSION CONTROL DEVICES FOR COMMERCIAL COOK STOVES

Last Updated: 04/2024

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
Captive Aire Systems, Inc., 4641 Paragon Park, Raleigh, NC 27616	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-PF-HE-HEPA, PCU-PF-HE-HEPA-OC, PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Captive Aire Systems, Inc., 4641 Paragon Park, Raleigh, NC 27616	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404
Grease Master 505 Cuthbertson St. Monroe, NC 28110	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	GM-PCU-PF-HE-HEPA, GM-PCU-PF-HE-HEPA-OC, GM-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Grease Master 505 Cuthbertson St. Monroe, NC 28110	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404



NEW YORK CITY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
CERTIFIED EMISSION CONTROL DEVICES FOR COMMERCIAL COOK STOVES

Last Updated: 04/2024

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
AquaMatic 4641 Paragon Park, Raleigh, NC 27616	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	AM-PCU-PF-HE-HEPA, AM-PCU-PF-HE-HEPA-OC, AM-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
AquaMatic 4641 Paragon Park, Raleigh, NC 27616	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404
Econ-Air 360 Northbrook Dr. Youngsville, NC 27596	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	EA-PCU-PF-HE-HEPA, EA-PCU-PF-HE-HEPA-OC, EA-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Econ-Air 360 Northbrook Dr. Youngsville, NC 27596	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404



**NEW YORK CITY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
CERTIFIED EMISSION CONTROL DEVICES FOR COMMERCIAL COOK STOVES**

Last Updated: 04/2024

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
Ventilation Direct, 14460 New Falls of the Neuse Road, Suite 149-293 Raleigh, NC 27614	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	VPCU-PF-HE-HEPA, VPCU-PF-HE-HEPA-OC, VPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3, 4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Ventilation Direct, 14460 New Falls of the Neuse Road, Suite 149-293 Raleigh, NC 27614	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404
Stratovent 4641 Paragon Park Raleigh, NC 27616	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	SV-PCU-PF-HE-HEPA, SV-PCU-PF-HE-HEPA-OC, SV-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Stratovent 4641 Paragon Park Raleigh, NC 27616	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
<p align="center">Aerolater 4641 Paragon Park Raleigh, NC 27616</p>	<p>Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>AR-PCU-PF-HE-HEPA, AR-PCU-PF-HE-HEPA-OC, AR-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0</p>		<p>Tested CFM: 2,862 Filter Velocity (ft/min): 124</p>
<p align="center">Aerolater 4641 Paragon Park Raleigh, NC 27616</p>	<p>MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0 Total Active Surface Area of ESP per Stage (ft²): 6.28</p>		<p>Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404</p>
<p align="center">Sun Air 4641 Paragon Park Raleigh, NC 27616</p>	<p>Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>SA-PCU-PF-HE-HEPA, SA-PCU-PF-HE-HEPA-OC, SA-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0</p>		<p>Tested CFM: 2,862 Filter Velocity (ft/min): 124</p>
<p align="center">Sun Air 4641 Paragon Park Raleigh, NC 27616</p>	<p>MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0 Total Active Surface Area of ESP per Stage (ft²): 6.28</p>		<p>Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404</p>

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
Rupp Air Management Systems, 4641 Paragon Park Raleigh, NC 27616	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	RPCU-PF-HE-HEPA, RPCU-PF-HE-HEPA-OC, RPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Rupp Air Management Systems, 4641 Paragon Park Raleigh, NC 27616	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404
ThermoTek 4031 Tull Avenue Muskogee, OK 74403	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	TPCU-PF-HE-HEPA, TPCU-PF-HE-HEPA-OC, TPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
ThermoTek 4031 Tull Avenue Muskogee, OK 74403	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
<p align="center">FloAire 360 Northbrook Dr Youngsville, NC 27596</p>	<p>Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>FA-PCU-PF-HE-HEPA, FA-PCU-PF-HE-HEPA-OC, FA-PCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0</p>		<p>Tested CFM: 2,862 Filter Velocity (ft/min): 124</p>
<p align="center">FloAire 360 Northbrook Dr Youngsville, NC 27596</p>	<p>MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0 Total Active Surface Area of ESP per Stage (ft²): 6.28</p>		<p>Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404</p>
<p align="center">K-Tech 4641 Paragon Park Raleigh, NC 27616</p>	<p>Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>KPCU-PF-HE-HEPA, KPCU-PF-HE-HEPA-OC, KPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0</p>		<p>Tested CFM: 2,862 Filter Velocity (ft/min): 124</p>
<p align="center">K-Tech 4641 Paragon Park Raleigh, NC 27616</p>	<p>MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p>Pollution Control Unit (PCU)</p>	<p>PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0 Total Active Surface Area of ESP per Stage (ft²): 6.28</p>		<p>Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404</p>

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
LDI 4641 Paragon Park, Raleigh NC 27616	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	LPCU-PF-HE-HEPA, LPCU-PF-HE-HEPA-OC, LPCU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
LDI 4641 Paragon Park, Raleigh NC 27616	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404
Global Aire, 389 Coombs Court, Milton, ON L9T 7N5, Canada	Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	ECO-PRE-HI-HEPA, ECO-PRE-HI-HEPA-OD, ECO-PRE-HI-HEPA-OD-OD followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0		Tested CFM: 2,862 Filter Velocity (ft/min): 124
Global Aire, 389 Coombs Court, Milton, ON L9T 7N5, Canada	MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System	Pollution Control Unit (PCU)	PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)
	Number of Stages: 4 Total Active Face Area of Filters per Stage (ft ²): 23.0 Total Active Surface Area of ESP per Stage (ft ²): 6.28		Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404

MANUFACTURER	CERTIFIED MODELS		
	EMISSION CONTROL DEVICE TYPE	TRADE NAME	MODEL NUMBER
<p align="center">RAMAire Fresher Source Energy Solutions Inc., 343 Roselawn Avenue, Toronto, Ontario, M4R 1G2</p>	<p>Prefilter, MERV 15 Filter, HEPA Filter, Optional Odor Control Filter, Option KB/KB-INLINE/USBI/SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p align="center">Pollution Control Unit (PCU)</p>	<p>RAMEU-PF-HE-HEPA, RAMEU-PF-HE-HEPA-OC, RAMEU-PF-HE-HEPA-OC-OC followed by -1,-2,-3,-4,-5,-6,-7 (optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0</p>		<p>Tested CFM: 2,862 Filter Velocity (ft/min): 124</p>
<p align="center">RAMAire Fresher Source Energy Solutions Inc., 343 Roselawn Avenue, Toronto, Ontario, M4R 1G2</p>	<p>MERV 15 Filter, ESP Filter, ESP Filter, Optional Odor Control Filter, Optional KB/KB-INLINE /USBI/ SIF Fan or Fan by others, Optional CORE/CAS-EWC/EWC Fire System</p>	<p align="center">Pollution Control Unit (PCU)</p>	<p>PCU-HE-ESP-ESP followed by -1,-2,-3,-4,-5,-6,-7 (optional odor control, optional Fire System)</p>
	<p>Number of Stages: 4 Total Active Face Area of Filters per Stage (ft²): 23.0 Total Active Surface Area of ESP per Stage (ft²): 6.28</p>		<p>Tested CFM: 2,551 Filter Velocity (ft/min): 115 ESP Filter Velocity (ft/min): 404</p>