



New York City Municipal Government Energy Benchmarking Results 2021

Energy

NYC DCAS
Citywide Administrative Services

September 2022

New York City Government Property Energy Benchmarking Results Calendar Year 2021

Overview

The Department of Citywide Administrative Services (DCAS) submitted benchmarking results for City government properties for calendar year 2021 to the Department of Finance (DOF) for publication on September 1, 2022, in compliance with Local Law 84 of 2009 (LL84). Since 2009, DCAS has coordinated with City agencies each year to benchmark nearly 3,000 public properties including libraries, police stations, firehouses, schools, colleges, courthouses, hospitals, community centers, and government offices.

The following report discloses energy performance metrics for calendar year 2021 for all City government properties that are covered by LL84. It also includes data from calendar year 2010, which was published in the original New York City Government Building Energy Benchmarking Results, as required by LL84. The performance metrics included in the report are: [ENERGY STAR score, energy use intensity \(EUI\), and greenhouse gas \(GHG\) emissions intensity](#). The U.S. EPA ENERGY STAR Portfolio Manager Tool calculates ENERGY STAR scores for certain common property types. For property types that are ineligible for an ENERGY STAR score, or for which property or energy consumption data was not available, the report indicates “Not Available.”

As a result of a rule change¹ issued by the NYC Department of Buildings (DOB), City government properties were benchmarked differently for calendar year 2021. Previously, when multiple buildings were located on the same tax lot and/or shared a utility meter, they were benchmarked as a single property with all energy and square footage data from the individual buildings aggregated to this single benchmarked property. In 2021, data for each individual building that met these criteria was directly entered into Portfolio Manager and a “parent property” was created to aggregate the data from the group of individual buildings (also known as a “benchmarking group”). The aggregated data for the parent property was used by Portfolio Manager to generate EUIs and ENERGY STAR scores, wherever applicable, and these metrics were then associated back to each individual building within the benchmarking group.² As such, the dataset enclosed with this report includes all buildings that were entered into Portfolio Manager; buildings that were part of benchmarking groups have received the EUIs and Energy Star Scores, if applicable, that were generated for the parent properties of their benchmarking groups.

¹ [§ 103-06 Benchmarking Energy and Water Use](#)

² Note that, with the change in benchmarking procedure, not all buildings that are part of benchmarked groups are eligible for an ENERGY STAR score, though most receive an EUI and GHG emissions intensity.

Summary of Results

The average ENERGY STAR score for eligible City properties in calendar year 2021 was 64, which was a 10% improvement since 2010, the first year of benchmarking City properties. The average Source EUI in 2021 was 147.4 kBtu/ft² and the average GHG intensity was 5.6 kgCO₂e/ft², both of which improved 25% from 2010. Please see Table 1 for additional detail.³

Table 1: Comparison of Benchmarking Results, 2021 vs 2010*

Years	Average ENERGY STAR		Average EUI		Average GHG Intensity		Cooling Degree Days (CDD)	Heating Degree Days (HDD)	Total Degree Days
	Score	# of Properties ³	(kBtu /ft ²)	# of Properties ³	(kgCO ₂ e /ft ²)	# of Properties ³			
2010	58	1,355	196.0	2,059	7.5	2,057	1,712	4,227	5,939
2021	64	1,302	147.4	1,945	5.6	1,945	1,570	3,961	5,531
% Change	10%	-4%	-25%	-6%	-25%	-5%	-8%	-6%	-7%

For additional information on these benchmarking results, contact NYC DCAS Energy Management at energy@dcas.nyc.gov.

³ To facilitate a one-to-one comparison between benchmarking results for 2010 and 2021, Table 1 below is based on a dataset that includes only the parent properties for 2021 to avoid double counting of the metrics from individual buildings that were included in benchmarking groups.



New York City Government Building Energy Benchmarking Results: 2021 *

Energy



Borough	Block	Lot	BIN	Building	Agency	2010 *			2021		
						Score *	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score *	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1	10	1086340	M877	DOE	Not Available	Not Available	Not Available	Not Available	322.5	8.5
1	1	10	1086435	M871	DOE	Not Available	Not Available	Not Available	Not Available	322.5	8.5
1	1	10	1999999	SBS Governor's Island	EDC	Not Available	Not Available	Not Available	Not Available	322.5	8.5
1	2	1	Not Available	Not Available	Not Available	Not Available	323.9	8.4	Not Available	Not Available	Not Available
1	2	23	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	3	1	1077335	Battery Park Garage	DPR	Not Available	Not Available	Not Available	Not Available	267	8
1	3	1	1088314	Battery Park/State Street Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	267	8
1	3	1	1088312	Battery Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	267	8
1	16	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	16	10	1084594	Museum of Jewish Heritage	CIG > MJH	Not Available	461.8	12	Not Available	329.6	8.7
1	16	40	1087945	M276	DOE	Not Available	Not Available	Not Available	30	189.8	6.1
1	16	215	1084587	M477	DOE	47	201.2	6	56	127.1	3.4
1	16	220	1085459	M089	DOE	34	155.5	4.9	40	136.3	4.6
1	29	73	1000850	Administrative Offices	DSNY	36	273.1	9.1	56	204.2	7.5
1	34	37	1000866	Police Museum	NYPD	Not Available	246.3	8	Not Available	8.2	0.2
1	36	12	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	36	18	1999999	Pier 11	EDC	Not Available	Not Available	Not Available	Not Available	14.4	0.4
1	36	25	1999999	East River Waterfront Esplanade	EDC	Not Available	Not Available	Not Available	Not Available	431470	11370.2
1	36	30	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	51	15	1001035	M894	DOE	24	169.8	11.2	7	218.8	9.1
1	52	1	1001037	M833	DOE	16	218.1	11.2	5	221.5	9
1	73	2	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	73	8	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	73	10	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	73	11	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	73	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	73	29	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	74	1	1082002	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1081994	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1081996	Gansevoort Meat Market	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1081997	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1081998	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1082001	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1

* Data used to generate this report is collected and reported by City operating agencies. The information in this report is subject to change due to data quality improvements, energy efficiency efforts, and changes in building use over time.

* 2010 data as published in 2013 New York City Government Building Energy Benchmarking Results.

* Score of "Not Available" indicates building use types for which the EPA Portfolio Manager (EPA PM) does not provide an ENERGY STAR score.

* Source EUI and GHG Emissions Intensity calculations performed by U.S. Environmental Protection Agency (EPA) methodology with EPA greenhouse gas emissions factors.

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	74	1	1085799	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1082003	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1085801	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1082000	Seaport Marketplace- GGP/ Imagination Plaground Comfort Station	DPR	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1088320	Seaport Associates - 97 Block	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1085800	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1081995	Seaport Marketplace - GGP	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1082004	Seaport- Museum	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1083713	Seaport- Museum	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1085798	Seaport- Museum	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	74	1	1082003	South Street Seaport - Seaport Residential (LL84)	EDC	Not available	Not Available	Not Available	Not Available	3.4	0.1
1	94	25	1001289	100 Gold Street Office Building	DCAS	30	319.6	8.9	70	215.4	6.8
1	96	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	96	5	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	96	12	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	106	9	1001363	M343	DOE	Not Available	Not Available	Not Available	27	155.3	4.8
1	111	150	1083359	Classified Location	DHS	Not Available	172.1	7.1	Not Available	92.4	4.2
1	111	160	1083358	Alfred E. Smith Recreation Center	DPR	81	110.8	4.8	62	103.9	4.6
1	111	160	1090086	Alfred E. Smith Park Comfort Station	DPR	81	110.8	4.8	62	103.9	4.6
1	111	160	1083357	M126	DOE	81	110.8	4.8	62	103.9	4.6
1	113	100	1001388	M520	DOE	8	271.3	13.5	31	164.2	6.3
1	119	1	1079143	Classified Location	NYPD	36	299.2	9.5	30	247.1	7.5
1	121	1	1001394	Manhattan Municipal Building	DCAS	88	150	5.4	Not Available	146.4	5.2
1	122	1	1079147	City Hall	DCAS	16	376.3	14.7	Not Available	146.4	5.2
1	122	1	1079146	Tweed Courthouse	DCAS	16	376.3	14.7	Not Available	146.4	5.2
1	127	1	1088292	BMCC: Fiterman Hall	CUNY CC > BMCC	Not available	Not Available	Not Available	Not Available	186.2	6.1
1	142	1	1001533	M234	DOE	70	134.2	5.2	51	123.9	4.9
1	142	50	1066406	BMCC: Chambers St. Building	CUNY CC > BMCC	Not available	Not Available	Not Available	Not Available	185.2	6.5
1	150	25	1001647	Engine Co. 7 at Ladder Co. 1, Batt. 1	FDNY	Not Available	166.7	5.6	Not Available	164	5.9
1	153	1	1079215	Sun Building	DCAS	69	207.3	6.9	88	132.9	4
1	153	24	1001670	Manhattan Surrogate's Court	DCAS	53	249.1	10.5	Not Available	146.4	5.2
1	154	23	1078613	City Planning Building	DCAS	56	222.4	7.2	83	133	4.5
1	155	1	1001672	Court Square Building	DCAS	77	185.7	5.4	70	162.8	5.1
1	160	21	1085748	Manhattan Supreme Court	DCAS	47	265.5	10.9	58	181.4	6.9
1	166	27	1001830	Louis J. Lefkowitz Building	DCAS	82	170.1	6.9	76	143.2	5.1
1	167	1	1079000	Manhattan Criminal Court	DCAS	63	224.2	8	Not Available	162	5.9
1	167	1	1088394	Manhattan CC: Manhattan Detention House South	DOC	63	224.2	8	Not Available	162	5.9
1	168	32	1001831	Health Building	DCAS	81	172	6.5	83	128.8	4.5
1	169	1	1001832	Refrigeration Plant	DCAS	Not available	Not Available	Not Available	Not Available	911.9	24
1	169	10	1001833	Manhattan Civil Court	DCAS	84	157.4	6.1	87	101.5	3.2
1	171	31	1001842	Manhattan Family Court	DCAS	79	179.5	6.5	87	105.4	3.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	190	33	1002168	1st Precinct	NYPD	Not Available	242.2	8.4	Not Available	221.1	7.6
1	197	17	1002358	Excelsior Building	NYPD	54	213.1	6.5	81	98.2	4
1	198	1	1002364	Manhattan CC: Manhattan Detention House North	DOC	Not Available	196.3	6.8	Not Available	162	5.9
1	198	126	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	200	1	1066494	Chinatown Senior Center	DFTA	Not Available	Not Available	Not Available	Not Available	Not Available	0
1	201	20	1066496	5th Precinct	NYPD	Not Available	103.2	3.6	Not Available	217.1	8
1	236	6	1087044	M130 - Addition	DOE	Not Available	Not Available	Not Available	49	130.4	5
1	236	38	1003086	M130	DOE	66	144.3	4.8	49	130.4	5
1	241	13	1079601	Classified Location	NYPD	Not Available	371	15.4	Not Available	155.6	6.7
1	241	13	1078939	EMS 4	FDNY	Not Available	371	15.4	Not Available	155.6	6.7
1	241	13	1999999	Pier 36 East River	EDC	Not Available	371	15.4	Not Available	155.6	6.7
1	241	13	1078939	Manhattan 3 District Garage	DSNY	Not Available	371	15.4	Not Available	155.6	6.7
1	241	18	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	245	7	1003143	M137	DOE	96	85.7	3.2	97	54.1	1.7
1	256	3	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	259	44	1003214	M446	DOE	97	68.6	2.5	92	66.3	3
1	262	25	1089226	Corlears Hook Park - PEP	DPR	Not Available	Not Available	Not Available	Not Available	29.7	0.8
1	269	41	1003223	M056	DOE	97	79.3	3.4	91	75	3.2
1	270	32	1003224	Gouverneur Health Care Services	H+H	Not Available	506.4	28	Not Available	525.5	20.6
1	273	1	1003248	M002	DOE	88	103.2	4.6	78	90.8	3.8
1	274	6	1079605	Print Shop and Storage	DSNY	81	38.9	1.4	80	28.4	1
1	275	3	1079607	Manhattan 3B Garage	DSNY	Not Available	45.5	1.4	Not Available	38	1.2
1	275	28	1003286	Manhattan Repair Shop	DEP	Not Available	385.9	22.2	Not Available	161.8	7.4
1	279	40	1003375	M001	DOE	83	116.6	4.3	82	85	2.9
1	280	44	1003425	Chatham Square Branch Library	NYPL	Not Available	243.4	8.2	Not Available	170.6	6.1
1	282	3	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	282	44	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	288	15	1003736	M134	DOE	73	114.2	4.8	95	82.9	3.4
1	289	1	1075787	M124	DOE	68	130.3	5.3	77	91.9	4.1
1	289	9001	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	301	3	1082489	M131	DOE	90	117.5	4.7	90	78.4	3.7
1	309	1	1003998	M042	DOE	68	118.7	4.2	84	88.3	3.3
1	311	31	1004053	Seward Park Branch Library	NYPL	Not Available	231.7	7.6	Not Available	174.9	4.6
1	316	200	1079657	East River Park at Rivington Street Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	141.8	4.7
1	316	200	1079659	East River Park 6th Street Rec Building	DPR	Not Available	Not Available	Not Available	Not Available	141.8	4.7
1	323	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	325	25	1004062	M097	DOE	44	97.3	3.7	89	75.3	2.9
1	331	140	1004066	M110	DOE	97	91.1	3.2	83	80.3	3.3
1	335	1	1004070	M022	DOE	63	130.1	6.1	97	58	2.4
1	340	1	1081932	Hamilton Fish Recreation Center	DPR	Not Available	309.6	10.2	Not Available	224.6	8.6
1	342	60	1004078	7th Precinct (LL84)	NYPD	Not Available	Not Available	Not Available	Not Available	286.8	10.6
1	343	1	1004080	M142	DOE	94	80.5	3.3	73	95	4.5

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	344	1	1004091	M140	DOE	85	84.8	3.9	73	73.5	3.7
1	350	8	1004240	Escuela Hispana Montessori #2	ACS	Not Available	162.5	5.1	Not Available	78.7	2.6
1	353	44	Not Available	Not Available	Not Available	Not Available	0	0	Not Available	Not Available	Not Available
1	353	54	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	354	80	1004323	M025	DOE	95	98.9	2.6	92	74.6	3
1	355	1	1004325	M020	DOE	97	76.8	3.3	95	56	2.2
1	356	100	1004349	M188	DOE	81	88	3.3	84	93.4	3.7
1	372	14	1004357	Classified Location	DHS	Not Available	352	11.3	Not Available	203.9	7
1	374	20	1004415	M015	DOE	47	169.3	10.9	85	95	5.7
1	381	38	1004564	M034	DOE	56	143.1	6.9	65	103.4	4.9
1	387	1	1004627	M064	DOE	62	119.6	4.7	53	108.2	4.6
1	387	49	1004651	Classified Location	DHS	Not Available	147.9	5.3	Not Available	123.9	4.6
1	394	12	1079053	M061	DOE	54	134.6	5.5	70	114.2	4.8
1	408	30	1005283	M445, M447 Campus: M445	DOE	87	109.2	5.7	86	89.4	4
1	408	30	1005283	M445, M447 Campus: M447	DOE	87	109.2	5.7	86	89.4	4
1	410	38	1005326	Delancey Street Parking Garage	DOT	Not Available	40.2	1	Not Available	20.1	0.5
1	422	72	1005626	M510	DOE	84	116.9	4	82	83.6	3.3
1	423	22	1005645	115 Chrystie Street Office Building	DCAS	95	101.1	2.7	Not Available	104.2	4.1
1	431	14	1005760	M063	DOE	77	90.6	3.5	69	92.5	3.8
1	437	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	439	17	1005974	M060	DOE	62	139.5	7.6	70	108.3	5.3
1	444	22	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	446	20	1006208	M751	DOE	81	121.4	4.5	81	110.3	5.4
1	447	47	1006254	9th Precinct	NYPD	Not Available	292.6	9	Not Available	239.6	7.1
1	453	34	1006478	M019	DOE	91	89.2	3.7	60	92.5	5
1	454	52	1006502	Sirovich Senior SRO Residence	DHS	Not Available	Not Available	Not Available	Not Available	188.3	7.5
1	457	7	1006537	Classified Location	DHS	Not Available	126.4	3.3	Not Available	65.3	1.7
1	458	4	1079828	Classified Location	DHS	Not Available	266.1	9	Not Available	101.7	2.7
1	458	11	1006546	Classified Location	DHS	Not Available	211.6	5.7	Not Available	276.2	14.9
1	462	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	479	1	1007156	Mott Street Neighborhood Senior Center (LL84)	DFTA	Not Available	Not Available	Not Available	Not Available	Not Available	0
1	491	16	1007378	M615	DOE	96	103.7	3.5	73	90.6	3.6
1	495	7	1007523	Ladder Co. 20 and Medical and BFI Division	FDNY	Not Available	265.5	8.3	Not Available	225.5	7.3
1	531	49	1008526	Engine Co. 33 & Ladder Co. 9	FDNY	Not Available	233.3	8.5	Not Available	229.2	8.7
1	543	32	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	544	16	1008774	The Public Theater	CIG > PT	Not Available	349.8	9.1	Not Available	386.6	11.8
1	559	16	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	563	19	1009128	Classified Location	NYPD	77	149.9	5.8	38	113.2	4.6
1	563	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	579	11	1009739	FDNY Museum	FDNY	Not Available	192.7	6.2	Not Available	147.9	5.6
1	581	54	1009757	M641	DOE	Not Available	Not Available	Not Available	91	80.5	3.3
1	582	18	1009760	Hudson Park Branch Library	NYPL	Not Available	134.1	4.1	Not Available	185.5	6.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	582	50	1088894	Tony Dapolito Recreation Center	DPR	Not Available	288.8	10.8	Not Available	166.8	6.9
1	585	41	1009872	M003	DOE	86	65.6	2.7	83	83.3	3.6
1	603	49	1010407	M323	DOE	Not Available	Not Available	Not Available	32	145.1	4.6
1	604	33	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	606	1	1082668	Jefferson Market Branch Library	NYPL	Not Available	210.8	6.9	Not Available	90.1	3.3
1	606	49	1010543	M041	DOE	98	70.1	1.9	92	65.3	3.1
1	620	33	1011192	6th Precinct	NYPD	Not Available	334.2	11.7	Not Available	249.5	8.8
1	644	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	644	10	1089240	High Line Maintenance and Operations Building	DPR	Not Available	Not Available	Not Available	10	266	8
1	665	10	1012261	Pier 76 Tow Pound	NYPD	Not Available	Not Available	Not Available	Not Available	Not Available	0
1	665	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	665	19	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	670	50	1012267	Manhattan Borough Repair Shop	DSNY	Not Available	87	2.8	Not Available	213.7	7.2
1	722	57	1012811	Chelsea Recreation Center	DPR	Not Available	311.3	10	Not Available	245.9	9
1	724	23	1012829	M033	DOE	33	165.7	6.3	55	138.6	5.7
1	724	82	1012830	Chelsea Health Center	DOHMH	Not Available	321.7	11.3	Not Available	233.9	7.8
1	724	100	1089479	Chelsea Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	798.1	21
1	734	66	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	741	10	1079152	M070	DOE	97	68.6	1.8	93	72.5	3.8
1	742	7	1013096	M440	DOE	81	118.2	4.7	78	99.9	4.2
1	744	24	1013260	M011	DOE	80	108.2	5.5	81	99.3	5.1
1	759	8	1013564	14th Precinct (Midtown South)	NYPD	Not Available	295.4	9.9	Not Available	277	10
1	767	68	1013858	M451	DOE	26	172.7	5.2	44	131	4.2
1	769	55	1013994	10th Precinct	NYPD	Not Available	141.1	3.7	Not Available	152.9	6.2
1	773	38	1014150	Muhlenberg Branch Library	NYPL	Not Available	227.4	7.2	Not Available	232.4	7.4
1	774	19	1014174	M600	DOE	91	100	5.6	86	80.6	3.6
1	776	40	1014236	Goodman Resource Center (E Building)	FIT	Not Available	276.4	10.6	Not Available	254.5	9.9
1	777	1	1014250	Dubinsky Student Center (A Building)	FIT	Not Available	359.8	16.7	Not Available	254.5	9.9
1	777	1	1014250	Business and Liberal Arts Center (B Building)	FIT	Not Available	359.8	16.7	Not Available	254.5	9.9
1	777	1	1014250	Dining Hall & Bookstore (West Courtyard Building)	FIT	Not Available	359.8	16.7	Not Available	254.5	9.9
1	777	18	1014251	Feldman Center (C Building)	FIT	Not Available	355.7	16.5	Not Available	254.5	9.9
1	777	37	1014252	Pomerantz Art and Design Center (D Building)	FIT	Not Available	355.2	16.4	Not Available	254.5	9.9
1	777	37	1014252	Conference Center (East Courtyard Building)	FIT	Not Available	355.2	16.4	Not Available	254.5	9.9
1	794	64	1014723	Engine Co. 3 at Ladder Co. 12, Batt. 7	FDNY	Not Available	160.4	5.5	Not Available	150.2	5.2
1	805	82	1015151	Classified Location	NYPD	89	118.1	3.3	Not Available	135.5	6.2
1	842	34	1089902	M868	DOE	Not Available	Not Available	Not Available	63	124.4	4.1
1	855	1	1016743	Manhattan Appellate Court	DCAS	11	354.9	13.8	37	249.4	8.4
1	869	74	1017602	Starvos Niarchos Foundation Library	NYPL	Not Available	Not Available	Not Available	Not Available	13.7	0.6
1	872	13	1017821	FIA/MICSA/IREA/HPA/OLA	HRA	64	220.9	7.2	94	91.2	3
1	872	57	1017828	M460	DOE	96	100.2	5.6	70	102.7	4.8
1	878	16	1018014	M660	DOE	81	135.4	5.3	69	120.8	5
1	878	20	1018015	Baruch College: Lawrence and Eris Field Building	CUNY SC > BAC	Not Available	204.6	5.5	Not Available	135.3	5.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	878	20	1086513	Baruch College: Steven L. Newman Hall	CUNY SC > BAC	Not Available	204.6	5.5	Not Available	135.3	5.7
1	878	20	1086544	Baruch College: Administrative Building	CUNY SC > BAC	Not Available	204.6	5.5	Not Available	135.3	5.7
1	886	51	1018325	Kips Bay Branch Library	NYPL	Not Available	Not Available	Not Available	Not Available	265.2	8.2
1	901	6	1019613	13th Precinct	NYPD	Not Available	200.8	8.1	Not Available	201.3	7.7
1	903	46	1019661	Epiphany Branch Library	NYPL	Not Available	174.2	5.5	Not Available	291.5	9.4
1	904	24	1019775	M047	DOE	51	156.6	7	71	114.2	4.5
1	904	9024	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	913	7	1020080	M116	DOE	91	102.2	4.8	91	73.3	2.8
1	921	64	1020416	M661	DOE	79	182	8.5	81	110.6	4.1
1	922	8	1020419	M475	DOE	86	109.3	5.7	89	89.1	3.8
1	925	12	1020513	M040	DOE	74	104.9	5.1	83	85.4	3.6
1	926	1	1081671	M104	DOE	84	78.2	3.4	94	62.7	2.4
1	932	17	1020610	Public Health Laboratory	DOHMH	Not Available	905.7	46.1	Not Available	473.5	18.8
1	955	1	1022052	M844	DOE	60	156.8	6.5	89	104.8	4.1
1	962	1	1022053	Manhattan Chief Medical Examiner	OCME	Not Available	571.6	23.2	1	535.6	20.2
1	962	50	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	962	97	1087298	Classified Location	DHS	Not Available	238.9	14.4	Not Available	126.9	5.9
1	962	100	1087242	OCME Center for Forensic Sciences	OCME	Not Available	204.5	6.7	Not Available	362.3	13.6
1	962	100	1087295	Bellevue Hospital Center	ACS	Not Available	204.5	6.7	Not Available	362.3	13.6
1	962	100	1069579	Hunter: Brookdale East Building	CUNY SC > HC	Not Available	204.5	6.7	Not Available	362.3	13.6
1	962	100	1069579	Hunter: Brookdale North Building	CUNY SC > HC	Not Available	204.5	6.7	Not Available	362.3	13.6
1	962	100	1069579	Hunter: Brookdale West Building	CUNY SC > HC	Not Available	204.5	6.7	Not Available	362.3	13.6
1	962	100	1086515	Bellevue Hospital: Center	H+H	Not Available	204.5	6.7	Not Available	362.3	13.6
1	962	100	1087295	Bellevue Hospital: Ambulatory Care Building	H+H	Not Available	204.5	6.7	Not Available	362.3	13.6
1	967	2	1089385	M281	DOE	Not Available	Not Available	Not Available	25	181.5	6.1
1	969	22	1083653	Maintenance Facility (BWSO, FMC)	DEP	Not Available	244.9	11.9	Not Available	177.3	7.4
1	970	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	981	2	1022552	Asser Levy Recreation Center and Pool	DPR	Not Available	227.9	5.9	Not Available	301.4	11
1	991	50	1086214	The Skyport Facility	EDC	Not Available	0	0	Not Available	12.6	0.3
1	991	50	Not Available	DockNYC - Skyport Marina (LL84)	EDC	Not Available	0	0	Not Available	12.6	0.3
1	991	59	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	991	60	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	991	61	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	995	5	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	998	41	1069583	M486	DOE	34	216.5	8.4	31	175.2	6.5
1	1008	15	1023391	NY City Center: Manhattan Theater Club	CIG > NYCC	Not Available	142.6	6	Not Available	110.5	4.2
1	1008	15	1023391	NY City Center: New York City Center	CIG > NYCC	Not Available	142.6	6	Not Available	110.5	4.2
1	1009	1	1023449	Carnegie Hall	CIG > CH	Not Available	236.1	9.2	Not Available	240	8.3
1	1009	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1013	12	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1013	29	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1013	39	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1013	41	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1013	57	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1014	17	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1014	20	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1014	25	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1014	33	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1014	39	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1014	41	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1019	61	1024767	Engine Co. 54 and Ladder Co. 4, Batt. 9	FDNY	Not Available	Not Available	Not Available	Not Available	236.8	8.1
1	1030	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1038	14	1025092	M017	DOE	93	90.1	3.4	97	74.4	2.9
1	1043	22	1025241	M058	DOE	97	115.7	5	86	95.4	3.8
1	1044	22	1025397	Midtown Community Court	DCAS	Not Available	Not Available	Not Available	35	221.9	6.8
1	1044	38	1082822	18th Precinct (Midtown North)	NYPD	Not Available	303.7	9.7	Not Available	228.2	8
1	1050	6	1026319	Hunter: Master of Fine Arts Building	CUNY SC > HC	Not available	Not Available	Not Available	Not Available	31.7	1.3
1	1059	15	1026646	M625	DOE	100	80.6	3.6	76	102	3.9
1	1060	63	1026706	Columbus Branch Library	NYPL	Not Available	202	6.3	Not Available	182.2	6.2
1	1062	3	1026740	M111	DOE	60	110.7	5.8	61	102.6	4
1	1065	1	1026841	M834	DOE	43	164.9	5	80	96.4	3
1	1070	44	1026909	Classified Location	NYPD	41	211.6	7.2	Not Available	200	7
1	1072	15	1026924	M912	DOE	Not Available	Not Available	Not Available	51	126.8	3.9
1	1073	14	1089418	M338	DOE	Not Available	Not Available	Not Available	30	169	5.2
1	1079	29	1083802	M535	DOE	48	143.7	6.8	58	120.4	5
1	1079	9029	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1080	103	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1081	80	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1103	44	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1104	1	1087609	Manhattan 4, 4A, 7 District Garage; Salt	DSNY	Not Available	349.6	21.1	Not Available	337.8	15.5
1	1107	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1107	12	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1107	21	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1109	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1109	99	1076222	West 59th St Marine Transfer Station	DSNY	Not Available	72	1.9	Not Available	75.1	2
1	1120	9	1028237	William E. Macaulay Honors College	CUNY SC > MAC	Not Available	293.2	8.9	Not Available	160	4.8
1	1130	1	1083846	American Museum of Natural History	CIG > AMNH	Not Available	326.5	12.8	Not Available	253.6	9
1	1134	5	1028831	David H. Koch Theater	CIG > LCPA	Not Available	326.8	14.6	Not Available	185.3	6.8
1	1134	10	1999999	Damrosch Park Bandshell	DPR	Not Available	Not Available	Not Available	Not Available	542	14.4
1	1134	25	1028832	The Library for the Performing Arts	NYPL	Not Available	348.5	9	Not Available	223.4	5.9
1	1148	14	1030178	M044	DOE	69	78.2	3.5	86	73.2	3.7
1	1149	7	1030196	M087	DOE	89	83	4.2	69	100.1	5.5
1	1151	15	1086545	Gertrude Ederle Recreation Center	DPR	Not Available	53.2	1.4	Not Available	228	9.1
1	1152	29	1030320	M191	DOE	88	99.4	4.7	80	84.6	4.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1154	108	1030328	M837	DOE	43	222.8	6.9	94	72.4	2.6
1	1156	30	1030341	M485	DOE	73	155.2	7.2	48	134.6	5.2
1	1157	25	1030343	M490	DOE	46	194.3	7.8	57	123.5	4.2
1	1158	40	1086824	PS 199 Playground and Comfort Station	DPR	86	95.2	4.7	91	70.6	2.8
1	1158	40	1030351	M199	DOE	86	95.2	4.7	91	70.6	2.8
1	1169	26	1030885	Ladder Co. 25 and Division 3	FDNY	Not Available	299.3	10	Not Available	212.4	7.6
1	1205	6	1081043	Sol Bloom Playground Comfort Station	DPR	66	102.2	5	80	73.5	4
1	1205	6	1081042	M084	DOE	66	102.2	5	80	73.5	4
1	1212	38	1032028	20th Precinct	NYPD	Not Available	337.4	11.9	Not Available	208.6	7.9
1	1214	29	1032119	M009	DOE	93	88.6	4.2	87	79.4	4.6
1	1215	1	1032128	M470	DOE	74	139.3	5.3	89	77.3	3.5
1	1219	47	1032308	M166	DOE	55	127.5	11.6	39	115.9	8
1	1223	5	1032522	M118	DOE	73	125.8	6.7	64	108	5.9
1	1229	31	1032683	St. Agnes Branch Library	NYPL	Not Available	198.1	6.4	Not Available	157.9	5.6
1	1230	1	1032754	M841	DOE	6	171	7.4	79	131.2	6
1	1253	65	1034190	M075	DOE	70	122.9	6.1	80	94	3.7
1	1257	1	1034194	Central Library - Stephen A. Schwartzman Building	NYPL	Not Available	214.1	7.6	Not Available	259.7	8.7
1	1257	2	1085593	Bryant Park Comfort Station (42nd St)	DPR	Not Available	Not Available	Not Available	Not Available	1201.9	31.7
1	1257	2	1085593	Bryant Park Comfort Station (40th St)	DPR	Not Available	Not Available	Not Available	Not Available	1201.9	31.7
1	1319	11	1037587	Classified Location	DHS	Not Available	332.5	11.2	Not Available	272.7	9.1
1	1330	13	1088892	M488	DOE	Not Available	Not Available	Not Available	42	154.1	4.6
1	1336	31	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1346	32	1039840	Recreation Center 54	DPR	Not Available	243.2	6.3	Not Available	205	9.8
1	1373	1	Not Available	Roosevelt Island Motorgate Ramp Lighting	DOT	8	230.2	6.1	Not Available	268.7	7.2
1	1373	1	1083213	Special Operations Command	FDNY	8	230.2	6.1	Not Available	268.7	7.2
1	1373	1	1999999	Roosevelt Island Main Pumping Station	DEP	8	230.2	6.1	Not Available	268.7	7.2
1	1373	1	1999999	Roosevelt Island Pumping Station	DSNY	8	230.2	6.1	Not Available	268.7	7.2
1	1373	1	1084848	M271	DOE	8	230.2	6.1	Not Available	268.7	7.2
1	1373	1	1999999	Roosevelt Island Ferry Landing	EDC	8	230.2	6.1	Not Available	268.7	7.2
1	1373	1	1999999	M819 (Out of service)	DOE	8	230.2	6.1	Not Available	268.7	7.2
1	1373	50	1040750	Coler-Goldwater Hospital: Coler Hospital	H+H	55	426.1	22.6	100	194	7.6
1	1380	30	1041133	Hunter: Roosevelt House	CUNY SC > HC	Not available	Not Available	Not Available	Not Available	195	6
1	1389	50	1041666	The Met, Breuer Building	CIG > MMA	Not Available	Not Available	Not Available	Not Available	Not Available	0
1	1401	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1402	24	1042470	Hunter: Baker Hall	CUNY SC > HC	Not Available	Not Available	Not Available	Not Available	59.8	2.5
1	1402	25	1042471	Eng39, Lad16, Pct19: 19th Precinct	NYPD	Not Available	398.2	15.7	Not Available	371.2	14.6
1	1402	29	1072190	Eng39, Lad16, Pct19: Eng.Co.39, Ladd.Co.16	FDNY	Not Available	402.5	15.8	Not Available	371.2	14.6
1	1403	1	1081419	Hunter: North Building	CUNY SC > HC	Not Available	204.5	6.7	Not Available	348.6	11.9
1	1403	1	1081418	Hunter: Thomas Hunter Hall	CUNY SC > HC	Not Available	204.5	6.7	Not Available	348.6	11.9
1	1418	7	1087680	M267	DOE	6	292	11.2	11	209.4	7.7
1	1430	5	1044058	M167	DOE	70	81.7	4	92	63.8	3.4
1	1434	1	1044193	Queensborough Bridge Ramp Shop	DOT	Not Available	247	13.2	Not Available	284.6	11.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1441	38	1044749	67th Street Branch Library	NYPL	Not Available	172.7	5.6	Not Available	142.6	4.9
1	1442	1	1083343	M480	DOE	94	108.2	5.9	75	117	5.5
1	1451	17	1045173	M471 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	96.3	2.9
1	1454	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1461	7	1045569	M183, M390 Campus: M183	DOE	87	108	4.7	85	91.9	4.3
1	1471	5	1045949	M855	DOE	25	226.4	6.4	58	125.2	3.8
1	1472	28	1045991	Webster Branch Library	NYPL	Not Available	211.4	7.1	Not Available	206	7.1
1	1488	17	1046409	John Jay Park Comfort Station	DPR	Not Available	109.8	3	Not Available	165.2	4.8
1	1488	17	1046409	John Jay Park, Pool and Comfort Station	DPR	Not Available	109.8	3	Not Available	165.2	4.8
1	1489	1	1046411	M158	DOE	97	104.9	3.7	63	106	3.9
1	1493	21	1046668	M006	DOE	56	137.6	6.8	75	95.4	4.2
1	1506	21	1047404	Hunter: Hunter College High School	CUNY SC > HC	Not Available	204.5	6.7	48	110.3	3
1	1524	23	1048492	M198	DOE	76	118	5.9	95	64.5	2.4
1	1524	64	1048501	96th Street Branch Library	NYPL	Not Available	205.9	6.7	Not Available	160.2	5.2
1	1545	5	1049876	M190	DOE	96	104.8	3.8	69	105.5	4.4
1	1554	15	1050217	M816	DOE	100	29.8	0.8	88	72.9	4.2
1	1554	23	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1554	32	1081267	M114	DOE	Not available	Not Available	Not Available	28	158.6	4.7
1	1558	34	1050338	M645	DOE	89	76.4	3.2	88	68.4	3.3
1	1568	8	1050618	M066	DOE	79	114.9	3.9	72	91.7	3.3
1	1570	29	1050735	Metropolitan Museum of Art Storage	CIG > MMA	1	499.3	16.5	1	315.4	9.9
1	1587	1	1085696	Asphalt Green Recreation Facility	DPR	Not Available	925	28.3	Not Available	430.1	15
1	1587	27	1999999	East 91st Street Marine Transfer Station	DSNY	Not available	Not Available	Not Available	Not Available	230	6.1
1	1595	15	1051410	M185, M208 Campus: M185	DOE	97	53.1	2.3	91	88	4.7
1	1595	15	1051410	M185, M208 Campus: M208	DOE	97	53.1	2.3	91	88	4.7
1	1601	1	1051434	M149, M207 Campus: M149	DOE	31	142.8	6.4	74	139.6	5.7
1	1601	1	1051434	M149, M207 Campus: M207	DOE	31	142.8	6.4	74	139.6	5.7
1	1609	1	1074157	Museum of the City of New York	CIG > MCNY	Not Available	240.3	8	Not Available	238.8	7.5
1	1609	7	1051497	M171	DOE	70	110.8	4.3	70	106.4	4.2
1	1610	1	1051499	El Museo Del Barrio	CIG > MB	Not Available	412	10.7	Not Available	279.4	7.8
1	1612	50	1051515	M013	DOE	84	96.2	4.8	92	74.1	4.3
1	1614	21	1051584	M108	DOE	60	76.1	3.6	84	80.9	4.2
1	1618	14	1080501	Engine Co. 58 and Ladder Co. 26	FDNY	Not Available	Not Available	Not Available	Not Available	159.6	5.7
1	1628	24	1051796	Classified Location	DHS	Not Available	398	16.5	Not Available	303.1	12
1	1628	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1629	40	1051850	23rd Precinct and Engine Company 53	NYPD	Not Available	Not Available	Not Available	Not Available	330.2	10.4
1	1632	11	1081340	M072	DOE	74	113.8	4.5	79	92.8	3.3
1	1633	13	1051991	M107 (The Heritage High School)	DOE	Not available	Not Available	Not Available	Not Available	49.6	1.4
1	1633	13	1051991	1680 Lexington Ave - DCAS	DCAS > NA	Not available	Not Available	Not Available	Not Available	49.6	1.4
1	1633	13	1086927	1680 Lexington Ave - EDC	EDC	Not available	Not Available	Not Available	Not Available	49.6	1.4
1	1633	13	1051991	1680 Lexington Avenue / Julia DeBurgos Latino Cultural Center (LL84)	EDC	Not available	Not Available	Not Available	Not Available	49.6	1.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1637	141	1052167	Aguilar Branch Library	NYPL	Not Available	291.3	9.1	Not Available	138.8	4.7
1	1639	3	1081346	M101	DOE	40	109.6	5.6	90	83.4	3.3
1	1640	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1640	139	1083184	M057	DOE	14	168.4	7	55	121.6	4.7
1	1640	147	1052229	East Harlem Health Center	DOHMH	Not Available	146.3	5.5	Not Available	127.7	5.3
1	1652	16	1052384	M121	DOE	85	111	4.1	54	132.5	5.9
1	1654	33	1075643	M495	DOE	84	100.5	4.5	91	77.9	3.5
1	1656	100	1052433	M117	DOE	70	131.1	6.6	71	103	5.4
1	1659	12	1052436	M083	DOE	56	122.6	6	68	107	5.3
1	1660	30	1052473	Engine Co. 91	FDNY	Not Available	216.1	8.1	Not Available	112.4	3.7
1	1668	1	1083925	Marx Brothers Playground Comfort Station	DPR	43	170	6.1	54	116.4	4.5
1	1668	1	1083927	M646	DOE	43	170	6.1	54	116.4	4.5
1	1669	1	1083929	Metropolitan Hospital: Main Building	H+H	100	205.1	5.3	95	301.1	10.5
1	1669	1	1083930	Metropolitan Hospital: Mental Health Building	H+H	100	205.1	5.3	95	301.1	10.5
1	1669	1	1088663	Metropolitan Hospital: OPD Building	H+H	100	205.1	5.3	95	301.1	10.5
1	1671	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1671	20	1089407	Manhattan 11 District Garage	DSNY	Not Available	55.1	1.4	Not Available	101.4	4.8
1	1680	45	1074278	Leonard Covello Senior Center	DFTA	Not Available	121.9	5	Not Available	152.5	6.1
1	1681	37	1052845	Animal Shelter - Manhattan	DOHMH	Not Available	687.5	20.9	Not Available	502.6	15.2
1	1684	101	1081366	M102	DOE	53	121.1	6.7	51	112.1	6.5
1	1689	5	1086937	PS 155 Playground Comfort Station	DPR	76	105.9	5.5	90	71.3	3.7
1	1689	5	1052986	M155	DOE	76	105.9	5.5	90	71.3	3.7
1	1691	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1693	1	1052998	M099	DOE	77	123	4.7	74	109.1	4.2
1	1694	1	1083933	M050	DOE	49	135.9	5	85	83.8	2.9
1	1694	3	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1700	1	1052999	M146	DOE	62	105.4	4.9	95	71.3	2.7
1	1705	1	1085632	Thomas Jefferson Recreation Center	DPR	Not Available	322.7	11.3	Not Available	277.5	10.4
1	1710	27	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1713	1	1053152	M435	DOE	79	179.5	6.5	86	77.6	3.1
1	1719	1	1083967	Mt. Morris Park Recreation Stand	DPR	Not Available	143.3	3.7	Not Available	230.1	10.1
1	1719	1	1083971	Marcus Garvey Park Pool	DPR	Not Available	143.3	3.7	Not Available	230.1	10.1
1	1719	1	1083967	Pelham Fritz Recreation Center	DPR	Not Available	143.3	3.7	Not Available	230.1	10.1
1	1722	30	1053460	Harlem Branch Library	NYPL	Not Available	217.6	6.9	Not Available	202.4	6.5
1	1730	55	1081456	Hansborough Pool and Recreation Center	DPR	Not Available	104.6	2.7	Not Available	1445.2	84.6
1	1733	1	1053899	EMS 16 (Harlem Hospital)	FDNY	52	433.2	15.5	90	402.1	14.8
1	1733	1	1053899	Harlem Hospital: Martin Luther King Pavilion	H+H	52	433.2	15.5	90	402.1	14.8
1	1733	17	1086941	Howard Bennett Playground Comfort Station	DPR	70	91.5	3.2	87	66.7	2.7
1	1733	17	1076433	M197	DOE	70	91.5	3.2	87	66.7	2.7
1	1734	1	1082167	Harlem Hospital: Kountz Pavilion	H+H	52	433.2	15.5	90	402.1	14.8
1	1734	1	1082172	Harlem Hospital: Ronald H. Brown Ambulatory Care Pavilion	H+H	52	433.2	15.5	90	402.1	14.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1734	1	1082170	Harlem Hospital: Women's Pavilion	H+H	52	433.2	15.5	90	402.1	14.8
1	1734	1	1082167	Harlem Hospital Center Campus: Mural Pavilion	H+H	52	433.2	15.5	90	402.1	14.8
1	1734	34	1053900	Central Harlem Health Center	DOHMH	Not Available	170	5.9	Not Available	143.9	4.9
1	1735	27	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1735	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1736	23	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1736	25	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1740	17	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1745	5	1076434	Classified Location	DHS	Not Available	221.2	8	Not Available	183.5	6.9
1	1747	1	1053968	M079	DOE	83	97	4.3	90	77.1	3.8
1	1747	35	1077376	Henry J. Carter Hospital	H+H	Not Available	Not Available	Not Available	83	340.8	11.4
1	1747	70	1088883	Henry J. Carter Hospital - Skilled Nursing Facility	H+H	Not Available	Not Available	Not Available	Not Available	346.6	10.6
1	1751	69	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1752	22	1054156	M501	DOE	87	109.4	5.1	61	115.1	5.7
1	1752	59	1054159	M911	DOE	67	119.3	5.2	70	104.3	5.5
1	1754	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1755	1	1054276	M133	DOE	70	120.9	6.3	16	171.9	10.4
1	1767	28	1088302	Hunter: Silberman School of Social Work	CUNY SC > HC	Not Available	Not Available	Not Available	Not Available	176	5.3
1	1767	30	1088293	Graduate Center Housing	CUNY SC > GC	Not Available	Not Available	Not Available	97	57.6	2.9
1	1767	62	1054360	25th Precinct	NYPD	Not Available	173.2	5.9	Not Available	152	5.4
1	1768	21	1083501	M007	DOE	45	147.9	7.7	60	102.3	4
1	1769	45	1054382	Harlem Courthouse	DCAS	35	231.7	9.2	49	162.9	9.2
1	1772	31	1054433	Manhattan Lot Cleaning	DSNY	Not Available	129.2	4.1	Not Available	130.9	4.2
1	1776	20	1054502	M030	DOE	55	123.1	4.3	76	130.4	5.3
1	1779	1	1054511	Manhattan 10 District Garage	DSNY	Not Available	77.2	2	Not Available	192.1	8.2
1	1784	12	1074333	M096	DOE	76	104.9	4.3	33	131.9	6
1	1789	37	1054674	125th Street Branch Library	NYPL	Not Available	117.6	4.4	Not Available	Not Available	Not Available
1	1797	100	1054786	M045	DOE	70	96.8	3.3	99	76.5	3
1	1797	110	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1808	8	1054888	East Harlem Multi Service Center	HRA	99	72.4	1.9	100	27	0.7
1	1816	1	1084005	M112, M206 Campus: M112	DOE	71	108.5	4.6	87	82.5	3
1	1816	1	1084005	M112, M206 Campus: M206	DOE	71	108.5	4.6	87	82.5	3
1	1819	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1819	40	1811074	Fire Academy: Fire Academy Complex	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088007	Fire Academy: Building 13 - Mand Library	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088008	Fire Academy: Building 14 - Subway Simulator	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088009	Fire Academy: Building 9 - Administration	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088010	Fire Academy: Building 11 - Administration	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088011	Fire Academy: Building 12 - Field House	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088012	Fire Academy: Building 10 - Operations Warehouse	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088013	Fire Academy: Building 7 - Mask Services Unit	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088014	Fire Academy: Building 8 - Haz Mat Ops	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1819	40	1088016	Fire Academy: Building 6 - Fleet Services Workshop	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088017	Fire Academy: Building 3 - Training	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088018	Fire Academy: Building 4 - Training - Old Law Tenement	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088019	Fire Academy: Building 5 - Training - Fire Simulator	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088020	Fire Academy: Building 2 - Smoke House	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088021	Fire Academy: Building 1 - Leary Firefighting Building	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088238	Fire Academy: Subway Simulator Woodshed	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1819	40	1088257	Fire Academy: Con Ed Transformer Vault	FDNY	Not Available	Not Available	Not Available	Not Available	214	8.1
1	1825	49	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1828	15	1055111	M113	DOE	29	141.2	7.3	87	100.2	3.9
1	1830	19	1055204	M088	DOE	53	158.2	6.4	52	132.7	5.4
1	1830	47	1055204	M088 - Gymnasium	DOE	Not Available	Not Available	Not Available	52	132.7	5.4
1	1831	25	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1831	26	1055236	115th Street Branch Library	NYPL	Not Available	186.4	6.5	Not Available	193.9	6
1	1849	27	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1850	2	1055890	M036	DOE	41	170.8	8.5	66	110	4.3
1	1852	49	1055906	Riverside Health Center	DOHMH	Not Available	113	4.5	Not Available	150.3	4.6
1	1852	49	1055906	Bloomingtondale Branch Library	NYPL	Not Available	113	4.5	Not Available	150.3	4.6
1	1852	99	1055908	M163, M919 Campus: M163	DOE	82	106.8	5.1	86	80.1	4.3
1	1855	5	1055910	24th Precinct	NYPD	Not Available	202.2	5.7	Not Available	187.3	7
1	1855	9	1055911	M506	DOE	45	186.5	5.8	49	137.9	4.9
1	1859	1	1076625	Bloomingtondale Playground Comfort Station	DPR	65	124.2	5.9	82	86.3	3.3
1	1859	1	1076625	M145	DOE	65	124.2	5.9	82	86.3	3.3
1	1862	11	1055990	M054	DOE	82	99.2	4.7	85	80.1	4.1
1	1863	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1863	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1876	20	1056586	Classified Location	DHS	Not Available	168.4	7	Not Available	126.4	5.6
1	1880	13	1056676	M165	DOE	15	97.5	3.6	82	81.1	3.2
1	1903	38	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1903	64	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1904	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1906	11	1057683	M144	DOE	78	122.5	5.7	88	83.2	3.9
1	1910	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1910	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1911	43	1057874	Classified Location	HRA	Not Available	99.2	3.7	Not Available	151.6	6.2
1	1912	12	1057904	Help Harbor Transitional Housing Site I	HRA	Not Available	172.7	6.4	90	88.1	3.5
1	1913	54	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1914	17	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1919	6	1058248	M175	DOE	68	119.1	5.8	82	93	4.9
1	1920	26	1058275	Schomburg Black History Library	NYPL	Not Available	304.9	13.1	Not Available	289.6	9.9
1	1920	26	1058275	Countee Cullen Branch Library	NYPL	Not Available	304.9	13.1	Not Available	289.6	9.9
1	1920	29	1058276	Schomburg Center/Research in Black Culture	NYPL	Not Available	43.6	1.1	Not Available	58	1.5

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1921	50	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1922	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1923	53	1058399	Sydenham Health Center	H+H	Not Available	Not Available	Not Available	Not Available	437.3	14.7
1	1925	19	1058447	M081	DOE	70	106	5.7	93	75.7	3.8
1	1925	38	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1925	40	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1926	17	1058470	M076	DOE	65	137.3	6.2	71	110.8	4.2
1	1930	55	1058649	Mart 125	EDC	Not Available	Not Available	Not Available	46	151.7	5.2
1	1930	55	Not Available	Mart 125 (LL84)	EDC	Not Available	Not Available	Not Available	46	151.7	5.2
1	1932	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1932	10	1058671	M154	DOE	74	107.4	4.6	86	90.1	4.6
1	1933	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1938	20	1058776	M484	DOE	Not available	Not Available	Not Available	69	88.6	3.7
1	1939	11	1058808	M092	DOE	83	91.1	4.4	99	54.3	2.2
1	1940	35	1058843	M970	DOE	17	220.8	6.7	55	129.7	4.2
1	1940	48	1075467	32nd Precinct	NYPD	Not Available	187.1	5	Not Available	233.3	9.5
1	1943	18	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1944	4	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1945	51	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1946	1	1059111	M180	DOE	41	122.9	4.2	61	112.3	4.4
1	1949	29	1059240	28th Precinct	NYPD	Not Available	189.6	5	Not Available	194.4	8.1
1	1957	1	1084075	CCNY: Aaron Davis Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1084067	CCNY: Mott Hall - DOE	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1084069	CCNY: Schiff House - Child Care Center	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1084073	CCNY: Spitzer School of Architecture	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1084068	CCNY: Structural Biology Center	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1084067	M223	DOE	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1813294	ASRC - Advanced Science Research Center	CUNY SC	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	1	1088609	CCNY: Center for Discovery and Innovation	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	10	1059407	M129	DOE	72	102.3	5.3	73	85.7	4.6
1	1957	78	1059409	M540	DOE	66	133.1	4.9	71	104.5	4.3
1	1957	100	1059410	CCNY: Marshak Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	100	1088597	CCNY: Vivarium	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	105	1085670	CCNY: Howard E. Wille Administration Building	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	105	1084077	CCNY: Shepard Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	129	1084078	CCNY: Steinman Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	200	1084085	CCNY: Baskerville Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	200	1084083	CCNY: Compton Goethals Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	200	1084082	CCNY: Harris Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	200	1084081	CCNY: North Academic Center	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1957	200	1084084	CCNY: Wingate Hall	CUNY SC > CCNY	Not Available	251.1	7.6	Not Available	310.6	10.9
1	1960	1	1059460	M136	DOE	72	96.8	3.7	71	99.7	4.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	1964	12	1059526	M125	DOE	59	143.5	7.6	85	107.3	5.8
1	1966	44	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1967	24	1084102	M916	DOE	Not Available	Not Available	Not Available	60	102.3	4
1	1968	23	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1968	24	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1968	25	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1968	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1968	35	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1968	37	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1969	65	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1969	66	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1971	1	1059645	M161	DOE	87	102.9	4.1	87	76.4	3.4
1	1982	38	1076682	26th Precinct	NYPD	Not Available	216.3	5.8	Not Available	238.6	10.6
1	1982	65	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1983	3	1059720	Manhattanville Health Center	DOHMH	Not Available	124.2	4.8	Not Available	113.2	4.5
1	1984	33	1059723	M043	DOE	44	119.1	4.7	79	102.3	4.1
1	1988	8	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1988	12	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1988	27	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1988	40	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1988	53	1059778	Offices Home Care and HASA services	HRA	35	249.6	7.7	68	166.9	5.3
1	1988	131	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	1988	166	1084132	M192, M848 Campus: M192	DOE	Not available	Not Available	Not Available	85	88.8	3.5
1	1988	166	1084132	M192, M848 Campus: M848	DOE	Not available	Not Available	Not Available	85	88.8	3.5
1	2001	5	1059942	M195	DOE	73	125.6	5.2	86	87.4	3.9
1	2001	9005	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2007	39	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2007	41	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2009	8	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2009	46	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2010	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2011	18	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2013	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2016	100	1060198	M010, M200 Campus: M010	DOE	83	86.2	4	68	101.2	5.3
1	2016	100	1060198	M010, M200 Campus: M200	DOE	83	86.2	4	68	101.2	5.3
1	2028	51	1075491	Engine Co. 69 and Ladder Co. 28, Batt. 16	FDNY	Not Available	267.3	7.7	Not Available	227	6.8
1	2029	11	1060432	M194	DOE	45	140.8	6.7	46	135.6	5.7
1	2032	17	1060503	Lutheran Social Service of NY #13	ACS	Not Available	193.6	5.1	Not Available	Not Available	0
1	2033	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2042	35	1060726	M123	DOE	62	89.2	4	94	62.9	2.4
1	2052	1	1089147	Jackie Robinson Park 149th Street Comfort Station	DPR	Not Available	174.7	4.5	Not Available	243.2	10.5
1	2052	1	1084165	Jackie Robinson Park 151st Street Comfort Station	DPR	Not Available	174.7	4.5	Not Available	243.2	10.5

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	2052	1	1084164	Jackie Robinson Park Pool and Rec Center	DPR	Not Available	174.7	4.5	Not Available	243.2	10.5
1	2054	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2060	1	1061339	Lower Washington Heights NFCC Clinic	H+H	16	371.2	13.5	2	397.4	15.4
1	2061	61	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2066	9	1081826	30th Precinct	NYPD	Not Available	265.2	9	Not Available	195.4	6.5
1	2066	61	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2067	50	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2069	26	1075503	Manhattan Sewer Maintenance Yard	DEP	Not Available	126.6	4.6	Not Available	136.8	6.2
1	2070	21	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2070	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2071	27	1075504	Engine Co. 80 and Ladder Co. 23	FDNY	Not Available	45.7	1.3	Not Available	310.6	10.9
1	2071	27	1083671	CCNY: Storehouse	CUNY SC > CCNY	Not Available	45.7	1.3	Not Available	310.6	10.9
1	2072	27	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2074	6	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2075	46	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2076	41	1061917	Lutheran Social Service of NY #14	ACS	Not Available	167.4	4.9	Not Available	115.4	3.5
1	2077	26	1061938	Hamilton Grange Branch Library	NYPL	Not Available	155.7	5.1	Not Available	215.2	6.6
1	2078	19	1081834	M153	DOE	67	114.1	4.1	81	77.7	2.9
1	2079	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2084	129	1087824	M093	DOE	7	225.7	6.3	8	216.5	6.8
1	2088	84	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2097	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2101	120	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2105	1	1076737	Classified Location	DHS	Not Available	159.7	4.1	Not Available	263.8	14.2
1	2105	1	1087016	Holcombe Rucker Playground Comfort Station	DPR	Not Available	159.7	4.1	Not Available	263.8	14.2
1	2106	1	1085868	Highbridge Recreation Center	DPR	Not Available	299.8	12	Not Available	268.1	9.6
1	2106	50	1082090	M046, M846 Campus: M046	DOE	87	52.2	1.5	97	40.6	1.2
1	2106	50	1082090	M046, M846 Campus: M846	DOE	87	52.2	1.5	97	40.6	1.2
1	2107	26	1087018	Wright Brothers Playground-Comfort Station	DPR	63	124.2	5.8	94	64.3	3.3
1	2107	26	1076739	M028	DOE	63	124.2	5.8	94	64.3	3.3
1	2108	23	1062503	United Federation of Black Community	ACS	Not Available	173.1	4.6	Not Available	157.8	4.2
1	2108	68	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2109	55	1062551	Washington Heights Branch Library	NYPL	Not Available	129.5	5	Not Available	121.4	4.6
1	2110	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2110	21	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2110	22	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2110	23	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2110	74	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2111	24	1062636	M164	DOE	39	146.8	5.9	48	116.9	4.8
1	2111	47	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2111	58	1062652	MAQR (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	Not Available	0
1	2112	1	1081842	M008	DOE	51	148.2	4.6	67	107.1	3.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	2112	10	1086200	33rd Precinct	NYPD	Not Available	312.9	10.1	Not Available	335.2	10.9
1	2112	58	1076741	M090	DOE	58	137.9	4.5	57	119.7	4
1	2116	21	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2116	31	1089242	M814	DOE	Not Available	Not Available	Not Available	21	186.3	6.3
1	2118	22	1062792	M004	DOE	43	176.4	5.5	42	144.5	4.9
1	2120	46	1062872	Engine Co. 84 and Ladder Co. 34	FDNY	Not Available	236	8.4	Not Available	185.7	6.3
1	2123	45	1085733	M876	DOE	2	299.3	8.5	7	230	7
1	2123	98	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2124	43	1087469	Audubon Building	EDC	99	83.5	3.1	100	64.8	2.1
1	2125	1	1062994	M128	DOE	56	129.4	6.1	87	86.6	4
1	2125	45	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2126	44	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2128	55	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2129	9	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2130	39	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2131	41	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2131	50	1089166	Highbridge Park/Wallenberg Playground Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	285.7	19.4
1	2133	40	1063228	M115	DOE	62	107.5	4.3	52	121.6	4.7
1	2138	24	1063379	Washington Heights Health Center	DOHMH	Not Available	615.7	34.1	Not Available	179.1	6.8
1	2138	79	1063381	Classified Location	DHS	Not Available	188.9	6.6	Not Available	169.9	6
1	2142	154	1063503	M173	DOE	45	127.3	5.2	36	114.2	4.9
1	2150	30	1089168	Swindler Cove Park	DPR	36	155.8	4.9	65	92.5	3
1	2150	30	1084201	M005, M921 Campus: M005	DOE	36	155.8	4.9	65	92.5	3
1	2153	53	1063632	Fort Washington Branch Library	NYPL	Not Available	235.5	8.2	Not Available	117.6	4.5
1	2155	30	1075518	Engine Co. 93, Ladder Co. 45 and Batt. 13	FDNY	Not Available	206.7	7	Not Available	159.8	5.8
1	2155	35	1063703	M143	DOE	93	87.7	3.5	85	89.5	4.8
1	2157	93	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2159	51	1076750	M189	DOE	60	113.8	4.5	7	218.8	10.3
1	2160	18	1076751	M465, M466, M965 Campus: M465	DOE	65	161.7	8.5	70	105.3	5.6
1	2160	18	1076751	M465, M466, M965 Campus: M965	DOE	65	161.7	8.5	70	105.3	5.6
1	2161	128	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2161	130	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2164	32	1063928	M528	DOE	66	206.1	7	30	163	5.3
1	2165	26	1063947	M132	DOE	87	86.1	3.3	44	144.5	7.7
1	2167	29	1076752	M048, M902 Campus: M048	DOE	36	158.7	4.8	58	144.5	4.4
1	2171	36	1064128	M178	DOE	74	110.4	3.5	50	112.4	3.5
1	2172	16	1076756	M218	DOE	84	107	4.5	81	81.4	3.5
1	2173	1	1064149	M152, M847 Campus: M152	DOE	39	134.8	6	74	98.5	5.2
1	2173	1	1064149	M152, M847 Campus: M847	DOE	39	134.8	6	74	98.5	5.2
1	2179	365	1064371	M187	DOE	26	114.3	4.7	52	114.4	4.8
1	2179	701	1090510	Fort Tryon Park Building A	DPR	Not Available	312.2	8.1	Not Available	147.4	3.9
1	2179	701	1064383	The Cloisters	CIG > MMA	Not Available	312.2	8.1	Not Available	147.4	3.9

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
1	2179	701	1064383	Fort Tryon Park Building C (The Cloisters)	DPR	Not Available	312.2	8.1	Not Available	147.4	3.9
1	2180	108	1064415	34th Precinct	NYPD	Not Available	326.5	10	Not Available	245.9	7.7
1	2186	9	1081892	Harlem River Bridge Shop	DOT	Not Available	186.1	6.1	Not Available	136.3	4.7
1	2196	1	1064485	Manhattan 8/12 District Garage	DSNY	Not Available	140.2	3.9	Not Available	233.3	12.7
1	2198	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2212	1	Not Available	BX 7, BX 8, MN 8 District Garage	DSNY	Not Available	243.6	9.8	Not Available	237.5	10
1	2213	1	1064513	Dyckman Job Center, Wash. Heights SNAP	HRA	11	368.1	10.7	43	199.3	6.2
1	2215	824	1082045	M898, M884 Campus: M884	DOE	95	143.6	4.3	98	94.6	3.1
1	2215	824	1082045	M898, M884 Campus: M898	DOE	95	143.6	4.3	98	94.6	3.1
1	2215	831	1064704	M918	DOE	88	92.5	2.8	82	85.4	2.9
1	2218	13	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
1	2226	41	1081910	M263	DOE	Not Available	Not Available	Not Available	15	184.2	6
1	2229	12	1064871	M098, M845 Campus: M098	DOE	35	120.3	9.9	25	112.2	7.6
1	2229	12	1064871	M098, M845 Campus: M845	DOE	35	120.3	9.9	25	112.2	7.6
1	2233	13	1064894	Inwood Branch Library	NYPL	Not Available	181.1	5.9	Not Available	Not Available	Not Available
1	2233	20	1076776	M052	DOE	62	115.7	5.6	62	114.9	6
1	2234	7	1064900	M176	DOE	78	136.4	4.4	55	122.6	4.2
2	2267	15	2000077	X030	DOE	49	120.5	6	80	105	6
2	2269	21	2090354	Segundo Ruiz Belvis Diagnostic and Treatment Center	H+H	48	268.2	9.2	15	282.3	9.9
2	2274	23	2000114	X027	DOE	42	119.5	5	74	93.9	3.6
2	2276	1	2000133	Horizon Juvenile Center	ACS	Not Available	154.4	4.7	Not Available	128.9	3.6
2	2280	40	2000205	X043	DOE	84	91.2	4.3	85	91	4
2	2284	34	2000308	X040	DOE	85	98.2	4.4	79	84	3.3
2	2284	34	2127605	Saw Mill Playground Comfort Station and Storage Room	DPR	85	98.2	4.4	79	84	3.3
2	2286	36	2000391	X139	DOE	43	122.9	6	81	94.8	4.6
2	2298	1	2102821	Lozada Playground Comfort Station	DPR	74	96.7	4.5	64	93.8	5.1
2	2298	1	2097030	X154	DOE	74	96.7	4.5	64	93.8	5.1
2	2302	40	2000626	X049	DOE	57	95.8	4.6	89	83.9	4.5
2	2303	58	2000645	Lincoln Detox Center Clinic	H+H	68	171.5	6.5	100	1.1	0
2	2306	52	2000656	Engine Co. 60 and Ladder Co. 17, Batt. 14	FDNY	Not Available	226.6	7.5	Not Available	230	7.8
2	2306	54	2117376	Clark Playground Comfort Station	DPR	87	97.4	4.1	92	78	3.7
2	2306	54	2097038	X149	DOE	87	97.4	4.1	92	78	3.7
2	2314	30	2000700	40th Precinct	NYPD	Not Available	445.8	14.3	Not Available	443.5	15.9
2	2315	18	2000744	Mott Haven Branch Library	NYPL	Not Available	264.4	7.8	Not Available	151.1	4.4
2	2323	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2324	8	2000816	X018	DOE	92	77.5	5.5	83	102.8	3.8
2	2329	75	2000876	X807	DOE	7	304.5	9.2	80	81.7	3.3
2	2331	22	2000927	East 149th Street Parking Garage	DOT	Not Available	Not Available	Not Available	Not Available	22	0.6
2	2333	70	2000957	X183	DOE	52	115.1	4.8	87	94.9	4.3
2	2335	6	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2335	16	2097050	Lincoln Medical and Mental Health Center	H+H	87	341.1	11.4	99	262	8.7
2	2335	16	2097050	EMS 14 (Lincoln Hospital)	FDNY	87	341.1	11.4	99	262	8.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2340	72	2000978	Rider Job Center #38	HRA	65	191.4	5.1	59	173.3	6
2	2341	58	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2343	14	2090411	Hostos CC: East Academic Complex - C	CUNY CC > HCC	Not available	Not Available	Not Available	Not Available	132.5	3.9
2	2344	96	2001027	X884	DOE	67	123.6	3.8	79	98.8	3.2
2	2346	29	2001038	Hostos CC: Allied Health and Sciences Building - A	CUNY CC > HCC	Not Available	174.9	5.6	Not Available	132.5	3.9
2	2349	103	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2349	107	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2350	24	2001088	Hostos CC: Administration Building - G	CUNY CC > HCC	Not Available	174.9	5.6	Not Available	132.5	3.9
2	2350	24	2092185	Hostos CC: Trailer Site #6 (471 Lot)	CUNY CC > HCC	Not Available	174.9	5.6	Not Available	132.5	3.9
2	2350	39	2001091	Hostos CC: Savoy Building D	CUNY CC > HCC	Not available	Not Available	Not Available	Not Available	132.5	3.9
2	2352	28	2001102	Manhattan 9 District Garage	DSNY	Not Available	128.5	4.7	Not Available	294.4	16.5
2	2353	57	2117641	Classified Location	DHS	Not Available	0	0	Not Available	252	7
2	2356	20	2001147	Gateway Plaza	EDC	Not Available	Not Available	Not Available	Not Available	132.5	3.9
2	2356	20	2001147	Hostos CC: Prow Building - CEWD	CUNY CC > HCC	Not Available	Not Available	Not Available	Not Available	132.5	3.9
2	2359	240	2001153	X470, X920 Campus: X470	DOE	23	130.3	4.7	71	104.2	4.2
2	2359	240	2001153	X470, X920 Campus: X920	DOE	23	130.3	4.7	71	104.2	4.2
2	2365	1	2001194	42nd Precinct	NYPD	Not Available	142.4	3.9	Not Available	177.6	7.3
2	2368	39	2001228	South East Bronx Neighborhood Center Inc.	ACS	Not Available	138.8	3.6	Not Available	85.6	2.3
2	2377	1	2001400	Engine Co. 71 and Ladder Co. 55, Division 6	FDNY	Not Available	275.7	9.7	Not Available	210.4	7.7
2	2383	12	2001505	Fulton Day Care Center	ACS	Not Available	180.6	4.9	Not Available	115.2	3.2
2	2388	45	2001584	Engine Co. 50 and Ladder Co. 19, Batt. 26	FDNY	Not Available	234.7	7.7	Not Available	203	7
2	2390	1	2001619	X132	DOE	50	107.7	5.3	99	45	3.3
2	2403	1	2001736	X029	DOE	78	104.4	5	72	87.4	4.3
2	2411	22	2001874	X600	DOE	79	108.3	6	86	80.9	4.6
2	2411	22	2001874	X601	DOE	79	108.3	6	86	80.9	4.6
2	2411	41	2001876	Philip Michaels Day Care Center	ACS	Not Available	200.1	5.2	Not Available	Not Available	0
2	2411	119	2001881	X001	DOE	93	70.9	3.5	82	82.3	4.7
2	2420	40	2001910	Children Pride Early Learning Center	ACS	Not Available	272.1	9.2	Not Available	184.9	6.6
2	2422	1	2001950	Melrose Branch Library	NYPL	Not Available	Not Available	Not Available	Not Available	120.2	4.3
2	2424	1	2097111	X145	DOE	47	101.9	4.9	79	83.8	4.5
2	2425	20	2102353	Classified Location	DHS	Not Available	89.9	3.1	Not Available	66.9	2.4
2	2435	75	2002299	X053, X851, X874 Campus: X053	DOE	58	122.9	5.8	82	92.2	4.5
2	2436	45	2002338	X053, X851, X874 Campus: X851	DOE	Not Available	Not Available	Not Available	82	92.2	4.5
2	2436	45	2109665	X053, X851, X874 Campus: X874	DOE	Not Available	Not Available	Not Available	82	92.2	4.5
2	2438	50	2002410	X022	DOE	53	106.2	5.3	77	89.9	4.7
2	2439	71	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2439	73	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2443	78	2103486	X790	DOE	Not Available	Not Available	2.9	4	251	7.7
2	2443	79	2002454	X151, X156 Campus: X156	DOE	38	158.6	4.1	67	130	3.4
2	2443	94	2099027	Bronx Concourse Plaza	DCAS	55	243.2	6.7	75	171.7	4.8
2	2443	190	2002458	X031	DOE	38	158.6	4.1	67	130	3.4
2	2443	190	2002458	X151, X156 Campus: X151	DOE	38	158.6	4.1	67	130	3.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2444	1	2097114	Bronx County Hall of Justice	DCAS	4	509.2	15.7	78	151.7	4.7
2	2445	6	2109459	X460	DOE	23	177.5	5.3	14	206.8	5.9
2	2446	43	2002497	X166	DOE	87	103.5	4.4	88	86.8	3.9
2	2446	43	2101573	X035	DOE	87	103.5	4.4	88	86.8	3.9
2	2450	40	2096490	Engine Co. 92 and Ladder Co. 44, Batt. 17	FDNY	Not Available	350.9	11.8	Not Available	279.6	9.6
2	2454	1	2002704	Bronx Family and Criminal Court	DCAS	32	323.3	10	81	151.4	4.7
2	2456	100	2002745	X090, X890 Campus: X090	DOE	82	77.8	4.3	76	95.7	4.8
2	2456	100	2002745	X090, X890 Campus: X890	DOE	82	77.8	4.3	76	95.7	4.8
2	2462	1	2002826	Bronx Museum of the Arts	CIG > BMA	Not Available	355.1	11.4	Not Available	184	6.2
2	2462	6	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2462	39	2101266	Bronx Housing Court	DCAS	38	268.6	7.7	75	149.5	4.4
2	2468	1	2002869	Bronx County Courthouse	DCAS	92	137.5	5.8	93	86.3	3.8
2	2480	8	2097130	X235	DOE	35	168.7	5.4	62	131.5	5.1
2	2485	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2489	60	2003015	Morrisania DTC Center	H+H	40	305.5	9	6	327.2	10.3
2	2489	77	2003017	44th Precinct	NYPD	Not Available	363.8	12.7	Not Available	290.5	10
2	2490	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2493	9	2101518	Mullaly Park Parks Building	DPR	Not Available	Not Available	Not Available	Not Available	137.8	4.3
2	2493	9	2101521	Mullaly Park Pool Bathhouse	DPR	Not Available	Not Available	Not Available	Not Available	137.8	4.3
2	2493	9	2117432	Arcilla Playground Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	137.8	4.3
2	2493	9	2116393	Yankee Stadium Parking Garage	DPR	Not Available	Not Available	Not Available	Not Available	137.8	4.3
2	2493	9	2999999	Mullaly Park North Pump House	DPR	Not Available	Not Available	Not Available	Not Available	137.8	4.3
2	2494	1	2003021	Mullaly Park Rink and Rec Center	DPR	Not Available	219.4	7.1	Not Available	65.2	2.3
2	2495	100	2003022	X114	DOE	29	125.8	6.5	32	163.4	9.9
2	2499	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2499	108	2832054	Macombs Dam Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	Not Available	0
2	2500	11	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2504	70	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2504	82	2003051	X073, X873 Campus: X073	DOE	19	204.5	11.5	39	107.9	5.3
2	2504	82	2003051	X073, X873 Campus: X873	DOE	19	204.5	11.5	39	107.9	5.3
2	2510	27	2003163	High Bridge Branch Library	NYPL	Not Available	242.7	8.6	Not Available	289.1	10.6
2	2514	56	2003268	Engine Co. 68 and Ladder 49	FDNY	Not Available	269.5	9	Not Available	381.9	16
2	2516	51	2003301	Highbridge Advisory SRCC	ACS	Not Available	178.9	4.7	Not Available	170.3	4.6
2	2526	83	2003495	X126	DOE	13	129.1	6.6	77	91.7	5.5
2	2527	14	2003496	Classified Location	DHS	Not Available	139.6	5.7	Not Available	116.6	5
2	2527	58	2117349	X285	DOE	Not Available	Not Available	Not Available	5	224.4	7.2
2	2529	81	2003519	X011	DOE	41	120.5	4.5	86	85	3.4
2	2530	21	2003522	Classified Location	NYPD	91	100.5	2.7	Not Available	228.9	10.2
2	2535	10	2116205	X172	DOE	21	178.6	5.3	70	104.1	3.1
2	2539	2	2097176	Mill Pond Park Power House	DPR	Not Available	Not Available	Not Available	76	100.3	3.5
2	2552	61	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2552	70	2003646	X855	DOE	9	204.2	5.3	41	155.9	4.1

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2557	1	2100446	St. Mary's Park - E 147th Street Comfort Station	DPR	Not Available	300.1	11.5	Not Available	263	12.2
2	2557	1	2003692	St. Mary's Recreation Center and Indoor Pool	DPR	Not Available	300.1	11.5	Not Available	263	12.2
2	2567	13	2003811	Classified Location	DHS	Not Available	82	2.1	Not Available	149.1	5.6
2	2571	1	2003834	X065	DOE	39	128.6	6.1	74	105.2	5
2	2572	6	2091301	Classified Location	DHS	32	276	8.7	71	137.1	5.2
2	2576	26	2003883	X655	DOE	48	145.5	6.4	96	64.8	2.2
2	2578	27	2003910	X155	DOE	75	105.6	5.2	68	104.1	5.8
2	2586	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2587	1	2003989	Classified Location	DHS	Not Available	68.5	1.8	Not Available	119.6	3.2
2	2589	31	2086438	Citywide Services and Storehouse	DPR	Not Available	Not Available	Not Available	Not Available	82.4	2.8
2	2605	20	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2605	40	Not Available	Rikers Island Chapel Command Center	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island DOI/IG	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island SOD Visits / NSD / Law library	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island ASRS Locker Room	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island Compost Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island DCJC / OT CTRL	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island DIV 1 & 2 / OPC	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2000000	Rikers Island Division 1 Storehouse	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116652	Rikers Island Powerhouse	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109478	Rikers Island Telecom / SOD / COD	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2096863	Rikers Island GRVC Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island Bridge Abutment Checkpoint	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island North Pumping Station	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2118476	Rikers Island Cogeneration Plant	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2999999	Rikers Island Welding Shop	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109475	Rikers Island West Facility: 200 Bed Modules	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Buildings 3&4	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Freezer Kitchen	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109474	Rikers Island Bakery	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2000000	Rikers Island Transportation Garage	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2097042	Rikers Island New Central Warehouse	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island Telecommunications Bldg	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109474	Rikers Island Laundry Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	Not Available	Rikers Island Firehouse	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2999999	Rikers Island Plumbing Shop	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Hart Island Module / S1	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Kitchen Switch A	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Kitchen Switch B	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Module 1	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Modules DD/	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Modules NN/	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2605	40	2109476	Rikers Island AMKC: Modules OO & PP/	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Modules VV/	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Modules WW & XX/	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Pantry Buildings 1&2	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Pantry Buildings 3&4	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Pantry Buildings 5	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: Visit House	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116651	Rikers Island EMTC: HIIP 3,4,5,6 & Admin	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116651	Rikers Island EMTC: Locker Room	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116651	Rikers Island EMTC: Sprung 1	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109475	Rikers Island West Facility: Kitchen	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2097042	Rikers Island GMDC: East Sprungs & WS	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2097042	Rikers Island GMDC: Servery & MOD 3	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109475	Rikers Island GMDC: West Sprungs	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109478	Rikers Island JATC: Equipment Room A	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109478	Rikers Island JATC: Equipment Room B	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109478	Rikers Island JATC: Equipment Room C	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116652	Rikers Island NIC: Aids Module	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116652	Rikers Island NIC: Kitchen / Elevator	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109474	Rikers Island OBCC: 300 Bed Annex	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109474	Rikers Island OBCC: CPSU 500 Bed Annex	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109474	Rikers Island OBCC: Kitchen / Locker Room	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	3109474	Rikers Island OBCC: Main Building	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109477	Rikers Island RMSC: Dorms 17-20	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2097042	Rikers Island GMDC: MODS 14,15,16,LL,N,QQ,RR	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2097042	Rikers Island GMDC: GMDC MODS 4,5,8,9,10,11,12,13	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109477	Rikers Island RMSC: Building 5	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109476	Rikers Island AMKC: AMKC Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116651	Rikers Island EMTC: EMTC Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2097042	Rikers Island GMDC: GMDC Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109477	Rikers Island RMSC: RMSC Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109479	Rikers Island RND: RND Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109475	Rikers Island West Facility: WF Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109479	Rikers Island RND: Sprungs, MOD 3	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109479	Rikers Island RND: Mods 2,4,10	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109477	Rikers Island RMSC: 800 Bed Addition	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109478	Rikers Island JATC: JATC Detention Facility	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2116652	Rikers Island NIC: North Infirmary Command	DOC	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2605	40	2109479	Q901 (Out of service)	DOE	Not Available	344.9	12.7	Not Available	332.3	15.5
2	2613	1	2004260	Classified Location	DHS	Not Available	216.1	8.5	Not Available	158	6.4
2	2615	14	2109706	EMS 26	FDNY	41	146.5	5.5	32	132.2	5.4
2	2615	14	2004302	X063, X862 Campus: X063	DOE	41	146.5	5.5	32	132.2	5.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2615	14	2004302	X063, X862 Campus: X862	DOE	41	146.5	5.5	32	132.2	5.4
2	2616	1	2004314	X162	DOE	73	78.6	3.8	96	62.8	3.3
2	2625	1	2004464	X157	DOE	77	106.2	5.3	86	60.1	2.4
2	2627	9	2004469	X140, X840 Campus: X140	DOE	56	110.9	5.7	80	77.5	3.1
2	2627	9	2004469	X140, X840 Campus: X840	DOE	56	110.9	5.7	80	77.5	3.1
2	2631	48	2004496	X120	DOE	79	92.4	5.2	76	108.5	6
2	2632	27	2004498	X146	DOE	76	102.4	4.6	50	117.3	5.6
2	2634	1	2004526	X400, X961 Campus: X400	DOE	56	158.4	5.7	70	103.6	4.1
2	2634	1	2101783	X400, X961 Campus: X961	DOE	56	158.4	5.7	70	103.6	4.1
2	2642	1	2004548	X005	DOE	82	128.2	6.2	74	89.8	4.5
2	2642	56	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2643	1	2004558	Hunts Point Multi Service Center	HRA	24	276.2	8.1	62	174	5.2
2	2655	30	2004690	X184	DOE	86	109.2	4.8	89	71.5	3.4
2	2657	30	2004700	Woodstock Branch Library	NYPL	Not Available	167.3	5	Not Available	108.9	3.5
2	2661	52	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2664	1	2004772	X025	DOE	85	88.2	3.4	77	77.8	2.9
2	2664	29	2004773	X161	DOE	70	95.6	4.3	84	83.5	4.3
2	2668	1	2004807	X650, X962 Campus: X650	DOE	80	123	4.4	48	112.3	4.3
2	2671	11	2004868	X158	DOE	78	123.8	5.5	80	93.1	4.3
2	2672	1	2004869	X198	DOE	72	129.1	5.9	70	104.5	4.8
2	2675	33	2117539	Engine Co. 73 and Ladder Co. 42	FDNY	Not Available	247.4	8.5	Not Available	210	7.3
2	2683	65	2005089	X062	DOE	47	140.2	8.1	42	115.9	6.7
2	2686	20	2005133	X052	DOE	34	169.9	9.1	74	91.4	4.8
2	2688	1	2005168	X130	DOE	43	107	5.6	59	105.7	5.7
2	2692	14	2005276	X099	DOE	59	125.4	5.2	83	86.8	4.3
2	2696	30	2005346	Lutheran Social Services of NY	ACS	Not Available	106.9	2.8	Not Available	121.2	3.2
2	2696	85	2005348	X060	DOE	79	65.2	3.3	91	71.5	3.5
2	2698	12	2005366	X401	DOE	88	95.5	5.1	95	66.3	2.7
2	2705	9	2005481	La Peninsula Head Start Program	ACS	Not Available	Not Available	Not Available	Not Available	131.3	3.5
2	2709	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2710	1	2005616	X039	DOE	44	99.9	4.1	91	65.7	2.9
2	2714	4	2005660	X116	DOE	21	148.8	5.1	65	103.1	3.4
2	2717	5	2109746	Tiffany Playground Comfort Station	DPR	77	90	4	84	69.9	3.5
2	2717	5	2005681	X150	DOE	77	90	4	84	69.9	3.5
2	2722	63	2005755	Hunt's Point Branch Library	NYPL	Not Available	212.3	7.3	Not Available	130.5	4.5
2	2727	17	2005802	Detective Borough Command	NYPD	Not Available	427	13.2	Not Available	418.1	14.3
2	2732	1	2090437	41st Precinct	NYPD	Not Available	228.1	6.9	Not Available	193.7	6.2
2	2747	1	2006079	X075	DOE	44	87.7	3.3	89	79.5	3.3
2	2758	6	2006302	Classified Location	HRA	Not Available	35.5	1.4	Not Available	76.1	3
2	2758	36	2006311	Classified Location	HRA	Not Available	85.8	3.3	Not Available	83.3	3.5
2	2761	43	2006338	Classified Location	DHS	Not Available	180.1	7.3	Not Available	197.7	7.9
2	2763	1	2109472	Hunt's Point Recreation Center	DPR	Not Available	289.6	9.9	Not Available	156.3	6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2763	279	2006566	X074	DOE	49	92	2.5	87	104.4	4.7
2	2765	177	2006621	Bronx 2 District Garage	DSNY	Not Available	225.4	9.2	Not Available	189.3	7.9
2	2766	1	2006680	X048	DOE	13	119	6.3	49	96.1	5.3
2	2770	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2777	292	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2780	73	2088215	800 Food Center Drive	EDC	Not available	Not Available	Not Available	Not Available	34.2	0.9
2	2780	73	2117759	The New Fulton Fish Market (800 FCD) (LL84)	EDC	Not available	Not Available	Not Available	Not Available	34.2	0.9
2	2780	74	2101256	Hunts Point WPCP: 1360 Ryawa Ave	DEP	Not Available	Not Available	Not Available	69	1356.8	37.1
2	2780	74	2118036	Hunts Point WPCP: 1360 Rear Ryawa Ave	DEP	Not Available	Not Available	Not Available	69	1356.8	37.1
2	2780	74	2118037	Hunts Point WPCP: Halleck St	DEP	Not Available	Not Available	Not Available	69	1356.8	37.1
2	2781	306	2999999	Salt Storage	DSNY	Not Available	Not Available	Not Available	57	47.1	1.2
2	2781	500	2109486	Hunts Point Cooperative Meat Market	EDC	Not available	Not Available	Not Available	Not Available	19.4	0.6
2	2781	500	2115237	Citarella/Sultana	EDC	Not available	Not Available	Not Available	Not Available	19.4	0.6
2	2781	500	2101319	Baldor Food	EDC	Not available	Not Available	Not Available	Not Available	19.4	0.6
2	2781	500	2109483	355 Food Center Drive	EDC	Not available	Not Available	Not Available	Not Available	19.4	0.6
2	2781	500	2115239	Krasdale Foods	EDC	Not available	Not Available	Not Available	Not Available	19.4	0.6
2	2781	500	Not Available	Hunts Point Cooperative Meat Market (355 FCD) (LL84)	EDC	Not available	Not Available	Not Available	Not Available	19.4	0.6
2	2781	520	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2788	1	2000000	Claremont Park Pool	DPR	Not Available	43.9	1.1	Not Available	150.3	4
2	2788	1	2096995	Claremont Park Comfort Station	DPR	Not Available	43.9	1.1	Not Available	150.3	4
2	2793	28	2007387	X070, X870 Campus: X070	DOE	8	120.6	6.3	75	83.1	3.8
2	2793	28	2007387	X070, X870 Campus: X870	DOE	8	120.6	6.3	75	83.1	3.8
2	2804	31	2007603	X028, X928 Campus: X028	DOE	33	115.8	5.5	70	90.8	4.5
2	2817	2	2007806	X410, X411 Campus: X410	DOE	85	104.5	5	89	85	3.4
2	2817	2	2007806	X410, X411 Campus: X411	DOE	85	104.5	5	89	85	3.4
2	2824	34	2007870	Grand Concourse Branch Library	NYPL	Not Available	191.3	6.2	Not Available	163.3	5.6
2	2827	1	2007902	X117, X957 Campus: X117	DOE	32	133.9	7	69	105.7	5.8
2	2830	17	2094533	X088	DOE	54	126.3	6.4	49	81.4	4.3
2	2843	40	2008098	X064, X924 Campus: X064	DOE	14	129.7	6.1	83	95.4	4.8
2	2843	40	2008098	X064, X924 Campus: X924	DOE	14	129.7	6.1	83	95.4	4.8
2	2847	41	2103870	X170	DOE	30	155.3	4.8	52	134.6	4.3
2	2851	21	2098479	X173	DOE	21	193.6	6	68	126.9	4.2
2	2859	77	2008336	X240	DOE	Not Available	Not Available	Not Available	8	254.9	7.9
2	2861	129	2109470	Babove Worldwide Institute Inc.	ACS	Not Available	160.7	5.1	Not Available	93.7	2.9
2	2862	14	2098721	X306	DOE	17	167.4	6.1	57	130.6	4.9
2	2865	49	2090448	Classified Location	DHS	Not Available	223.6	8.1	Not Available	182	6.6
2	2866	70	2008460	X082	DOE	32	159.7	7.8	62	132.9	6.8
2	2866	105	2008470	X338	DOE	Not Available	Not Available	2.1	28	164.3	4.4
2	2871	77	2008640	Bronx 5 District Garage	DSNY	Not Available	76.6	2.1	Not Available	283.6	12.7
2	2872	126	2008679	West Bronx Recreation Center	DPR	Not Available	168	5.8	Not Available	84.7	3.4
2	2873	27	2088263	X104	DOE	62	101.1	3.9	67	101.1	5.1
2	2876	8	2008794	X824	DOE	45	77.8	2.1	93	65.2	3.1

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2876	55	2008816	Nelson Ave Family Residence	DHS	Not available	Not Available	Not Available	Not Available	Not Available	0
2	2877	393	2094549	X109, X899 Campus: X109	DOE	15	128.5	6.9	49	117	6.3
2	2877	393	2094549	X109, X899 Campus: X899	DOE	15	128.5	6.9	49	117	6.3
2	2877	522	2008966	Lutheran Social Services of NY	ACS	Not Available	272.9	7.2	Not Available	95.1	2.5
2	2888	21	2009316	Labor Bathgate Day Care Center	ACS	Not Available	236.1	6.1	Not Available	174.9	4.6
2	2897	5	2009400	X147	DOE	87	102.3	4.4	91	73.3	3.3
2	2897	49	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2898	1	2094564	X876	DOE	47	189.6	5.5	78	112.9	3.8
2	2902	1	2009463	X055	DOE	26	138.8	5.9	48	129.2	5
2	2903	23	2009466	X042	DOE	72	80.7	2.8	87	85.6	3.5
2	2904	34	2009477	Bronx 03 Section Station 1	DSNY	Not Available	14	0.4	Not Available	36	1.6
2	2905	30	2117924	EMS 18	FDNY	Not Available	146.3	4.8	Not Available	152.7	5.2
2	2905	30	2117925	Rescue 3	FDNY	Not Available	146.3	4.8	Not Available	152.7	5.2
2	2907	10	2009509	48th Precinct	NYPD	Not Available	265.1	8.4	Not Available	255.4	8.7
2	2909	32	2009540	X058	DOE	72	107.8	5	49	112.4	5.6
2	2909	40	2009541	BX Boro Command, District Office and Communications	FDNY	Not Available	64.5	2.4	88	67.7	2.4
2	2913	1	2009555	X970	DOE	22	213.4	6	28	176.2	5
2	2914	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2915	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2916	2	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2917	40	2009572	X236	DOE	8	252.2	6.5	84	88.2	2.3
2	2918	1	2009573	Tremont Branch Library	NYPL	Not Available	284.2	10.1	Not Available	559.6	23.6
2	2919	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2920	2	2086675	Bronx CC: EOC - Bathgate Industrial Park	CUNY CC > BCC	Not available	Not Available	Not Available	Not Available	144.4	5.6
2	2921	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2923	18	2117666	X465	DOE	Not Available	Not Available	3.3	10	230.7	6.8
2	2925	1	2009611	X148	DOE	62	91.7	3.9	94	64.8	3
2	2925	56	2009617	X002	DOE	74	85.8	4.3	4	232.6	11.1
2	2925	80	2009620	Morrisania Health Center	DOHMH	Not Available	296.8	9.8	Not Available	207.3	7.1
2	2930	1	2009659	X004	DOE	77	114.6	4.5	49	89.8	3.6
2	2930	12	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	2930	75	2100071	X171	DOE	18	200.6	6.9	20	149.1	5.2
2	2932	1	2009718	X110	DOE	83	87.1	3.9	92	59.1	3.1
2	2939	45	2009865	X061	DOE	31	126.1	5.2	46	103.8	4.2
2	2939	90	2009866	East Tremont-Crotona Day Care Center	ACS	Not Available	150.2	5.1	Not Available	104.9	3.3
2	2939	93	2009867	X098	DOE	29	105.2	4.5	88	82.8	3.4
2	2941	1	2114529	Crotona Park Pool and Bathhouse	DPR	Not Available	195.2	6.9	Not Available	133.8	4.9
2	2942	1	2009887	Crotona Park South Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	1405.3	46.2
2	2942	1	2009887	Crotona Park Tennis House	DPR	Not Available	Not Available	Not Available	Not Available	1405.3	46.2
2	2942	1	2009887	Crotona Park - Martin Van Buren Playground	DPR	Not Available	Not Available	Not Available	Not Available	1405.3	46.2
2	2945	18	2009891	Tremont Health Center	DOHMH	Not Available	263.1	8.5	Not Available	138.1	4.6
2	2947	18	2009911	Bronx Bergen Building	DCAS	34	277.5	10	81	125.4	4.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	2949	64	2009957	X044	DOE	28	115.3	4.6	85	77.1	3
2	2951	32	2094582	X193	DOE	61	106	4.4	91	69.4	3.2
2	2953	21	2097277	Bronx 6, 6A District Garage	DSNY	Not Available	236.6	9.4	Not Available	353	16.1
2	2965	82	2010273	X134, X834 Campus: X134	DOE	46	120.2	5.3	73	77.9	4.2
2	2965	82	2010273	X134, X834 Campus: X834	DOE	46	120.2	5.3	73	77.9	4.2
2	2969	1	2010344	X136	DOE	83	88.4	4.1	87	76.2	3.5
2	2973	38	2010447	Engine Co. 82 and Ladder Co. 31	FDNY	Not Available	Not Available	Not Available	Not Available	272.2	9.6
2	2983	15	2010604	X973	DOE	1	275.3	7.8	55	136	3.9
2	2990	6	2010671	X817	DOE	68	129.9	3.4	62	143.7	3.8
2	2996	10	2010786	X050	DOE	57	119.3	5	60	104.1	5.5
2	3005	10	2010892	X006, X936 Campus: X006	DOE	52	113.8	4.2	87	79.4	3.8
2	3007	1	2010906	Classified Location	DHS	Not Available	205.9	8.8	Not Available	504.2	24.3
2	3007	8	2010910	X084	DOE	87	98.3	4.3	100	54.8	2.5
2	3008	1	2010916	X066	DOE	68	100.8	3.7	73	81.6	3.4
2	3013	1	2101786	X878	DOE	46	181.2	5.8	87	98.1	3.3
2	3014	16	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3015	49	2010954	Bronx 3A Broom Depot	DSNY	Not Available	136.1	3.5	Not Available	Not Available	0
2	3015	58	2010955	Section Station 92, Bronx Enforcement	DSNY	Not Available	64.1	1.7	Not Available	100.3	5.8
2	3021	38	2094603	X167	DOE	71	109.5	4.9	82	82.7	2.9
2	3024	21	2011054	X085, X885 Campus: X085	DOE	59	113.6	4.6	62	96.1	3.7
2	3024	21	2011054	X085, X885 Campus: X885	DOE	59	113.6	4.6	62	96.1	3.7
2	3024	21	2011054	X085, X885 Campus: X085 Annex	DOE	59	113.6	4.6	62	96.1	3.7
2	3025	25	2011061	Engine Co. 48 and Ladder Co. 56, Division 7	FDNY	Not Available	180.9	5.8	Not Available	124.8	3.9
2	3026	14	2118012	X444	DOE	Not Available	Not Available	Not Available	Not Available	161.2	7.2
2	3030	6	2100288	BX Borough Engineering, BX Sign Shop	DOT	Not Available	142.6	5.6	Not Available	28.4	1
2	3030	6	2999999	400 East 181 St	DOT	Not Available	142.6	5.6	Not Available	28.4	1
2	3030	28	2011136	Fleet Services Maintenance and Repair	DOT	Not Available	208.6	6.6	Not Available	204.1	6.6
2	3037	79	2090472	X023	DOE	42	154.3	5.6	25	167.8	6.4
2	3044	24	2011440	Trabajamos Community Head Start Inc.	ACS	Not Available	260.8	6.8	Not Available	179.2	4.7
2	3047	50	2011508	Bronx Lot Cleaning	DSNY	Not Available	60.2	2.6	Not Available	56.7	2.3
2	3049	37	2011538	X059	DOE	57	90.4	3.8	40	104	4.6
2	3058	3	2103863	X254	DOE	36	183.4	5.5	30	142.8	4.3
2	3059	1	2011810	X435	DOE	89	112.9	7.7	78	88.8	3.5
2	3060	32	2011826	Crotona Job and SNAP Centers	HRA	61	210.7	5.5	64	168.5	5.6
2	3061	55	2011844	X211	DOE	86	124.1	4.9	88	71.1	3.8
2	3062	43	2099356	X003	DOE	56	159.5	5.2	40	116.7	4
2	3067	1	2011937	X045	DOE	73	105.1	4	78	71.2	3
2	3069	1	2011995	X118, X932 Campus: X118	DOE	51	125.1	4.9	43	122	5.1
2	3069	1	2011995	X118, X932 Campus: X932	DOE	51	125.1	4.9	43	122	5.1
2	3073	13	2012125	Arthur Avenue Retail Market	EDC	Not Available	60.6	3.1	33	172.4	5.2
2	3073	13	Not Available	Arthur Ave Market (LL84)	EDC	Not Available	60.6	3.1	33	172.4	5.2
2	3073	20	2012129	Belmont Branch Library	NYPL	Not Available	204.5	6.7	Not Available	174	5.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3081	26	2012359	X057	DOE	28	149.3	6	7	198.6	8.3
2	3085	1	2012409	X032, X832 Campus: X032	DOE	26	159.2	7.9	60	101.1	3.8
2	3085	1	2012409	X032, X832 Campus: X832	DOE	26	159.2	7.9	60	101.1	3.8
2	3086	38	2086781	Engine Co. 88 and Ladder Co. 38	FDNY	Not Available	209.9	7.5	Not Available	187	7.2
2	3089	24	2012517	Belmont Community Day Care Center	ACS	Not Available	204	5.3	Not Available	157.6	4.2
2	3092	14	2012620	X092	DOE	60	105.5	4.1	80	87.9	3.6
2	3100	14	2098380	X034	DOE	75	112.5	3.6	96	62.9	1.8
2	3104	7	2012887	X660	DOE	82	96.1	5	75	106.1	5.5
2	3109	1	2118273	Mapes Pool	DPR	11	143.7	6.2	98	59.3	4.3
2	3109	1	2012957	X129, X234, X941 Campus: X129	DOE	11	143.7	6.2	98	59.3	4.3
2	3109	1	2012957	X129, X234, X941 Campus: X234	DOE	11	143.7	6.2	98	59.3	4.3
2	3109	1	2012957	X129, X234, X941 Campus: X941	DOE	11	143.7	6.2	98	59.3	4.3
2	3114	52	2013047	X864	DOE	35	181.5	4.7	2	289.2	7.6
2	3114	9052	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3115	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3115	21	2086808	X205	DOE	23	129.6	6.3	64	94	4.5
2	3115	9021	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3120	20	2128273	Bronx Park - 180th Street Comfort Station	DPR	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Shelter Bldg	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Shuttle Maintenance Garage	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116700	Bronx Zoo: Skyfari Maintenance Bldg	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Skyfari Tension Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Skyfari Ticket Booths West	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Snow Leopard Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Stand 3	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Storage Sheds & Truck Garage	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116691	Bronx Zoo: Terrace Cafe	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Tiger Mountain Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Tiger Mountain Holding Bunker	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: TOPS	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Wild Asia Gaur/Eld's Deer Shelters	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Wild Asia Kanha Meadow Shelters	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Wild Asia Restaurant	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Wild Asia Tahr Shelters	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Wild Asia Uplands Shelters	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Administration East	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Administration West	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: African Labs	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: African Market Food Stand	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: African Market Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: African Plains Lion House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: African Terrace Food Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3120	20	2116709	Bronx Zoo: Wildlife Health Center	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116693	Bronx Zoo: World of Birds	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: World of Birds - Prop Building	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116694	Bronx Zoo: World of Darkness	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Yak House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Zebra House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Zoo Center	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Service Gate Guard Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116674	Bronx Zoo: CGC Cogeneration Plant	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Southern Blvd Admission Ticket Booth 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Southern Blvd Admission Ticket Booth 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Southern Blvd Parking Ticket Booth 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Southern Blvd Parking Ticket Booth 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Souvenir Photo Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Zoo Shuttle Ticket Booth East 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Zoo Shuttle Ticket Booth East 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Zoo Shuttle Ticket Booth West 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Zoo Shuttle Ticket Booth West 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Aquatic Stork Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Asia Admission Ticket Booth 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Asia Admission Ticket Booth 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Asia Admissions Ticket Booth Storage Locker	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bronxdale Photo Booth and Stroller Rental	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bronxdale Admissions Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bronxdale Parking Ticket Booth 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bronxdale Parking Ticket Booth 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bronxdale Parking Ticket Booth 3	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bronxdale Parking Ticket Booth 4	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bug Carousel Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Business Service Trailer	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Camel Ride Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116678	Bronx Zoo: Education Trailer #1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Asia Theater & Holding Area	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Asian Horse Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Babirusa Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Bear Dens	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Beebe Lab	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Bird Department Offices	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123937	Bronx Zoo: Birds of Prey	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Bison Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116673	Bronx Zoo: Bronx Zoo Store	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: African Wild Dogs Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3120	20	2123911	Bronx Zoo: Animal Commissary Barn	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116672	Bronx Zoo: Aquatic Bird House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Asia Bazaar Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Asia Cart Depot	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Asia Marketplace Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Carter Giraffe Building	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Center for Global Conservation	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Children's Zoo / Petting Zoo Feed	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Force Main Pump Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Gains Trailer	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Grote Street Guard Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Irrigation Pump House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	3999999	Bronx Zoo: Italian Fountain Vault/Astor Court	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Jungleworld Rd Parking Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Asia Plaza Monorail Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Northern Pond Food Stand	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Rainey Gate Admissions Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Rainey Gate Old Admissions Ticket Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Rare Animal Range Sheds	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Recycling Center Booth	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Reptile Landing Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Service Yard Gas Pumps	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Skyfari Terminal East	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Skyfari Ticket Booth East	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Tractable Animal Building	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Isoquarantine	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: Bug Carousel	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116703	Bronx Zoo: Butterfly Garden & Exhibit	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Camel Barn	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Carpenter's/Foreman's Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Children's Zoo Animal Nursery	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Children's Zoo Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2999999	Bronx Zoo: CNG Fenced Area	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Cogeneration Plant	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Comfort Station - Wild Asia	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Comfort Station - World of Darkness	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Congo Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Congo Gorilla Forest	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Congo Restroom	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Construction Office	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Crandall Building	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Crossroads Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3120	20	2123911	Bronx Zoo: CS - Crossroads	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Dancing Crane	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Discover the Wild Gift Shop	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: East Elephant Walk Comfort Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Eco Restroom Comfort Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: EGAD/Sign Shop/Animal Commissary & Office	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Electric Vault Building	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Emu Shelter	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Exhibit Shop Complex	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Farm Apartments	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Flamingo Holding Facility	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Flamingo Pub	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Gelada Baboon Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Greenhouse 1	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Greenhouse 2	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Greenhouse 3	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Grizzly Goodies Food Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Group Sales	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Heads & Horns	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Horticulture/Greenhouse	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Incinerator Building	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116683	Bronx Zoo: Jungle World	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116841	Bronx Zoo: Madagascar	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Maintenance	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Mammals/Cage Facility	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Media Lab	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Merchandise Receiving/Souvenir Barn	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116689	Bronx Zoo: Monkey House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Monorail Loading Station	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116685	Bronx Zoo: Monorail Maintenance Bldg	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116689	Bronx Zoo: Mouse House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Multiple Bldgs behind Congo on Tram Route	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Nyala Barn	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Pere David Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Pheasant Aviary	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Red Panda Night Holding	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2116695	Bronx Zoo: Reptile House	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Sea Lion Exhibit	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Seabird Aviary	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Service Yard Cart Depot/Service Yard Emergency Generator	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8
2	3120	20	2123911	Bronx Zoo: Service Yard Garage	CIG > WCS BZ	Not Available	654.4	32.8	Not Available	551.2	27.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3123	3	2013142	X067, X967 Campus: X067	DOE	51	108.6	5.3	64	101.7	5
2	3123	61	2013151	West Farms Branch Library	NYPL	Not Available	229.8	7.3	Not Available	179.9	6
2	3126	11	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3141	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3142	48	2013297	X163, X933 Campus: X163	DOE	13	249.7	10.2	25	189	8
2	3142	48	2013297	X163, X933 Campus: X933	DOE	13	249.7	10.2	25	189	8
2	3143	43	2013307	X137	DOE	68	143.1	5.3	58	123.3	4.2
2	3143	203	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3146	72	2103868	X209	DOE	57	171	5.6	19	188.1	6.6
2	3149	90	2013535	46th Precinct	NYPD	Not Available	206.5	6.7	Not Available	179.3	6
2	3150	10	2013561	X009, X930 Campus: X009	DOE	47	91	4.7	67	98.7	4.1
2	3150	10	2013561	X009, X930 Campus: X930	DOE	47	91	4.7	67	98.7	4.1
2	3154	83	2116006	Bronx Library Center	NYPL	Not Available	668.2	17.9	Not Available	293.4	8.3
2	3168	27	2013830	X843	DOE	68	114.8	4.5	78	109.6	4.2
2	3170	1	2013849	X079	DOE	48	130.7	5.3	26	141.3	5.5
2	3172	46	2013899	X115	DOE	1	186.3	9.8	40	138	4.7
2	3178	14	2103867	X279	DOE	68	125.8	4.6	43	158.1	5.3
2	3178	32	2013953	Morris and Steven Soles Day Care Center	ACS	Not Available	195.2	5.2	Not Available	108.2	2.9
2	3186	49	2014062	X859	DOE	81	99	2.9	85	84.5	2.8
2	3188	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3188	20	2014099	X033	DOE	32	132.2	7.3	77	101.2	3.8
2	3189	9	2014125	Jerome 190th Street Parking Garage	DOT	Not Available	16.2	0.4	Not Available	9	0.2
2	3207	40	2094683	X091, X891 Campus: X091	DOE	Not Available	Not Available	Not Available	80	84.8	4.4
2	3207	40	2094682	X091, X891 Campus: X891	DOE	Not Available	Not Available	Not Available	80	84.8	4.4
2	3209	1	2086823	X206	DOE	77	129.3	5.5	55	124.6	5.5
2	3211	5	2014579	Francis Martin Branch Library	NYPL	Not Available	167.6	5.7	Not Available	162.4	5.7
2	3216	2	2014692	X026	DOE	76	124.5	6.4	74	107.3	4
2	3222	1	2014898	Bronx CC: Loew Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	40	2097306	Bronx CC: Alumni Gymnasium	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	40	2097307	Bronx CC: Loew Annex	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100250	Bronx CC: New Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100249	Bronx CC: Nichols Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100244	Bronx CC: Philosophy Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100241	Bronx CC: Carl Polowczyk Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100247	Bronx CC: Roscoe C. Brown Student Center	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100247	Bronx CC: Brown Annex	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100254	Bronx CC: Sage Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100255	Bronx CC: South Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100245	Bronx CC: Clock Tower	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100256	Bronx CC: Havemeyer Annex	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2119712	Bronx CC: North Hall and Library	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100241	Bronx CC: Begrisch Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3222	62	2100252	Bronx CC: Bliss Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100242	Bronx CC: Butler Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2116208	Bronx CC: The Children's Center	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100240	Bronx CC: Colston Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100240	Bronx CC: Community Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100251	Bronx CC: Energy Plant	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100243	Bronx CC: Gould Memorial Library	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100248	Bronx CC: Gould Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100256	Bronx CC: Greenhouse	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100253	Bronx CC: Guggenheim Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100243	Bronx CC: Hall of Fame, Auditorium and Colonnade	CUNY CC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100256	Bronx CC: Havemeyer Lab	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2096464	Bronx CC: Language Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	62	2100246	Bronx CC: Main Guard House	CUNY CC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	100	2096465	X826	DOE	93	58.7	2.2	69	95.8	3.4
2	3222	100	2096465	X827	DOE	93	58.7	2.2	69	95.8	3.4
2	3222	620	2118442	Bronx CC: Sage Annex	CUNY CC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3222	620	2014900	Bronx CC: Meister Hall	CUNY CC > BCC	Not Available	95.3	2.5	Not Available	144.4	5.6
2	3223	50	2090980	Patterson Reserve Center	CUNY CC > BCC	Not Available	Not Available	Not Available	Not Available	144.4	5.6
2	3223	50	2119433	Bronx CC: Patterson Garage	CUNY CC > BCC	Not Available	Not Available	Not Available	Not Available	144.4	5.6
2	3223	50	2090982	Bronx CC: MacCracken Hall	CUNY CC > BCC	Not Available	Not Available	Not Available	Not Available	144.4	5.6
2	3223	50	2119433	Bronx CC: Receiving Building	CUNY CC > BCC	Not Available	Not Available	Not Available	Not Available	144.4	5.6
2	3224	9	2096013	X015	DOE	6	242.7	7.9	10	217.8	7.5
2	3239	41	2124946	Riverbend Playground Comfort Station	DPR	69	53.9	2.5	56	92.2	3.8
2	3239	41	2096486	X122, X822 Campus: X122	DOE	69	53.9	2.5	56	92.2	3.8
2	3239	41	2096486	X122, X822 Campus: X822	DOE	69	53.9	2.5	56	92.2	3.8
2	3246	2	2015222	X905	DOE	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097311	Lehman College: Bookstore Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097318	Lehman College: Chiller Plant	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2103693	Lehman College: Communications Station - Gate 5	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097317	Lehman College: Concert Hall	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097312	Lehman College: Davis Hall	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097313	Lehman College: Fine Arts Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2098696	Lehman College: Gillet Hall	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097314	Lehman College: Old Gymnasium Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097315	Lehman College: Library	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097318	Lehman College: Music Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2117131	Lehman College: Nursing Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2098697	Lehman College: Speech and Theater Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2097316	Lehman College: Student Life Building	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2119733	Lehman College: Childcare Center	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	1	2116604	Lehman College: Science Hall	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3247	2	2098782	Kingsbridge Armory	EDC	Not Available	Not Available	Not Available	Not Available	2.9	0.1
2	3247	15	2101862	X340	DOE	27	210.9	6.3	32	174.4	5.6
2	3247	70	2100971	X086, X868 Campus: X086	DOE	27	155.3	5.9	66	122.1	4.9
2	3247	70	2100971	X086, X868 Campus: X868	DOE	27	155.3	5.9	66	122.1	4.9
2	3247	70	2015241	X430	DOE	27	155.3	5.9	66	122.1	4.9
2	3247	220	2015245	Lehman College: Shuster Hall	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3247	220	2000000	Lehman College: Tunnels	CUNY SC > LC	Not Available	106.5	4.5	Not Available	223.1	7.6
2	3248	62	2115783	X886	DOE	Not available	Not Available	Not Available	2	422.6	14.9
2	3250	73	2086833	X779	DOE	Not available	Not Available	Not Available	38	131.9	4.3
2	3251	201	2095215	X440	DOE	79	100.5	4.7	85	92.5	5.1
2	3251	201	2094706	X445	DOE	79	100.5	4.7	85	92.5	5.1
2	3251	401	2015443	Jerome Park Reservoir: 3201 Jerome Ave	DEP	Not Available	160.8	4.3	Not Available	118.4	3.1
2	3252	182	2015472	X095	DOE	76	128.5	6.3	40	145.6	6.4
2	3253	141	2015547	X143	DOE	73	96.4	4.9	89	75.8	3.4
2	3253	341	2103864	X360	DOE	51	179.3	5.9	42	140.4	4.5
2	3257	111	2015788	Kingsbridge Recreation Center	DPR	Not Available	143.8	3.8	Not Available	157.8	5.7
2	3266	68	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3272	1	2097529	French Charley Playground / Allerton Baseball Fields Comfort Station	DPR	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2823777	NYBG: ECAG Discovery Center	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2824109	NYBG: ECAG Multi-Purpose Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2824110	NYBG: ECAG Service Bldg	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113012	NYBG: Enid A. Haupt Conservatory	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113012	NYBG: Garden Cafe & Terrace Room	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2820080	NYBG: Charles B. Harding Laboratory Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2123955	NYBG: Hort Services Storage Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113265	NYBG: International Plant Science Center	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2118170	NYBG: LuEsther T. Mertz Library	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2823760	NYBG: Nolen Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113264	NYBG: Pfizer Plant Research Laboratory	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113265	NYBG: Harriet Barnes Pratt Library Wing	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2831176	NYBG: School Groups Restroom	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113267	NYBG: Transformer Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113266	NYBG: Leon Levy Visitor Center: Restroom	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113266	NYBG: Leon Levy Visitor Center: Restroom	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2999999	NYBG: Leon Levy Visitor Center: Shop in the Garden	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2118171	NYBG: Leon Levy Visitor Center: Ticketing and Cafe	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113267	NYBG: Jeannette Kittredge Watson Science and Education Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113264	NYBG: Picnic Pavilions	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3272	1	2113012	NYBG: Irrigation Pump House	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	3273	122	2094718	NYBG: NYBG - Upper and lower	CIG > NYBG	Not available	Not Available	Not Available	Not Available	258.1	9.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3274	1	2118801	NYBG Peter Jay Sharp Building Parking Garage	CIG > NYCC	Not Available	121.3	3.7	Not Available	19.7	0.6
2	3278	14	2113630	X054	DOE	35	160.5	5.3	29	136.4	4.3
2	3286	14	2016589	2556 Bainbridge Ave	DCAS > NA	Not Available	Not Available	Not Available	Not Available	0.5	0
2	3293	8	2016777	Fordham Model Office	HRA	40	236.5	7.6	57	169.8	6.1
2	3295	1	2094729	X046, X846 Campus: X046	DOE	63	140.5	5.9	61	111.1	4
2	3299	60	2118048	Van Cortlandt Park - Bainbridge Avenue Comfort Station	DPR	51	116.4	5.4	84	91	4.4
2	3299	60	2094734	X008, X808 Campus: X008	DOE	51	116.4	5.4	84	91	4.4
2	3299	60	2094734	X008, X808 Campus: X808	DOE	51	116.4	5.4	84	91	4.4
2	3325	5	2017718	52nd Precinct	NYPD	Not Available	312	8.3	Not Available	246.2	10.3
2	3325	5	2118049	Mosholu Parkway Comfort Station	DPR	Not Available	312	8.3	Not Available	246.2	10.3
2	3327	200	2017787	North Central Bronx Hospital	H+H	50	442	15.5	30	424.8	15.5
2	3328	10	2017791	Jerome Gun Hill Parking Garage	DOT	Not Available	8.8	0.2	Not Available	4.9	0.1
2	3329	124	2017858	X852	DOE	15	213.6	6.2	20	178	5.6
2	3330	1	2086851	X020, X931 Campus: X020	DOE	4	241.8	8.2	50	144.9	4.7
2	3330	1	2086851	X020, X931 Campus: X931	DOE	4	241.8	8.2	50	144.9	4.7
2	3330	60	2017876	North Bronx Yard and Reservoir HQ	DEP	100	41.7	1.2	99	31.2	0.9
2	3336	35	2018046	X080, X910 Campus: X080	DOE	52	148.8	7.2	61	120.5	5.1
2	3343	400	2018251	Williamsbridge Oval Field House	DPR	Not Available	Not Available	Not Available	Not Available	231.2	11.6
2	3351	1	2018457	X056, X865 Campus: X056	DOE	44	160.2	5.8	42	147.8	5
2	3353	40	2098420	X177	DOE	Not Available	Not Available	Not Available	14	202.2	6.4
2	3356	36	2115241	X361	DOE	Not Available	Not Available	Not Available	2	276.5	9.9
2	3356	42	2018628	X094	DOE	48	98	3.7	81	96	4.1
2	3386	1	2019463	X019	DOE	84	115.3	4.2	88	64.5	3
2	3478	18	2020580	X174	DOE	17	100.3	4.4	92	71.3	3.4
2	3524	20	2021482	X069, X869 Campus: X069	DOE	66	122.9	5.6	53	105.3	5.1
2	3524	20	2021482	X069, X869 Campus: X869	DOE	66	122.9	5.6	53	105.3	5.1
2	3540	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3558	14	2021838	Soundview Branch Library	NYPL	Not Available	292.9	9.6	Not Available	164.7	4.9
2	3564	1	2021923	X182	DOE	44	123.7	5.1	96	49	3.1
2	3591	50	2021972	X107	DOE	35	86.1	3.6	69	99.3	4
2	3604	39	2022205	X450, X451, X922 Campus: X450	DOE	86	94.8	4.3	76	96.7	5
2	3604	39	2022205	X450, X451, X922 Campus: X451	DOE	86	94.8	4.3	76	96.7	5
2	3609	16	2022289	X138, X938 Campus: X138	DOE	58	134.4	6.4	58	100.4	5.3
2	3622	16	2022544	X972	DOE	58	149.5	4.1	71	97.9	2.8
2	3641	1	2128993	Story Playground Comfort Station - PS 100	DPR	80	95.2	4.7	59	90.7	4.9
2	3641	1	2022550	X100	DOE	80	95.2	4.7	59	90.7	4.9
2	3644	1	2128986	Space Time Playground Comfort Station	DPR	32	107.7	5.3	94	65.7	2.6
2	3644	1	2103869	X131	DOE	32	107.7	5.3	94	65.7	2.6
2	3652	1	2097341	X093, X893 Campus: X093	DOE	74	93.1	3.6	63	113.9	4.5
2	3652	1	2097341	X093, X893 Campus: X893	DOE	74	93.1	3.6	63	113.9	4.5
2	3660	3	2022630	43rd Precinct	NYPD	Not Available	326.3	11	Not Available	256.6	8.4
2	3702	1	2094841	BX 9, 10, 11 District Garages: Bronx 9/10 Sanitation Garage	DSNY	Not Available	93.3	2.7	Not Available	151.3	7.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	3702	1	2094842	BX 9, 10, 11 District Garages: Bronx 11 Sanitation Garage	DSNY	Not Available	93.3	2.7	Not Available	151.3	7.7
2	3706	1	2023318	East Bronx Water Maintenance and Repair	DEP	Not Available	Not Available	Not Available	Not Available	212.9	6.6
2	3711	1	2023336	X152	DOE	66	119.4	5.5	78	83.8	4.4
2	3718	1	2087014	X123	DOE	69	85.6	4	87	84.1	4.6
2	3718	1	2087014	X823	DOE	69	85.6	4	87	84.1	4.6
2	3732	39	2023653	H.G. Birch Watson Day Care Center	ACS	Not Available	131.4	3.5	Not Available	104.5	2.8
2	3733	5	2129248	X317	DOE	Not Available	Not Available	Not Available	17	154.9	4.8
2	3736	1	2023714	Tremont Crotona Day Care Center	ACS	Not Available	126.4	3.3	Not Available	99.2	2.6
2	3748	15	2024083	Bronxdale Tenants League DDC Inc.	ACS	Not Available	103.3	2.8	Not Available	75.1	2.2
2	3752	13	2088552	Classified Location	DHS	Not Available	211.7	7.5	Not Available	199.8	7.9
2	3775	25	2088553	X077, X976, X982 Campus: X077	DOE	12	150.8	6.6	75	97.5	4.6
2	3775	25	2088553	X077, X976, X982 Campus: X976	DOE	12	150.8	6.6	75	97.5	4.6
2	3775	25	2088553	X077, X976, X982 Campus: X982	DOE	12	150.8	6.6	75	97.5	4.6
2	3786	16	2025622	X047	DOE	13	137	5.3	96	52.4	1.6
2	3789	21	2025696	X119, X915 Campus: X119	DOE	67	113.9	5.7	53	98.8	5.4
2	3790	40	2025717	X125	DOE	87	80.9	3.7	86	73.3	3.5
2	3817	1	2026706	X036	DOE	34	123.4	5.2	76	102.8	4.3
2	3831	40	2027115	Zerega Avenue Garage	DOHMH	Not available	Not Available	Not Available	Not Available	63.1	3
2	3834	70	2103494	X194	DOE	20	157	4.9	39	143.8	5.1
2	3841	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	3842	2	2027195	X833	DOE	1	167.8	5	82	143.1	4.5
2	3864	1	2027459	X420, X421, X423 James Monroe Campus: X420	DOE	59	187.5	7.9	52	131.9	5.3
2	3864	1	2027459	X420, X421, X423 James Monroe Campus: X421	DOE	59	187.5	7.9	52	131.9	5.3
2	3864	12	2117663	X420, X421, X423 James Monroe Campus: X423	DOE	59	187.5	7.9	4	290.3	9.1
2	3921	30	2028640	X102	DOE	35	152.3	5.5	73	103.3	3.7
2	3946	7	2041211	X106, X913 Campus: X106	DOE	61	126.6	5.8	47	130	5.6
2	3948	55	2110609	Castle Hill Park Comfort Station	DPR	60	95.8	5.2	49	130.3	7.7
2	3948	55	2041247	X127	DOE	60	95.8	5.2	49	130.3	7.7
2	3983	1	2041864	X012	DOE	22	164.9	7.5	76	119.9	4.5
2	3986	34	2041911	Westchester Square Branch Library	NYPL	Not Available	341.1	12.7	Not Available	234.5	8.6
2	3986	34	2041911	Westchester Health Center	DOHMH	Not Available	341.1	12.7	Not Available	234.5	8.6
2	4006	3	2042451	X879	DOE	31	181.4	5.6	55	134.8	4.5
2	4015	1	2119365	Transit District 12	NYPD	Not Available	458.4	12.7	Not Available	478.4	13.6
2	4037	1	2097571	X311	DOE	Not Available	Not Available	Not Available	59	108.1	4.7
2	4074	1	2044091	DOT Bronx Borough Commissioners Office	DOT	87	119.9	3.6	74	99	3.6
2	4091	1	2116414	X498	DOE	Not Available	Not Available	2.4	20	169.6	5.3
2	4101	1	2044743	ACS Bronx Field Office	ACS	7	316.2	8.9	82	133.3	3.8
2	4125	1	2045344	X083	DOE	86	110.9	5.2	78	90.5	5
2	4125	15	2117664	X981	DOE	13	185.1	5.7	50	124.5	4.1
2	4126	40	2045398	Morris Park Branch Library	NYPL	Not Available	79.5	2.3	Not Available	112.6	3.4
2	4133	200	2045725	X722	DOE	37	154.7	5.8	62	133.6	5
2	4171	1	2046140	X071, X948 Campus: X071	DOE	40	106.4	4.4	87	77.1	3.2

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	4171	1	2046140	X071, X948 Campus: X948	DOE	40	106.4	4.4	87	77.1	3.2
2	4205	1	2097543	49th Precinct	NYPD	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2097550	Jacobi Medical Center: Jacobi Building	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2097551	Jacobi Medical Center: Jacobi Medical Center Staff Residence	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2102972	Jacobi Medical Center: Conference Center	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2102971	Jacobi Medical Center: New Jacobi Building	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2097547	Jacobi Medical Center: Old Store House	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2829503	Jacobi Medical Center: Ambulatory Care	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2097546	Jacobi Medical Center: EMS 20	FDNY	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	1	2124702	Rotunda (LL84)	H+H	Not Available	Not Available	Not Available	94	379.8	12.8
2	4205	3	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	4205	30	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	4205	40	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	4205	55	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	4222	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	4226	75	2125035	Public Safety Answering Center II	DCAS	Not Available	Not Available	Not Available	Not Available	335	10.5
2	4275	1	2048608	X108, X946 Campus: X108	DOE	22	208.4	10	21	188	7.2
2	4275	1	2048608	X108, X946 Campus: X946	DOE	22	208.4	10	21	188	7.2
2	4288	1	2048794	X105, X935 Campus: X105	DOE	35	116.9	5	54	106	5.3
2	4288	1	2048794	X105, X935 Campus: X935	DOE	35	116.9	5	54	106	5.3
2	4290	48	2048811	X839	DOE	2	184.2	5.4	66	116.1	3.3
2	4293	31	2048831	X292	DOE	Not Available	Not Available	Not Available	12	174.2	5.7
2	4333	1	2124088	Bronx Park Field Office	DPR	33	278.3	11.3	Not Available	367.7	13.5
2	4333	1	2101004	Bronx Parks Headquarters and Shops - Ranaqua	DPR	33	278.3	11.3	Not Available	367.7	13.5
2	4333	1	2115599	Bronx River Parkway - Waring Avenue Comfort Station	DPR	33	278.3	11.3	Not Available	367.7	13.5
2	4333	1	2101003	Bronx Central Office	FDNY	33	278.3	11.3	Not Available	367.7	13.5
2	4333	1	2128300	Bronx Park - Brady Playground Comfort Station	DPR	33	278.3	11.3	Not Available	367.7	13.5
2	4333	1	2101003	Classified Location	NYPD	33	278.3	11.3	Not Available	367.7	13.5
2	4333	1	2128315	Brady Playground Comfort Station	DPR	33	278.3	11.3	Not Available	367.7	13.5
2	4336	1	2820085	NYBG: Hort Services Head-House	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2115623	NYBG: Hort Services Temporary Office	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2115623	NYBG: Nolen Glasshouses	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2115623	NYBG: Operations Garage/Storage Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2115623	NYBG: Operations Multi-Purpose Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2115623	NYBG: Operations Office/Shops Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2115623	NYBG: P-10	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	3412857	NYBG: Pit Houses	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2823840	NYBG: Stone Mill	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2832134	NYBG: Stone Cottage	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2127028	NYBG: Composting Restroom	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2120273	NYBG: Edible Academy	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	4336	1	2832134	NYBG: Hort Services Butler Building	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2999999	NYBG: Landscape Design/Arboretum Shed	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4336	1	2999999	NYBG: P-20	CIG > NYBG	Not Available	121.3	3.7	Not Available	258.1	9.7
2	4341	13	2049999	X096, X912 Campus: X096	DOE	18	133.8	5.1	35	123.9	4.5
2	4358	1	2050179	X415, X416 Campus: X415	DOE	72	121.9	4.8	47	132.8	5.6
2	4358	1	2999999	X415, X416 Campus: X416	DOE	72	121.9	4.8	47	132.8	5.6
2	4432	1	2051313	X135	DOE	51	91.9	4.7	83	80.9	4.4
2	4444	16	2051571	X089, X919 Campus: X089	DOE	77	97.9	3.9	80	101.3	3.9
2	4444	16	2051571	X089, X919 Campus: X919	DOE	77	97.9	3.9	80	101.3	3.9
2	4474	1	2052739	X097, X917, X997 Campus: X097	DOE	45	146	4.8	72	107.1	4.1
2	4474	1	2052739	X097, X917, X997 Campus: X917	DOE	45	146	4.8	72	107.1	4.1
2	4493	1	2053518	X144	DOE	54	100.7	4.5	90	66.7	3.2
2	4513	16	2053752	Allerton Branch Library	NYPL	Not Available	210	7.4	Not Available	156	4.2
2	4526	1	2125353	Allerton Playground Comfort Station	DPR	15	131.9	6.9	73	80.4	4
2	4526	1	2054253	X121, X921 Campus: X121	DOE	15	131.9	6.9	73	80.4	4
2	4526	1	2054253	X121, X921 Campus: X921	DOE	15	131.9	6.9	73	80.4	4
2	4552	10	2054933	X076, X926 Campus: X076	DOE	39	119	4.7	64	115.5	5.4
2	4552	10	2054933	X076, X926 Campus: X926	DOE	39	119	4.7	64	115.5	5.4
2	4624	15	2056898	X041	DOE	21	123.9	6.3	28	130.1	5.1
2	4633	40	2057045	X425	DOE	72	142.5	7.7	66	107.9	6.2
2	4651	44	2057523	Williamsbridge NAACP Early EEC	ACS	Not Available	146.1	4	Not Available	109.5	3
2	4675	20	2058396	X113	DOE	10	131.7	6.6	62	109.5	4.4
2	4719	1	2060191	X078	DOE	35	114.1	5.7	54	112.3	6.1
2	4823	1	2062883	X103, X923 Campus: X103	DOE	60	106.2	4.1	43	111.7	4.4
2	4823	1	2062883	X103, X923 Campus: X923	DOE	60	106.2	4.1	43	111.7	4.4
2	4829	6	2063070	North Bronx NCNW Community Dev.Center	ACS	Not Available	153.8	4	Not Available	133	3.5
2	4832	9	2063174	Bronx Neighborhood Building	DCAS	37	213.6	9.9	68	149.3	6
2	4839	39	2063435	X021	DOE	11	133.4	6.8	58	98	5.6
2	4864	35	2064589	X362	DOE	7	278.1	8.1	14	213.2	6.8
2	4876	1	2065163	47th Precinct	NYPD	Not Available	243.9	8	Not Available	214.6	7.2
2	4894	1	2116222	X169	DOE	3	313.3	9.4	4	267.1	7.5
2	4905	2	2097408	1250 East 229 Street	ACS	Not available	Not Available	Not Available	Not Available	278.2	9.7
2	4905	500	2065991	X112	DOE	64	99.9	5.7	94	56.5	2.1
2	4916	1	2065992	X111, X937 Campus: X111	DOE	31	152.2	6.6	19	179.2	9.9
2	4916	1	2065992	X111, X937 Campus: X937	DOE	31	152.2	6.6	19	179.2	9.9
2	4935	1	2066190	X142	DOE	62	104.5	5	87	71	3.7
2	4974	28	2090261	Bronx 12 District Garage	DSNY	Not Available	215.5	9.3	Not Available	191.5	8.5
2	4986	81	2067852	X068, X918 Campus: X068	DOE	59	131.2	6	20	174	8.7
2	4986	81	2067852	X068, X918 Campus: X918	DOE	59	131.2	6	20	174	8.7
2	5018	1	2069061	X087, X945 Campus: X087	DOE	39	128.5	5.1	69	100.1	3.8
2	5076	31	2070894	X016, X916, X942 Campus: X016	DOE	2	235	13.1	87	83.9	3.9
2	5080	1	2097456	X314	DOE	Not Available	Not Available	Not Available	64	93.5	4.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	5101	12	2071627	Classified Location	NYPD	62	218.3	6.6	26	140.4	4.3
2	5135	200	2072352	X160	DOE	58	71.5	1.9	51	127.3	5.7
2	5141	150	2097470	X153, X178, X180, X181, X455, X456 Campus: X456	DOE	99	121.5	3.2	57	117.3	3.8
2	5141	150	2116158	X153, X178, X180, X181, X455, X456 Campus: X180	DOE	99	121.5	3.2	57	117.3	3.8
2	5141	150	2116161	X153, X178, X180, X181, X455, X456 Campus: X178	DOE	99	121.5	3.2	57	117.3	3.8
2	5141	150	2116159	X153, X178, X180, X181, X455, X456 Campus: X455	DOE	99	121.5	3.2	57	117.3	3.8
2	5141	150	2097470	X153, X178, X180, X181, X455, X456 Campus: X153	DOE	99	121.5	3.2	57	117.3	3.8
2	5141	150	2116160	X153, X178, X180, X181, X455, X456 Campus: X181	DOE	99	121.5	3.2	57	117.3	3.8
2	5263	70	2093879	X701	DOE	Not Available	Not Available	Not Available	62	138.9	3.7
2	5263	192	2124548	X189	DOE	8	238.1	7	28	192.8	5.3
2	5313	92	2072754	X014, X947 Campus: X014	DOE	51	171.5	6.1	5	220.5	9.3
2	5313	92	2072754	X014, X947 Campus: X014 Addition	DOE	51	171.5	6.1	5	220.5	9.3
2	5368	1	2074045	X405, X406 Campus: X405	DOE	79	156.7	7.3	68	112.6	4.1
2	5368	1	2074045	X405, X406 Campus: X406	DOE	79	156.7	7.3	68	112.6	4.1
2	5368	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	5438	1	2077130	X192	DOE	66	107.6	4.9	41	136.3	7.4
2	5440	1	2077162	X072	DOE	56	139.9	5.1	57	116.1	4.7
2	5531	40	2097742	45th Precinct	NYPD	Not Available	137.6	3.7	Not Available	110.8	2.9
2	5547	1	2080231	X101	DOE	64	91.8	4.5	92	76	3.9
2	5622	1	2123826	Ferry Point Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	466.3	12.3
2	5641	280	2097870	Ambrosini Playground	DPR	53	170.3	6.9	35	127.1	5.2
2	5641	280	2082444	X175, X906 Campus: X175	DOE	53	170.3	6.9	35	127.1	5.2
2	5641	280	2082444	X175, X906 Campus: X906	DOE	53	170.3	6.9	35	127.1	5.2
2	5649	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	5650	1	2097423	Bartow Pell Mansion Museum	DPR	1	408.4	12.4	Not Available	117	4.3
2	5650	1	2118119	City Island Sewage Testing Plant (Large Bldg)	DPR	1	408.4	12.4	Not Available	117	4.3
2	5650	1	2124384	City Island Sewage Testing Plant (Small Bldg)	DPR	1	408.4	12.4	Not Available	117	4.3
2	5650	1	2124384	Orchard Beach (North End) Comfort Station	DPR	1	408.4	12.4	Not Available	117	4.3
2	5650	1	2109473	Orchard Beach Administration Building	DPR	1	408.4	12.4	Not Available	117	4.3
2	5650	1	2999999	Rodman's Neck: NYPD Firearms & Tactics Range	NYPD	1	408.4	12.4	Not Available	117	4.3
2	5650	1	2999999	Rodman's Neck Training Campus: Bomb Squad Building	NYPD	1	408.4	12.4	Not Available	117	4.3
2	5650	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
2	5701	105	2083138	X819	DOE	Not available	Not Available	Not Available	66	72.3	3.4
2	5713	87	2087522	Kingsbridge	ACS	100	0	0	83	107.4	3.4
2	5713	123	2119474	Kingsbridge Library	NYPL	Not Available	33.6	0.9	Not Available	265.2	8.3
2	5716	725	2112838	X368	DOE	12	271.9	8.3	56	138.5	4.6
2	5716	725	2097990	X037	DOE	12	271.9	8.3	56	138.5	4.6
2	5756	195	2083564	X007	DOE	55	116.2	4.5	74	92.3	3.7
2	5760	134	2087576	50th Precinct	NYPD	Not Available	278.7	9.4	Not Available	198.8	6.2
2	5850	1550	2084806	X081	DOE	24	130.4	4.9	58	106.6	4.2
2	5900	50	2112805	Arthur Ross Nursery	DPR	Not Available	91.2	2.4	Not Available	345.9	20.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
2	5900	50	2112805	Van Cortlandt Park - Woodlawn Playground Comfort Station	DPR	Not Available	91.2	2.4	Not Available	345.9	20.8
2	5900	150	2123972	Van Cortlandt Park Building (Nature Center)	DPR	Not Available	70.5	1.8	Not Available	115.9	5.1
2	5900	150	2123986	Van Cortlandt Park Garage	DPR	Not Available	70.5	1.8	Not Available	115.9	5.1
2	5900	150	2114843	Van Cortlandt House Museum	DPR	Not Available	70.5	1.8	Not Available	115.9	5.1
2	5900	150	2123971	Van Cortlandt Park - West 242nd Street Comfort Station	DPR	Not Available	70.5	1.8	Not Available	115.9	5.1
2	5900	150	2123972	Van Cortlandt Park Mansion Comfort Station	DPR	Not Available	70.5	1.8	Not Available	115.9	5.1
2	5900	150	2000000	Van Cortlandt Park Pool	DPR	Not Available	70.5	1.8	Not Available	115.9	5.1
2	5917	140	2085869	X024	DOE	55	104.1	5.8	80	85.3	3.4
2	5918	376	2085870	X141	DOE	75	128.3	6.3	80	96.6	3.8
2	5937	440	2117846	Wave Hill: Ecology Building	CIG > WH	Not Available	45.4	1.6	Not Available	43.4	1.4
2	5937	440	2117850	Wave Hill: Glyndor House	CIG > WH	Not Available	45.4	1.6	Not Available	43.4	1.4
2	5937	440	2117849	Wave Hill: Greenhouse	CIG > WH	Not Available	45.4	1.6	Not Available	43.4	1.4
2	5937	440	2117847	Wave Hill: Perkins Visitors Center	CIG > WH	Not Available	45.4	1.6	Not Available	43.4	1.4
2	5937	440	2101020	Wave Hill: Wave Hill House	CIG > WH	Not Available	45.4	1.6	Not Available	43.4	1.4
2	5937	440	2101020	Wave Hill: Wave Hill House	CIG > WH	Not Available	45.4	1.6	Not Available	43.4	1.4
3	25	12	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	35	21	3000880	Service Shop #1	NYPD	31	96.5	3.3	Not Available	57.4	1.8
3	39	1	3000089	Bridges ERB Iron Shop	DOT	35	88.4	2.9	Not Available	225.1	7.4
3	56	7	3000158	K307	DOE	77	112.7	5	86	76.9	4.4
3	58	50	3395568	Brooklyn War Memorial and Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	147.7	8.9
3	58	50	3999999	Cadman Plaza Comfort Stations	DPR	Not Available	Not Available	Not Available	Not Available	147.7	8.9
3	85	6	3000172	OEM Headquarters	DCAS	2	517.9	14.5	Not Available	371.3	10.8
3	86	18	3329429	NYCCT: Environmental Center	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	89	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	97	2	3000182	NYCCT: Voorhees Building	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	111	1	3000203	K287	DOE	93	80.9	3.8	74	82.9	4.6
3	120	20	3000216	K805	DOE	83	113.9	3.9	92	70.8	2.8
3	128	1	3335890	NYCCT: Pearl Building	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	128	1	3335892	NYCCT: Namm Hall	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	128	1	3335891	NYCCT: Library Building	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	128	26	3000243	NYCCT: General Building	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	131	1	3348041	K580	DOE	Not Available	183.5	4.9	Not Available	147.2	5.3
3	131	1	3414138	NYCCT: Academic Complex	CUNY SC > CT	Not Available	183.5	4.9	Not Available	147.2	5.3
3	132	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	132	23	3000246	Technology Center	DOITT	Not Available	Not Available	Not Available	1	1133	29.9
3	134	6	3000252	84th Precinct	NYPD	Not Available	318.9	10.7	Not Available	441.5	13.8
3	139	1	3000256	Brooklyn Borough Hall	DCAS	5	419.9	15.1	Not Available	151	5.6
3	139	20	3000257	Brooklyn Supreme Court	DCAS	33	310.4	12.3	Not Available	151	5.6
3	140	10	3331741	K313	DOE	2	255.3	7.9	73	112.6	3.5
3	140	111	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	147	4	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	148	7	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	154	1	3000420	K802	DOE	95	145.9	4.3	92	99.8	3.4
3	163	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	169	9	3000533	K520	DOE	98	101.1	4	93	77.2	3.1
3	169	17	3000534	Brooklyn Criminal Court	DCAS	37	298.3	11.8	Not Available	227.4	8.6
3	172	55	3000567	K369	DOE	91	97.2	4	96	77.5	3.6
3	173	1	3000573	IREA/IDNYC/FIA	HRA	1	522.6	16	8	303.8	10.1
3	174	1	3331754	K806	DOE	100	19.2	1.1	77	84.1	4.4
3	175	1	3000605	Brooklyn House of Detention #129	DOC	Not Available	412.3	15.4	Not Available	227.4	8.6
3	184	25	3000937	Strong Place for Hope DCC	ACS	Not Available	298.4	9	Not Available	194.6	5.8
3	188	14	3001070	K261, K982 Campus: K261	DOE	94	89.2	3.6	91	75.9	3.8
3	191	1	3001183	K038	DOE	68	88.6	4	62	94.6	5.3
3	192	1	3001189	K656	DOE	81	112.5	5.1	80	88	4.2
3	192	13	3001190	K655	DOE	90	104.6	4	89	97.5	4
3	197	28	3335918	FIA DeKalb Job Fort Greene SNAP Center	HRA	68	191.9	5	100	19	0.5
3	208	25	3395702	Pierrepont Playground Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	589.3	24.5
3	208	25	3395701	Squibb Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	589.3	24.5
3	211	1	3001540	K008	DOE	93	84.7	2.8	37	128.8	4.5
3	237	1	3001881	Brooklyn Appellate Court	DCAS	49	217.9	7.8	82	127	4.8
3	239	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	245	15	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	245	29	3999999	Pier 6	EDC	Not Available	Not Available	Not Available	Not Available	19	0.5
3	266	20	3002557	K801	DOE	40	301.2	10.1	70	208	7.6
3	269	14	3002643	K871	DOE	65	158	5	75	113.5	3.9
3	311	1	3255627	K029	DOE	88	91.4	3.6	41	139.8	6.5
3	312	24	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	335	1	3004232	Brooklyn 6A Broom Garage	DSNY	Not Available	236.2	10.3	Not Available	233.6	10
3	335	10	3004233	Communications Garage	FDNY	1	237.9	10.8	Not Available	196.7	9.2
3	337	27	3004301	76th Precinct	NYPD	Not Available	372.2	11.8	Not Available	334.1	11.8
3	338	33	3004336	Carroll Gardens Branch Library	BPL	Not Available	129.2	4.2	Not Available	137	4.9
3	369	1	3336036	K142	DOE	93	88.7	4.3	72	99.6	5.7
3	391	56	3006144	Sunset Bay Community Services Inc.	ACS	Not Available	118.5	3.2	Not Available	104	2.7
3	397	11	3006356	K804	DOE	99	72.1	2.4	93	70.7	2.9
3	402	1	3006401	K293	DOE	52	148.2	7.4	86	80.6	4.1
3	411	24	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	418	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	425	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	437	1	3007326	K032, K979 Campus: K032	DOE	70	128.8	5.9	56	115.7	5.1
3	449	15	3007547	K058	DOE	94	59.8	2.8	99	47.7	1.8
3	486	18	3008207	Engine Co. 279 and Ladder Co. 131	FDNY	Not Available	254.2	9.1	Not Available	243.6	8.2
3	504	50	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	515	61	3398756	Brooklyn Cruise Terminal Pier 11	EDC	Not Available	265.4	8.4	Not Available	11.2	0.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	515	61	Not Available	Brooklyn Cruise Terminal - Pier 12 (LL84) (Leased)	EDC	Not Available	265.4	8.4	Not Available	11.2	0.4
3	525	1	3008342	K027	DOE	69	116.8	4.6	54	125.5	5.5
3	539	24	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	552	5	3008517	P.A.L. Miccio Day Care Center	ACS	Not Available	194.9	5.1	Not Available	126.3	3.3
3	566	1	3008585	K015	DOE	73	125.1	6.2	88	83.3	3.1
3	582	1	3008670	Red Hook Recreation Center	DPR	Not Available	238.8	6.2	Not Available	263.9	10.4
3	583	1	3008671	Board of Elections	BOE	96	25.8	0.7	92	17.4	0.5
3	602	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	612	250	3008876	Erie Basin Auto Pound	NYPD	Not Available	Not Available	Not Available	100	4.2	0.2
3	625	2	3336714	Hamilton Avenue Marine Transfer Station	DSNY	Not Available	3777.6	187.2	Not Available	1050.3	47.3
3	625	2	3336712	Hamilton Ave Asphalt Plant	DOT	Not Available	3777.6	187.2	Not Available	1050.3	47.3
3	644	1	Not Available	Not Available	Not Available	100	0.2	0	Not Available	Not Available	Not Available
3	644	109	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	651	47	3009582	K749	DOE	Not Available	Not Available	Not Available	Not Available	23.8	1.2
3	652	70	3336859	K661	DOE	Not Available	Not Available	Not Available	Not Available	148.9	5.2
3	662	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	668	29	3009843	72nd Precinct	NYPD	Not Available	179.6	6	Not Available	196.6	7.3
3	669	1	3009847	K172	DOE	66	134	4.7	59	127.5	5.1
3	688	50	3394175	K564	DOE	Not Available	Not Available	Not Available	7	253.8	8.6
3	693	39	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	696	31	3337060	K371, K231 Campus: K231	DOE	92	93.3	4.6	90	79.2	4.3
3	696	31	3337059	K371, K231 Campus: K371	DOE	92	93.3	4.6	90	79.2	4.3
3	701	1	3346119	K024	DOE	68	137.6	4.4	59	102.1	3.4
3	713	20	3010580	K136, K939 Campus: K939	DOE	96	100.6	4.8	67	110.8	5.7
3	713	20	3010580	K136, K939 Campus: K136	DOE	96	100.6	4.8	67	110.8	5.7
3	715	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	717	61	3010669	Classified Location	NYPD	13	123	4.8	65	76.3	2.9
3	724	1	3010833	Classified Location	NYPD	24	285.8	9.8	42	219	8.1
3	725	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	728	36	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	732	1	3011002	K169	DOE	71	129.9	4.6	67	121.9	5
3	755	22	3011821	K001, K881 Campus: K881	DOE	46	114.6	5.3	80	87.9	3.2
3	755	22	3011821	K001, K881 Campus: K001	DOE	46	114.6	5.3	80	87.9	3.2
3	777	1	3332092	K682	DOE	Not Available	Not Available	Not Available	39	111.1	3.7
3	778	23	3012824	K220	DOE	72	124.4	4.8	73	106.9	4.6
3	792	26	3332126	K094	DOE	63	127.9	4.5	82	89.3	4
3	799	3	3414000	Engine Co. 201 and Ladder 114, Batt. 40	FDNY	Not Available	201.3	6.9	Not Available	157.4	5.6
3	803	5	3332515	Brooklyn South 7 and 10 District Garage	DSNY	Not Available	334.1	8.7	Not Available	311.5	14.9
3	819	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	861	37	3016235	K746	DOE	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	862	12	3016258	K314	DOE	70	131.2	4.2	65	126.5	4.4
3	869	1	3016509	K010	DOE	38	103	3.8	74	111.2	4.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	880	1	3250724	Slope Park Comfort Station	DPR	77	74.3	2.7	79	82.3	3.3
3	880	1	3331274	K845	DOE	77	74.3	2.7	79	82.3	3.3
3	880	1	3331276	K088	DOE	77	74.3	2.7	79	82.3	3.3
3	921	1	3337407	Sunset Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	434.4	11.4
3	921	1	3337407	Sunset Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	434.4	11.4
3	928	6	3018376	Pacific Branch Library	BPL	Not Available	185.8	5.7	Not Available	154.1	4.7
3	940	111	3413716	K317	DOE	Not Available	Not Available	Not Available	4	242.1	7.7
3	941	50	3259250	K902	DOE	76	141.1	4.7	65	129.4	5
3	947	54	3019440	Park Slope North Child Development Center	ACS	Not Available	209.8	7.2	Not Available	184.7	6.7
3	950	24	3019597	K282	DOE	74	97.1	4.3	67	95.2	4.8
3	971	28	3337516	K321, K896 Campus: K896	DOE	83	115.9	4.8	65	115.5	5.8
3	971	28	3337516	K321, K896 Campus: K321	DOE	83	115.9	4.8	65	115.5	5.8
3	981	111	3021057	K051	DOE	83	84.3	4.2	89	72.5	4
3	998	1	3021840	K763	DOE	81	91.1	5.1	72	78.1	3.9
3	1000	1	3021932	K039	DOE	94	117	4	62	117.4	4.4
3	1020	1	3022747	Brooklyn South 6 District Garage	DSNY	Not Available	236.3	8.9	Not Available	124	5.1
3	1034	1	3023391	K124	DOE	83	140	5.2	54	107.9	4.5
3	1038	1	3023562	Brooklyn North 2 District Garage	DSNY	Not Available	234.4	8.8	Not Available	276.2	11.5
3	1082	1	3025510	K460	DOE	24	219.1	14	79	101.5	4.2
3	1097	47	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1102	12	3026581	Classified Location	DHS	Not Available	184	9	Not Available	295.8	10.6
3	1136	1	3027810	78th Precinct	NYPD	Not Available	274	10.6	Not Available	305.4	13.4
3	1136	11	3027813	Engine Co. 219 and Ladder Co. 105	FDNY	Not Available	Not Available	Not Available	Not Available	239.7	8.6
3	1141	5	3027982	K909	DOE	84	122.4	4.1	90	78.4	2.7
3	1145	26	3028204	K009	DOE	83	93.4	4.4	79	82.4	4.6
3	1148	50	3028281	K022	DOE	48	144.8	4.6	55	107.9	3.6
3	1160	1	3028862	K813	DOE	75	148.5	7	72	116.8	6.3
3	1160	30	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1162	1	3028914	Classified Location	NYPD	5	329.8	10.7	Not Available	359.9	11.7
3	1164	57	3029060	K874	DOE	93	153.6	5.4	28	145.6	5.3
3	1167	18	3425815	Elijah Stroud Playground Comfort Station	DPR	82	113.2	5.1	56	101.7	5.2
3	1167	18	3029246	K316	DOE	82	113.2	5.1	56	101.7	5.2
3	1174	51	3029451	Engine Co. 280 and Ladder 132	FDNY	Not Available	Not Available	Not Available	Not Available	400.1	13.8
3	1183	1	3029666	Eastern Parkway Comfort Station	DPR	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3347228	Lefferts Historic House	DPR	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3337842	BBG: Administrative Building	CIG > BBG	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3337842	BBG: Conservatory	CIG > BBG	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3337842	BBG: Palm House	CIG > BBG	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3337842	BBG: Service Garage	CIG > BBG	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3337842	BBG: Comfort Station	CIG > BBG	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	1	3398161	Brooklyn Botanical Garden: Entry Building	CIG > BBG	Not Available	227.8	8.5	Not Available	288.6	10.7
3	1183	2	3029665	Central Library and Learning Center	BPL	Not Available	187.3	5.5	Not Available	114.1	3.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	1183	2	3347227	Grand Army Plaza Arch	DPR	Not Available	187.3	5.5	Not Available	114.1	3.6
3	1183	26	3029667	Brooklyn Museum	CIG > BKM	Not Available	290.7	9.8	Not Available	257.3	9.3
3	1183	30	3856674	Brooklyn Botanical Garden: Visitor Center	CIG > BBG	Not Available	Not Available	Not Available	Not Available	288.6	10.7
3	1187	1	3029686	K440	DOE	93	109.6	3.6	76	108.1	4.4
3	1188	1	3378160	K241, K840 Campus: K840	DOE	79	112	5.5	79	90.2	4.4
3	1188	1	3029702	K600	DOE	79	112	5.5	79	90.2	4.4
3	1188	1	3378160	K241, K840 Campus: K241	DOE	79	112	5.5	79	90.2	4.4
3	1199	15	3029748	Classified Location	DHS	Not Available	176.1	6.6	Not Available	139.3	5.7
3	1203	19	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1203	23	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1203	24	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1203	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1203	30	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1203	44	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1212	6	3030302	Fort Greene Grant Square Senior Center	DFTA	Not available	Not Available	Not Available	Not Available	217.8	5.8
3	1216	46	3030553	K625	DOE	73	135.9	4.8	76	94.1	3.3
3	1224	45	3030896	Friends of Crown Heights #2	ACS	Not Available	211.9	5.5	Not Available	138.3	3.6
3	1229	1	3031049	Brooklyn Children's Museum	CIG > BKM	Not Available	204.5	5.5	Not Available	139.3	4
3	1229	28	3031050	K289	DOE	34	120.6	6	79	85.3	5
3	1233	26	3330794	K138	DOE	39	106	4.4	76	87.1	3.6
3	1235	37	3031296	K867	DOE	73	183.1	4.7	39	157.1	4.1
3	1235	58	3031302	United Interfaith Action Council of Brooklyn	ACS	Not Available	107.6	4.2	Not Available	106.7	4.2
3	1240	56	3031515	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	144.7	4.3	Not Available	90.2	2.8
3	1259	36	3032563	Medgar Evers: 391 Eastern Pkwy	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1267	1	3032886	K824	DOE	4	313.9	8.5	2	294	9.1
3	1274	1	3033161	Brooklyn Armory	DCAS	Not available	Not Available	Not Available	Not Available	59.2	1.6
3	1274	1	3033161	Bedford Union Armory Building 1	EDC	Not available	Not Available	Not Available	Not Available	59.2	1.6
3	1274	101	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1280	54	3033470	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	141.5	3.7	Not Available	115.7	3.1
3	1287	48	3033791	Medgar Evers: School of Science, Health and Technology	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1288	1	3033796	Medgar Evers: School of Business and Student Services	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1289	25	3348092	K590	DOE	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1289	25	2000000	Medgar Evers: Electric Room for Portables	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1289	25	3337869	Medgar Evers: Carroll Street Building	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1289	25	2000000	Medgar Evers: Portables (P01-P22)	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1294	1	3034075	Medgar Evers: Bedford Building	CUNY CC > MEC	Not Available	150.1	6.6	Not Available	176.5	5.7
3	1297	26	3034181	K161	DOE	87	88.8	3.2	60	103.6	4.7
3	1301	1	3034356	K320	DOE	53	119.9	5.8	90	59.2	3.3
3	1310	1	3034563	71st Precinct	NYPD	Not Available	342.8	10.8	Not Available	268.5	8.7
3	1316	15	3379176	J.H.S. 61 Playground Comfort Station	DPR	43	108.4	5.2	76	80.6	3.1
3	1316	15	3337872	K061	DOE	43	108.4	5.2	76	80.6	3.1
3	1331	9	3035444	Mosdoth Day Care Center	ACS	Not Available	172.2	4.6	Not Available	141.7	3.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	1336	18	3330693	Brooklyn North 8 District Garage	DSNY	Not Available	448.2	15.5	Not Available	359.5	15.2
3	1347	1	3035761	K243	DOE	99	70	3.2	78	89.2	4.5
3	1353	1	3393257	St. Johns Recreation Center	DPR	Not Available	434.9	17	Not Available	951.5	48.2
3	1355	1	3035883	77th Precinct	NYPD	Not Available	260	8.8	Not Available	219.6	7.5
3	1355	23	3379207	Woods Playground Comfort Station	DPR	33	113.6	5.1	75	81.3	4.6
3	1355	23	3035887	K335	DOE	33	113.6	5.1	75	81.3	4.6
3	1356	50	3035918	Weeksville Heritage Center	CIG > WHC	Not Available	Not Available	Not Available	Not Available	150.6	4.1
3	1361	66	3036100	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	147.6	3.9	Not Available	140.7	3.8
3	1367	22	3036289	K210	DOE	83	101.3	5.2	66	103	5.1
3	1370	29	3036405	K390	DOE	72	111	5.6	72	95.5	3.7
3	1375	12	3036635	K191	DOE	85	101.6	5.8	51	113	6.7
3	1384	8	3037055	Engine Co. 234 and Ladder Co. 123, Batt. 38	FDNY	Not Available	282.6	9.4	Not Available	264.2	9.5
3	1389	35	3037303	K167	DOE	50	118.3	4.8	56	99.5	4.3
3	1396	6	3037543	Eastern Parkway Branch Library and Learning Center	BPL	Not Available	240.3	7.9	Not Available	189.5	6.8
3	1420	51	3038317	All My Children Daycare and Nursery School	ACS	Not Available	177.2	4.6	Not Available	157.2	4.1
3	1423	14	3038372	K221, K892 Campus: K892	DOE	23	151.2	8.4	49	106	5.9
3	1423	14	3038372	K221, K892 Campus: K221	DOE	23	151.2	8.4	49	106	5.9
3	1431	54	3038522	Shirley Chisholm Day Care Center Inc.	ACS	Not Available	114.6	3	Not Available	83.1	2.2
3	1440	56	3038718	K178	DOE	25	139.1	5	72	113.6	4.6
3	1440	73	3038719	Dean Street Family Residence	DHS	Not available	Not Available	Not Available	Not Available	82.5	6.1
3	1448	1	3038939	K055	DOE	91	98.3	3.3	97	60	2.3
3	1454	54	3039123	K808	DOE	98	90.2	3.4	99	101.2	3.8
3	1457	32	3039174	K012	DOE	52	146.3	4.6	23	147.9	4.6
3	1467	22	3421359	Rescue 2 (LL84)	FDNY	Not available	Not Available	Not Available	Not Available	112.9	4.3
3	1467	27	3039391	K854	DOE	41	179.7	4.7	46	121.9	3.2
3	1472	1	3319475	Classified Location	DHS	Not Available	222.3	8.1	Not Available	171.8	6.3
3	1482	1	3039676	K987	DOE	28	267.9	8.5	21	198.6	6.8
3	1490	1	3039906	K005	DOE	43	150	7.4	65	109.9	6
3	1498	6	3040195	SCO Family of Services	ACS	Not Available	104.8	3.3	Not Available	72.9	2.4
3	1510	1	3040878	K137	DOE	72	129.2	4.7	82	88.3	3.8
3	1512	1	3040990	Engine Co. 233 and Ladder Co. 176	FDNY	Not Available	244.3	7.7	Not Available	207	6.8
3	1518	1	3379497	Carver Playground Comfort Station	DPR	68	126.6	5.8	76	79.9	4.1
3	1518	1	3041214	K040	DOE	68	126.6	5.8	76	79.9	4.1
3	1520	51	3339185	Shirley Chisholm Day Care Center Inc.	ACS	Not Available	163.5	4.7	Not Available	104.4	3.4
3	1528	1	3041561	K073	DOE	61	117.3	4.6	60	102.5	4
3	1538	46	3041852	Shirley Chisholm Day Care Center Inc.	ACS	Not Available	161.9	4.3	Not Available	153.1	4.1
3	1548	19	3042090	Bedford Stuyvesant Multi Service Center	HRA	99	84	2.3	100	29	0.8
3	1548	19	3042090	K028	DOE	99	84	2.3	100	29	0.8
3	1550	1	3042157	K271	DOE	94	70.3	3.3	98	52.9	2
3	1552	43	3042263	K155	DOE	73	134.8	5.3	47	111.4	4.9
3	1602	13	3043244	Classified Location	HRA	Not available	Not Available	Not Available	Not Available	Not Available	0
3	1602	19	3043248	K081	DOE	47	132.9	6.5	81	81.6	3.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	1616	1	3399443	Jesse Owens Playground Comfort Station	DPR	5	115.6	4.3	78	84.5	3.8
3	1616	1	3393805	K026	DOE	5	115.6	4.3	78	84.5	3.8
3	1616	1	3043822	K057	DOE	5	115.6	4.3	78	84.5	3.8
3	1630	1	3044493	K308, K946 Campus: K308	DOE	71	92.4	3.9	87	78.4	3.6
3	1633	39	3044596	81st Precinct	NYPD	Not Available	187.2	5.9	Not Available	291	10.1
3	1636	1	3044657	K324	DOE	70	116.8	4.4	78	85.8	3.3
3	1643	36	3399478	Salgado Playground Comfort Station	DPR	63	169.2	9.6	70	86.6	4.9
3	1643	36	3045047	K309	DOE	63	169.2	9.6	70	86.6	4.9
3	1649	1	3045367	Classified Location	DHS	Not Available	35.2	1	Not Available	59.6	3.5
3	1671	19	3379561	El Hajj Malik El Shabazz Playground Comfort Station	DPR	83	89.1	4.4	74	81.4	4.7
3	1671	19	3046876	K262	DOE	83	89.1	4.4	74	81.4	4.7
3	1674	11	3047054	K035	DOE	68	103.4	4.2	82	97.5	4.1
3	1692	17	3047914	K021	DOE	39	134.6	6.9	24	140.1	8.1
3	1701	1	3047996	K455, K456 Campus: K455	DOE	87	127.7	5.5	73	88.3	3.3
3	1701	1	3047996	K455, K456 Campus: K456	DOE	87	127.7	5.5	73	88.3	3.3
3	1718	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1723	1	3048341	Woodhull Medical and Mental Health Center	H+H	38	467.8	15.9	51	416.3	14.9
3	1723	1	3048341	EMS 57	FDNY	38	467.8	15.9	51	416.3	14.9
3	1723	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1726	14	3048352	K148	DOE	85	97.4	3.3	85	102.8	4.1
3	1737	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1739	11	3048508	Stockton Playground Comfort Station	DPR	85	87.1	3.2	70	86.8	3.2
3	1739	11	3048508	K297	DOE	85	87.1	3.2	70	86.8	3.2
3	1739	11	3379581	Stockton Park Comfort Station	DPR	85	87.1	3.2	70	86.8	3.2
3	1743	18	3048517	K033	DOE	88	90	3.9	76	92.3	4.8
3	1749	1	3048546	K059	DOE	68	98.1	5	63	93.1	5.3
3	1751	25	3329636	Bedford Stuyvesant Alcohol Treatment Center	H+H	23	273.7	8.8	Not Available	Not Available	0
3	1759	13	3379585	Willoughby Playground Comfort Station	DPR	68	84.5	3.8	70	86.5	4.7
3	1759	13	3048818	K023	DOE	68	84.5	3.8	70	86.5	4.7
3	1765	15	3049020	K054	DOE	28	142.5	5.7	45	124.6	5.5
3	1769	72	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1773	14	3049420	K304	DOE	60	95.8	4.8	75	84.2	4.4
3	1779	27	3255870	Kosciusko Pool House	DPR	Not Available	194.3	6	Not Available	207.8	7.6
3	1784	20	3049769	K256	DOE	92	79.5	3.4	84	71.1	3.8
3	1787	14	3049858	K025	DOE	77	95.5	3.7	65	87.6	4
3	1790	1	3049973	Herbert Von King Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	95.5	3.5
3	1800	3	3050453	79th Precinct	NYPD	Not Available	262.6	9.3	Not Available	228.9	7.9
3	1812	1	3329679	K994	DOE	22	293.5	9.2	10	235.2	8.3
3	1819	14	3379611	Hattie Carthan Playground Comfort Station	DPR	90	98.7	3.5	86	68.6	3.1
3	1819	14	3051458	K305	DOE	90	98.7	3.5	86	68.6	3.1
3	1821	1	3051540	K044	DOE	23	109.2	6	79	97.7	3.8
3	1823	38	3051641	K458	DOE	89	104.2	3.6	83	92.3	3.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	1826	1	3051782	Bedford Health Center	DOHMH	Not Available	355.5	10.9	Not Available	171.9	5.9
3	1844	1	3053020	K743	DOE	89	117.2	5.4	73	99.9	4.5
3	1845	1	3053075	K258	DOE	91	85.5	3.8	89	79.8	4.1
3	1862	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1862	26	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1862	38	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1868	7	3053993	K093	DOE	62	122.2	6.8	66	86.5	5.3
3	1868	28	3323075	K853	DOE	92	186.1	4.8	38	158.3	4.2
3	1868	9028	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1882	1	3054189	Shaft Maintenance/Kent Avenue Machine Shop	DEP	Not Available	91	2.7	Not Available	136.4	4.3
3	1888	34	3054323	K914	DOE	9	226	7.3	50	136.8	4.7
3	1894	38	3054607	Hazmat Citywide Field Operations	DEP	Not Available	248.9	8.5	Not Available	163.1	5.3
3	1897	13	3054671	K157	DOE	74	79.5	3.4	55	90.2	3.7
3	1923	1	Not Available	Not Available	Not Available	73	107.6	5.5	Not Available	Not Available	Not Available
3	1926	10	3379640	JHS 117 Playground Comfort Station	DPR	89	91.8	4.6	83	71.9	4
3	1926	10	3055165	K117	DOE	89	91.8	4.6	83	71.9	4
3	1933	102	3055378	K270	DOE	Not Available	Not Available	Not Available	67	89.7	5.3
3	1933	121	3055379	88th Precinct	NYPD	Not Available	219.3	7.4	Not Available	165.5	5.5
3	1962	10	3056024	Greene Playground Comfort Station	DPR	86	82.5	3.5	42	116.4	6.1
3	1962	10	3332865	K011	DOE	86	82.5	3.5	42	116.4	6.1
3	1967	68	3056327	Classified Location	DHS	Not Available	374.3	10.3	Not Available	219.3	6.1
3	1983	10	3056874	K056	DOE	97	72.2	1.9	50	135.2	5.1
3	1992	18	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	1998	1	3057406	K003	DOE	52	101.2	5.3	57	98.7	4.1
3	2002	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2008	1	3057521	K085	DOE	39	137.1	5.7	77	104.1	3.8
3	2014	26	3057638	Young Minds Day Care Center	ACS	Not Available	202.7	5.4	Not Available	143.2	3.8
3	2023	1	3395473	Brooklyn Navy Yard: Service Building	DCAS	Not Available	Not Available	Not Available	Not Available	760	28.5
3	2023	1	3335122	Brooklyn Navy Yard: Brooklyn Navy Yard	EDC	Not Available	Not Available	Not Available	Not Available	760	28.5
3	2023	1	3335122	Brooklyn Navy Yard: Marine Co. 6	FDNY	Not Available	Not Available	Not Available	Not Available	760	28.5
3	2023	1	3335125	Kent Avenue Salt Storage	DSNY	Not Available	Not Available	Not Available	Not Available	760	28.5
3	2023	1	3396651	Brooklyn Navy Yard: Tow Pound Operations Building	NYPD	Not Available	Not Available	Not Available	Not Available	760	28.5
3	2023	1	3335129	New FDNY Marine Repair Facility (MC-6) (LL84)	FDNY	Not Available	Not Available	Not Available	Not Available	760	28.5
3	2023	50	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2023	150	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2028	1	3057942	K265	DOE	85	81.4	3.7	92	72	2.7
3	2039	2	3332507	K067	DOE	45	132.9	5.6	60	127.3	5.5
3	2039	71	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2039	81	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2039	101	3251647	Cumberland Diagnostic and Treatment Center	H+H	59	294.4	7.6	Not Available	168.3	5.7
3	2039	101	3251647	Classified Location	DHS	59	294.4	7.6	Not Available	168.3	5.7
3	2039	101	3251647	EMS 31 (Cumberland Hospital)	FDNY	59	294.4	7.6	Not Available	168.3	5.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	2039	101	3251647	Cumberland Mental Health and Chemical Dependency Center	H+H	59	294.4	7.6	Not Available	168.3	5.7
3	2045	11	3058088	K046	DOE	81	86.1	3.9	67	84.4	4.6
3	2047	11	3058187	Fire Headquarters	FDNY	30	323.6	8.4	58	217.3	5.8
3	2047	40	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2079	21	3058406	Fort Greene Health Center	DOHMH	Not Available	207.6	9.3	Not Available	264.9	9.1
3	2091	3	3379688	Parham Playground Comfort Station	DPR	94	99.4	5.3	44	114.1	6.8
3	2091	3	3058531	K020	DOE	94	99.4	5.3	44	114.1	6.8
3	2095	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2095	45	3345162	BAM Harvey Theater	CIG > BAM	Not Available	316.4	9.3	Not Available	158.9	5.2
3	2098	13	3058752	K430	DOE	92	142	8.2	47	120.3	6.7
3	2103	4	3379691	Samuel Goldberg Triangle Comfort Station	DPR	90	82.1	3.6	66	91.5	5.2
3	2103	4	3059051	K113	DOE	90	82.1	3.6	66	91.5	5.2
3	2107	30	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2111	15	3059185	BAM Peter Jay Sharp Theater	CIG > BAM	Not Available	322	10.6	Not Available	156.1	4.9
3	2151	18	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2177	1	3379699	Ps 16 Playground Comfort Station	DPR	84	89.1	3.4	69	87.6	3.6
3	2177	1	3059906	K016	DOE	84	89.1	3.4	69	87.6	3.6
3	2189	1	3060090	Williamsburg Branch Library	BPL	Not Available	151.7	5.1	Not Available	144.9	5.4
3	2203	16	3060298	Engine Co. 211 and Ladder Co. 119	FDNY	Not Available	273	10.8	Not Available	180.3	7.5
3	2207	2	3060407	K778	DOE	95	80.6	2.1	99	55.8	1.5
3	2227	1	3061064	K071	DOE	84	105.9	4.9	87	87.1	4.8
3	2236	9	3061235	K380	DOE	66	125.5	5.3	97	58.4	2.9
3	2246	1	3379720	Eugenio Maria De Hostos Playground Comfort Station	DPR	72	110	5.1	76	80.8	4.5
3	2246	1	3061328	K318	DOE	72	110	5.1	76	80.8	4.5
3	2276	12	3061504	Bushwick Job Center	HRA	60	203.1	6	Not Available	Not Available	0
3	2294	1	3061583	Bushwick Inlet Warehouse	DPR	Not available	Not Available	Not Available	93	16.8	0.4
3	2294	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2301	1	3061641	Bushwick Inlet Park Community Center	DPR	Not Available	Not Available	Not Available	Not Available	204.2	5.4
3	2330	11	3062135	K650	DOE	90	113.4	5	86	83.4	4.1
3	2345	1	3062337	K017	DOE	79	105.7	4.3	52	115	4.5
3	2366	4	3062457	Metropolitan Pool and Fitness Center	DPR	Not Available	302.7	9	Not Available	267.8	10.5
3	2368	12	3391565	Greenpoint EMT Station	FDNY	Not Available	Not Available	Not Available	Not Available	188.8	7.1
3	2391	1	3379756	William Sheridan Playground Comfort Station	DPR	68	97.8	4.1	94	54.2	3.2
3	2391	1	3062766	K084	DOE	68	97.8	4.1	94	54.2	3.2
3	2419	1	3063128	K050	DOE	79	99.9	5.1	75	92.3	4.9
3	2423	1	3063188	K019	DOE	85	86	4.1	72	78.9	4.4
3	2424	1	3063189	K319	DOE	51	223.4	5.8	14	195.1	5.1
3	2451	8	3063507	Nuestros Ninos Child Development	ACS	Not Available	149.2	4	Not Available	134.4	3.6
3	2453	1	3335960	Williamsburg Bridge Repair Shops	DOT	Not Available	229.4	10.4	Not Available	172.2	7
3	2453	1	3335963	Williamsburg Bridge Carpenter Shop	DOT	Not Available	229.4	10.4	Not Available	172.2	7
3	2454	1	3335965	Williamsburg Bridge Office	DOT	Not Available	68.3	2.3	Not Available	147.9	4.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	2454	1	3335964	Williamsburg Bridge Lighting and Shop	DOT	Not Available	68.3	2.3	Not Available	147.9	4.7
3	2465	100	3063633	90th Precinct and Engine Company 216	NYPD	Not Available	415.4	13.6	Not Available	345.3	11.4
3	2467	1	3063635	Construction Shops	DCAS	Not Available	32.6	1.4	Not Available	20.2	0.7
3	2489	7	3336609	Offices and Storage	DOT	50	173.7	4.5	93	86.7	2.3
3	2508	1	3064006	BCC Warehouse	DSNY	Not Available	Not Available	Not Available	1	282.8	9.7
3	2527	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2560	50	3064786	Engine Co. 238 and Ladder Co. 106	FDNY	Not Available	304.5	10.8	Not Available	235.4	8
3	2564	25	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2595	1	3065299	K031	DOE	78	89.8	3.5	62	89.2	3.9
3	2604	1	3065442	Testing Station	DCA	Not Available	68.3	2	Not Available	92.1	3.3
3	2619	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	2621	32	3065691	Greenpoint Branch Library	BPL	Not available	Not Available	Not Available	Not Available	187.1	5.1
3	2622	28	3065733	K034	DOE	84	125.4	6.1	65	97.8	3.7
3	2670	1	3066698	K610	DOE	71	132.3	5	80	88.1	3.7
3	2687	1	3338038	Monsignor McGolrick Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	233.3	8
3	2688	42	3067144	K110	DOE	92	74.3	2.8	78	65	2.6
3	2696	1	3067525	McCarren Park Recreation Center	DPR	Not Available	8	0.2	Not Available	420.7	14.4
3	2712	1	3067788	K126	DOE	6	101.2	4.6	96	64.8	2.5
3	2722	28	3067898	Engine Co. 229 and Ladder Co. 146	FDNY	Not Available	176.5	6	Not Available	152.9	5.4
3	2759	1	3068728	K132	DOE	94	80.7	3.9	36	127.4	4.5
3	2782	24	3069418	Williamsburg Community Health Center	H+H	Not Available	Not Available	Not Available	49	179.2	5.1
3	2787	1	3069559	K018	DOE	93	114.8	3.4	33	143.4	5.2
3	2788	33	3069604	Williamsburg Health Center	DOHMH	Not Available	81.4	3.5	Not Available	615.8	19.8
3	2929	53	3070506	Engine Co. 206	FDNY	Not Available	183.4	6.7	Not Available	157	5.4
3	2944	11	3070524	BWS Storehouse	DEP	4	156.7	6.7	9	116	5.2
3	2962	1	3400387	Brooklyn North 1 District & 4 District Garage	DSNY	Not Available	604.5	24.9	Not Available	390.5	16
3	2987	16	3070584	Brooklyn North 3 District Garage	DSNY	Not Available	264.1	10.3	Not Available	190	8.2
3	3016	1	3325733	K450	DOE	96	98.3	4.2	91	70.5	3.4
3	3025	1	3070825	K049	DOE	45	94.8	4	75	90.8	3.8
3	3046	1	3071024	K196	DOE	80	89.6	3.6	74	103.1	4.5
3	3060	1	3071199	K250	DOE	86	93.2	4.3	86	69	3.8
3	3091	1	3071418	K147	DOE	88	67.8	2.5	94	59.3	2.4
3	3098	19	3071470	Bushwick Branch Library	BPL	Not Available	190.3	5.7	Not Available	115.8	4.1
3	3106	20	3071521	Moore Street Market	EDC	Not available	Not Available	Not Available	Not Available	146.9	5.2
3	3106	20	Not Available	Moore Street Market Sitewide (LL84)	EDC	Not available	Not Available	Not Available	Not Available	146.9	5.2
3	3114	11	3071571	K257	DOE	87	86.1	3.9	94	62.7	2.8
3	3132	1	3071688	Gotham Health	H+H	Not Available	Not Available	Not Available	3	348	9.4
3	3137	26	3071806	K120	DOE	58	123.2	5.3	76	93.1	3.5
3	3153	11	3071915	K145	DOE	96	63.5	2.6	59	86.4	3.6
3	3156	1	3071940	Bushwick Job Center, Williamsburg SNAP Center, OCP, ICP (LL84) (Leased)	HRA	Not available	Not Available	Not Available	95	75	2
3	3157	37	3071962	K799	DOE	89	84.6	4.4	67	93.1	4.9

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	3185	1	3380055	IS 111 Playground Comfort Station	DPR	96	57.3	1.5	80	75.7	4.1
3	3185	1	3072497	K111	DOE	96	57.3	1.5	80	75.7	4.1
3	3210	1	3072966	K123	DOE	58	96.1	4.1	71	78	3.5
3	3212	1	3073018	K162	DOE	89	103.2	4.1	69	73.4	3.1
3	3227	10	3073394	Bushwick United Housing Development Fund Corp	ACS	Not Available	131	3.4	Not Available	94.4	2.5
3	3228	20	3073408	Bushwick United Housing Dev.Fund Corp.	ACS	Not Available	135.1	4.4	Not Available	155.1	4.7
3	3230	27	3073462	K913	DOE	82	116	3.6	59	128.1	4.3
3	3241	18	3073751	DeKalb Branch Library	BPL	Not Available	186	6	Not Available	138	4.7
3	3241	37	3073752	K274, K876 Campus: K876	DOE	84	87.8	3.9	83	66.4	3.2
3	3241	37	3073752	K274, K876 Campus: K274	DOE	84	87.8	3.9	83	66.4	3.2
3	3242	1	3073761	K865	DOE	87	95.5	3.7	94	62.4	2.5
3	3243	44	3073772	Classified Location	DHS	Not Available	342.2	14	Not Available	190.9	8.2
3	3243	46	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	3246	5	3073816	Classified Location	NYPD	Not Available	Not Available	Not Available	Not Available	412.3	13.1
3	3259	23	3074237	Grand Street Settlement Inc	ACS	Not Available	196.7	5.3	Not Available	140	3.8
3	3281	22	3074885	Engine Co. 271 and Ladder Co. 124, Batt. 28	FDNY	Not Available	211.2	7.4	Not Available	189.9	7.1
3	3287	1	3075072	K376	DOE	54	146.6	4.6	37	136.6	4.8
3	3289	27	3075109	K086	DOE	100	71.5	3	75	92.2	3.6
3	3298	1	3075413	K383	DOE	37	104.5	4.4	83	79	2.9
3	3306	15	3325706	K677	DOE	Not Available	Not Available	Not Available	86	62.8	2.6
3	3307	22	3326387	83rd Precinct	NYPD	Not Available	255.6	8.3	Not Available	279.8	9.5
3	3314	1	3075879	K075, K875 Campus: K875	DOE	76	111.5	4	33	123.2	4.7
3	3314	1	3075879	K075, K875 Campus: K075	DOE	76	111.5	4	33	123.2	4.7
3	3317	1	3075909	K116	DOE	82	90.3	4.3	82	86.8	4.4
3	3324	1	3076115	Bushwick Health Center	DOHMH	Not Available	221.1	7.6	Not Available	148.1	5.3
3	3331	25	3076253	Lutheran Social Services of NY	ACS	Not Available	217	5.7	Not Available	139	3.7
3	3343	1	3076460	K291	DOE	44	101.8	3	87	84.2	2.8
3	3343	29	3076461	Engine Co. 277 and Ladder Co. 112	FDNY	Not Available	268.5	8.7	Not Available	239	8.5
3	3344	16	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	3344	136	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	3358	1	3076734	K299	DOE	66	95.5	3.5	85	66.9	2.9
3	3360	1	3076784	K377	DOE	72	88.1	4	73	82.5	3
3	3362	55	3076869	New Life Child Care Center	ACS	Not Available	307.5	9.6	Not Available	255.5	8.8
3	3365	98	3380140	Bushwick Playground Comfort Station	DPR	56	155	5.8	60	123.5	4.8
3	3365	98	3076908	K480, K482 Campus: K480	DOE	56	155	5.8	60	123.5	4.8
3	3365	98	3076908	K480, K482 Campus: K482	DOE	56	155	5.8	60	123.5	4.8
3	3377	1	3077286	K106	DOE	65	95.3	3.4	91	67.1	2.8
3	3406	1	3078654	K151	DOE	63	102.4	4.1	46	94	3.8
3	3416	1	3380167	Tiger Playground Comfort Station	DPR	63	95.5	4.5	64	89.5	5.1
3	3416	1	3079027	K296	DOE	63	95.5	4.5	64	89.5	5.1
3	3427	11	3079428	K045	DOE	89	76.3	3.8	76	75.3	4.2
3	3433	5	3079655	Labor and Industry for Education Inc.	ACS	Not Available	122.3	3.3	Not Available	104.4	2.9

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	3442	1	3080043	K384	DOE	75	99.4	3.4	77	92.2	3.7
3	3444	22	3080067	Bushwick Multi Service Center	HRA	26	218.2	8.6	80	134.8	5.7
3	3448	15	3080179	Labor and Industry for Education Inc.	ACS	Not Available	82	2.7	Not Available	75.5	2.4
3	3496	4	3080726	Brownsville Multi Service Center	HRA	69	168.7	6	83	123.4	4.8
3	3497	2	3080735	73rd Precinct	NYPD	Not Available	282.5	9.7	Not Available	237.2	8.7
3	3498	8	3378202	Crossroads Juvenile Center	ACS	Not Available	152.8	4.6	Not Available	347	11.2
3	3507	5	3080767	Engine Co. 231 and Ladder Co. 120, Batt. 44	FDNY	Not Available	Not Available	Not Available	Not Available	228.2	7.9
3	3507	7	3080768	K298	DOE	54	110.4	5.4	37	102	5.4
3	3508	12	3080779	K907	DOE	60	132.7	3.9	57	101.8	3.2
3	3520	8	3341114	Chester Playground Comfort Station	DPR	61	119	5.3	87	83	4.2
3	3520	8	3081032	K327, K396 Campus: K327	DOE	61	119	5.3	87	83	4.2
3	3520	8	3081032	K327, K396 Campus: K396	DOE	61	119	5.3	87	83	4.2
3	3535	16	3081276	K356	DOE	33	163.5	5.5	41	127.9	4.5
3	3541	1	3081419	K175	DOE	70	142.4	5.3	54	124.1	5.3
3	3542	1	3081442	K263	DOE	46	106.7	5.5	76	89.6	4.8
3	3544	135	3081460	K284	DOE	75	100	3.7	78	99.9	3.8
3	3559	11	3081765	Brownsville Health Center	DOHMH	Not Available	275.3	10.1	Not Available	217.3	8.2
3	3568	1	3326658	SCO Family of Services	ACS	Not Available	233.5	6.1	Not Available	148.1	3.9
3	3570	1	3392494	Betsy Head Park Comfort Station	DPR	Not Available	175.3	4.5	Not Available	295.3	17.1
3	3570	1	3081931	Betsy Head Pool House	DPR	Not Available	175.3	4.5	Not Available	295.3	17.1
3	3580	20	3081953	Engine Co. 283 and Division 15	FDNY	Not Available	235.6	9.1	Not Available	209.4	7.5
3	3583	6	3082035	Classified Location	DHS	Not Available	93.5	4.2	Not Available	83.8	3.9
3	3597	11	3082253	K183	DOE	16	156.7	6.3	26	161.8	7
3	3604	1	3380281	Newport Playground Comfort Station	DPR	44	119.1	5.7	67	86.2	4.6
3	3604	1	3082389	K041	DOE	44	119.1	5.7	67	86.2	4.6
3	3606	1	3082391	K184	DOE	56	118.4	4.9	46	120.6	5.5
3	3622	23	3082726	K165	DOE	78	113.7	4.1	73	90.1	3.9
3	3636	7	3082940	K275	DOE	81	102.6	4.5	94	65.3	3.6
3	3687	1	3083515	Facilities Management Division	NYPD	Not Available	Not Available	Not Available	45	205.6	7.8
3	3691	1	3083579	Engine Co. 332 and Ladder Co. 175	FDNY	Not Available	Not Available	Not Available	Not Available	246.1	8.6
3	3693	1	3083608	K332	DOE	57	105.8	5	79	96.1	5.8
3	3698	32	3083636	Classified Location	NYPD	34	261.8	8.5	Not Available	215.3	6.8
3	3699	1	3083637	Classified Location	DHS	Not Available	364.3	15.6	Not Available	189.2	7.9
3	3704	1	3083660	K660	DOE	18	210.7	8.5	65	109.6	4.2
3	3704	33	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	3704	35	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	3704	36	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	3738	15	3083929	East New York Diagnostic & Treatment Center	H+H	24	323.6	11.8	20	264.3	9.5
3	3740	1	3083931	K292	DOE	35	116.7	5.6	73	106.5	5.6
3	3744	9	3084012	K150	DOE	28	113.9	4.4	72	89.3	3.6
3	3755	22	3084088	Classified Location	HRA	Not available	Not Available	Not Available	Not Available	Not Available	0
3	3768	1	3084283	K328	DOE	68	111.5	5.6	80	86.5	4.5

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	3772	6	3084298	K848	DOE	5	250.7	6.5	11	170.2	4.5
3	3774	16	3084348	K149	DOE	78	114.2	4.5	40	109.4	4.8
3	3788	1	3084440	K435	DOE	91	107.5	4.2	73	95.8	3.9
3	3794	18	3084596	Stone Avenue Branch Library	BPL	Not Available	153.8	4.6	Not Available	138.8	4.7
3	3802	15	3084617	K174	DOE	68	98.6	4	79	74.7	3.3
3	3803	46	3084621	University Settlement Society of New York	ACS	Not Available	173.2	4.5	Not Available	124.3	3.3
3	3804	43	3084622	Engine Co. 290 and Ladder Co. 103	FDNY	Not Available	Not Available	Not Available	Not Available	269.8	9.8
3	3805	26	3084628	Police Athletic League Inc.	ACS	Not Available	162.3	4.3	Not Available	Not Available	0
3	3823	1	3085070	K013	DOE	84	109	4.2	85	87.6	4.3
3	3838	18	3085491	K190	DOE	28	174.8	5.9	13	148.7	5.6
3	3844	1	3085646	Classified Location	DHS	Not Available	415.2	16.1	Not Available	399.3	16.8
3	3868	2	3085992	Brownsville Recreation Center	DPR	Not Available	154.6	5.3	Not Available	132.7	4.7
3	3871	1	3252759	Cioffe Borough Repair Shop	DSNY	Not Available	716.9	29.4	Not Available	562.6	23.8
3	3871	101	3332519	Classified Location	DHS	Not Available	470.3	16.7	Not Available	238.8	9.2
3	3926	45	3087131	K108	DOE	86	96.8	3.6	61	107.1	4.2
3	3949	18	3087821	K290, K948 Campus: K290	DOE	8	215.3	7.8	66	93.9	4.3
3	3952	47	3397079	K814	DOE	Not Available	Not Available	Not Available	23	179.8	6.1
3	3969	1	3380474	Sperandeo Brothers Playground Comfort Station	DPR	63	125.4	5.3	67	96	5.5
3	3969	1	3088357	K302, K974 Campus: K302	DOE	63	125.4	5.3	67	96	5.5
3	3976	70	3088473	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	149.1	3.9	Not Available	90.8	2.5
3	3990	1	3088734	K345	DOE	50	119.3	6.6	58	79.7	3.8
3	4006	37	3089020	Friends of Crown Heights Educational Center Inc	ACS	Not Available	158.2	4.1	Not Available	135.5	3.6
3	4013	23	3089149	K932	DOE	59	142.2	6.5	99	51.7	3.8
3	4015	1	3089176	K158	DOE	64	104.2	4	41	96.2	4
3	4039	1	3089620	Urban Strategies Day Care Center	ACS	Not Available	179.4	4.6	Not Available	99.7	2.6
3	4051	16	3089813	75th Precinct	NYPD	Not Available	330.7	10.5	Not Available	348.6	11.9
3	4069	1	3090219	K072	DOE	89	80	4	73	80	4.2
3	4077	24	3090429	Classified Location	DHS	Not Available	69.2	2.6	Not Available	142.2	5.8
3	4077	28	3090430	Classified Location	DHS	Not Available	69.2	2.6	Not Available	142.2	5.8
3	4090	1	3090726	New Lots Branch Library	BPL	Not Available	155.1	4.9	Not Available	140.8	4.7
3	4094	1	3090738	K420, K421 Campus: K420	DOE	79	120.9	6.6	68	119.4	7.1
3	4094	1	3090738	K420, K421 Campus: K421	DOE	79	120.9	6.6	68	119.4	7.1
3	4102	19	3397004	K798	DOE	11	232.8	6.2	17	175.7	5.4
3	4106	39	3090998	K007, K991 Campus: K007	DOE	36	144	4.6	81	85.2	3.3
3	4134	20	3092456	K171	DOE	34	105.7	4.5	60	100.5	3.9
3	4140	13	3092631	Cypress Hills Senior Center	DFTA	Not Available	337.6	8.8	Not Available	198.1	5.2
3	4142	32	3424693	K667 (Main Building) (LL84)	DOE	Not Available	Not Available	Not Available	86	64.5	3.2
3	4155	75	3327249	K615	DOE	41	172.7	6.8	67	106.3	5.6
3	4216	1	3094735	K159, K998 Campus: K159	DOE	97	80.8	3	65	86.8	3.6
3	4217	1	3094749	K851	DOE	49	129.5	4.6	83	86.4	3.2
3	4243	1	3095254	K214, K949 Campus: K214	DOE	60	113.1	4.2	83	78.3	3.3
3	4258	36	3095610	Classified Location	DHS	Not Available	516.3	13.4	Not Available	372.8	9.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	4278	1	3095977	K218	DOE	73	117.9	4.1	62	109.8	4.6
3	4298	7	3096389	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	128.3	4.3	Not Available	91.6	3.3
3	4315	40	3097095	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	210.1	5.5	Not Available	165.2	4.4
3	4324	1	3380772	K213, K893 Campus: K893	DOE	75	142.2	6.6	63	111.2	5.7
3	4324	1	3097334	K213, K893 Campus: K213	DOE	75	142.2	6.6	63	111.2	5.7
3	4327	24	3097429	K857	DOE	85	130.9	3.9	80	109.8	3.7
3	4328	15	3097444	K599	DOE	Not available	Not Available	Not Available	Not Available	Not Available	0
3	4349	50	3097675	K166	DOE	65	94.4	4.3	92	80.5	4
3	4363	1	3097756	Animal Shelter - Brooklyn	DOHMH	Not Available	507.6	18.1	Not Available	511.5	19
3	4363	11	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	4388	1	3097871	Brooklyn South 16 District Garage	DSNY	Not Available	150.4	4.4	Not Available	411.3	19
3	4392	1	3380792	Ethan Allen Playground Comfort Station	DPR	55	120.2	5.9	88	62	3
3	4392	1	3097873	K306	DOE	55	120.2	5.9	88	62	3
3	4401	1	3097973	Jerome Playground Comfort Station	DPR	64	109.9	5.8	78	74.3	4.3
3	4401	1	3097973	K273	DOE	64	109.9	5.8	78	74.3	4.3
3	4449	1	3398623	K422	DOE	Not Available	Not Available	Not Available	11	225.8	7.1
3	4452	25	3098294	K346	DOE	32	158.2	8	87	71	3.4
3	4457	1	3098472	Friends of Crown Heights Educational Center Inc.	ACS	Not Available	184.3	6.3	Not Available	156.9	5.7
3	4461	1	3098536	701 Euclid Ave Office	HPD	58	177.3	5.2	70	164.4	5.7
3	4477	1	3098664	K202, K958 Campus: K202	DOE	35	121.3	4.8	49	110.6	4.9
3	4530	1	3098980	K224	DOE	52	148	4.8	76	92.3	3.4
3	4555	1	3099064	Brooklyn Lot Cleaning and Salt Shed	DSNY	99	22.6	0.6	88	26.9	1.1
3	4562	1	3099068	Brooklyn North 5 District Garage	DSNY	Not Available	310.9	13.2	Not Available	298.6	12.8
3	4566	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	4595	15	3323072	K398	DOE	68	95.1	4.4	55	85.2	4.1
3	4599	1	3099537	K189, K889 Campus: K889	DOE	58	143.1	5.9	87	80.4	3.3
3	4599	1	3099537	K189, K889 Campus: K189	DOE	58	143.1	5.9	87	80.4	3.3
3	4606	25	3099733	K232	DOE	51	120.3	4.8	63	111.1	4.5
3	4623	28	3100292	K268, K981 Campus: K268	DOE	45	132.9	5.8	23	115.3	5
3	4648	1	3381007	Kennedy-King Playground Comfort Station	DPR	74	119.7	4.4	30	127	5.3
3	4648	1	3101168	K219	DOE	74	119.7	4.4	30	127	5.3
3	4650	15	3101218	K860	DOE	22	203.1	6.8	21	167.3	6.8
3	4669	37	3101840	K252	DOE	63	127.3	7	60	117.3	4.9
3	4673	1	3102005	K135, K953 Campus: K135	DOE	64	159.1	6.4	8	175.2	7.6
3	4739	1	3104513	K244	DOE	36	144.6	5.4	51	98.5	3.9
3	4742	1	3104598	K415	DOE	90	93.2	3.7	84	78.4	3.3
3	4744	1	3104599	K285	DOE	55	120.3	5.9	69	86.2	3.7
3	4753	1	3104990	K233	DOE	65	90.6	3.3	30	136.3	5.4
3	4769	25	3105680	K208, K972 Campus: K208	DOE	65	120.5	4.4	60	86.8	3.8
3	4794	26	3106599	K091, K891 Campus: K891	DOE	66	107.4	4.3	42	97.8	4.2
3	4794	26	3106599	K091, K891 Campus: K091	DOE	66	107.4	4.3	42	97.8	4.2
3	4806	1	3107129	K391	DOE	86	90.8	3.8	91	73.8	3.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	4811	1	3381428	Wingate Park Comfort Station	DPR	55	135.1	5.1	42	111.5	4.8
3	4811	1	3381428	George Wingate High School Playground Comfort Station	DPR	55	135.1	5.1	42	111.5	4.8
3	4811	1	3107227	K470	DOE	55	135.1	5.1	42	111.5	4.8
3	4812	1	3397939	Brooklyn Chief Medical Examiner	OCME	Not Available	271.7	7	91	410.7	17.5
3	4812	1	3327674	Dr. Susan Smith McKinney Nursing Center	H+H	Not Available	271.7	7	91	410.7	17.5
3	4812	1	3329549	Kings County Hospital: Food Service	H+H	Not Available	271.7	7	91	410.7	17.5
3	4812	1	3327678	Kings County Hospital: Hospital Support Office	H+H	Not Available	271.7	7	91	410.7	17.5
3	4812	1	3327679	Kings County Hospital: Building K	H+H	Not Available	271.7	7	91	410.7	17.5
3	4812	1	3327681	Kings County Hospital: Central Laundry	H+H	Not Available	271.7	7	91	410.7	17.5
3	4815	20	3107315	K397	DOE	51	179.1	7.2	75	101.8	3.6
3	4827	39	3327687	Brooklyn South 9 District Garage	DSNY	Not Available	341.8	12.6	Not Available	401.7	16.6
3	4829	1	3327722	EMS 38	FDNY	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327712	Kings County Hospital: Building D	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327713	Kings County Hospital: Building S	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327714	Kings County Hospital: Ambulatory Care Building E	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327720	Kings County Hospital: Building Z (Powerhouse)	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327711	Kings County Hospital: Buildings A, B, C	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327725	Kings County Hospital: Building T	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	1	3327710	Kings County Hospital: Building R	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	2	3396539	Kings County Hospital: Parking Garage	H+H	32	470.4	17.7	91	410.7	17.5
3	4829	3	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	4829	4	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	4829	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	4833	1	3337083	Classified Location	DHS	Not Available	19.2	0.5	Not Available	107.7	3.4
3	4844	1	3107846	K235, K835, K980 Campus: K835	DOE	18	146	5.4	32	114	4.6
3	4844	1	3107846	K235, K835, K980 Campus: K235	DOE	18	146	5.4	32	114	4.6
3	4904	10	3327776	K181	DOE	49	148	5.4	39	128.8	5
3	4965	1	3112334	K864, K869 Campus: K864	DOE	86	85	2.6	81	69.9	3.1
3	4965	1	3112334	K864, K869 Campus: K869	DOE	86	85	2.6	81	69.9	3.1
3	4988	66	3113388	K198, K983 Campus: K198	DOE	48	126.9	4.8	48	95.4	3.8
3	4994	23	3113780	K269	DOE	59	127.2	5.3	59	109.2	4.5
3	5022	2	3114526	K395	DOE	2	243.2	7.5	23	142.8	4.8
3	5049	28	3328159	K092 Addition	DOE	Not Available	Not Available	Not Available	64	106.4	4.2
3	5049	55	3115866	K092	DOE	90	89.8	3.4	64	106.4	4.2
3	5050	51	3378201	K002	DOE	47	157.4	4.8	36	161.3	5.8
3	5051	1	3347260	Parade Grounds - Bowling Green	DPR	5	344.9	12.1	Not Available	320.4	10.9
3	5051	1	3256655	Classified Location	NYPD	5	344.9	12.1	Not Available	320.4	10.9
3	5075	1	3116438	K249	DOE	66	143.3	7.2	42	119.6	4.6
3	5086	15	3116706	Flatbush Branch Library and Learning Center	BPL	Not Available	245.3	8	Not Available	141.5	4.9
3	5103	10	3336215	K465	DOE	86	135.1	5.4	58	120	4.9
3	5103	79	3117230	K006	DOE	52	159.6	4.8	47	122.2	4.1
3	5103	93	3338996	K877	DOE	92	98.1	3.7	79	78.7	3.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	5103	101	3117232	K884	DOE	52	132.8	3.9	87	67.4	2
3	5110	25	3117381	K246	DOE	13	175.5	6.3	29	140.5	5.4
3	5111	1	3117396	K399	DOE	46	218.6	7.4	15	208.5	7.3
3	5111	24	3117400	67th Precinct and Engine Company 248	NYPD	Not Available	253.3	7.9	Not Available	290.9	9.6
3	5121	32	3117584	K735	DOE	Not Available	Not Available	Not Available	81	71.2	2.9
3	5132	18	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	5144	64	3328235	K139	DOE	74	124.1	5.6	88	77.9	4.3
3	5232	1	3121072	K217	DOE	19	159.2	6	27	137.3	5.1
3	5257	1	3121871	K154	DOE	87	111.7	4.1	54	101.3	4.1
3	5293	29	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	5319	1	3124019	K130	DOE	67	107.6	3.8	82	100.3	4.2
3	5321	64	3398290	K437	DOE	Not Available	Not Available	Not Available	11	239.3	7.9
3	5323	32	3415739	Albemarle Playground Comfort Station	DPR	69	122.2	4.5	74	84.7	3.6
3	5323	32	3124109	K230	DOE	69	122.2	4.5	74	84.7	3.6
3	5334	64	3343470	K908	DOE	70	140.3	4.4	36	165.4	5.9
3	5342	6	3425170	K338	DOE	Not Available	Not Available	Not Available	5	206.3	7.1
3	5362	21	3125676	K223	DOE	83	104.2	4.2	87	88.8	3.5
3	5371	1	3126001	K179, K921 Campus: K921	DOE	86	106.7	4.2	79	91.5	3.8
3	5371	1	3126001	K179, K921 Campus: K179	DOE	86	106.7	4.2	79	91.5	3.8
3	5391	1	3126842	K062	DOE	86	111.2	5	92	70.2	3.4
3	5416	14	3801250	Kensington Branch Library	BPL	Not Available	102	3.2	Not Available	150.5	4.6
3	5416	48	3127692	K849, K839 Campus: K839	DOE	68	120.3	4.3	75	98	4
3	5416	48	3127692	K849, K839 Campus: K849	DOE	68	120.3	4.3	75	98	4
3	5423	21	3127902	70th Precinct	NYPD	Not Available	313.6	10	Not Available	255	8.8
3	5437	38	3324164	K767	DOE	Not Available	Not Available	Not Available	Not Available	94.7	5.1
3	5445	1	3128909	K192	DOE	63	122.1	4.4	59	124.7	5.4
3	5492	1	3130809	K180	DOE	76	95.6	3.7	85	83.3	3.6
3	5494	89	3328495	Brooklyn South 12 District Garage	DSNY	Not Available	140.8	3.6	Not Available	202.1	9.3
3	5495	1	3130960	Brooklyn 12 District Garage Parking Lot	DSNY	Not Available	96.4	3.2	Not Available	520.8	24.8
3	5495	1101	3253281	K121	DOE	80	139.2	5.2	75	104.7	4.2
3	5506	6	3131537	K505	DOE	93	102.5	5.1	94	63.5	3.2
3	5518	4	3132091	Mapleton Branch Library	BPL	Not Available	211.9	6.2	Not Available	198.5	5.9
3	5519	1	3132140	K048	DOE	58	141.7	5.1	73	92.7	3.8
3	5551	18	3133741	K227	DOE	72	101.9	3.8	60	98.7	4
3	5571	1	3134749	K205	DOE	88	78.3	2.8	68	107.8	4.3
3	5598	48	3135907	Borough Park Branch Library	BPL	Not Available	123.8	3.2	Not Available	125.9	3.9
3	5600	1	3135976	K164	DOE	75	113.5	4.5	91	93.3	3.9
3	5603	1	3136085	K131	DOE	69	94	4.7	76	99.8	5.4
3	5653	21	3138276	K160, K521 Campus: K160	DOE	88	115.8	4.4	16	199.8	6.9
3	5653	55	3398120	K160, K521 Campus: K521	DOE	88	115.8	4.4	16	199.8	6.9
3	5702	1	3140612	K105	DOE	72	113.2	4.3	61	123.3	5.2
3	5727	10	3141384	K678	DOE	Not available	Not Available	Not Available	Not Available	54.9	2.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	5729	24	3141434	K310	DOE	Not Available	Not Available	Not Available	14	206.1	6.4
3	5735	32	3387646	K069	DOE	28	212	7.1	11	180.2	6.4
3	5745	29	3142008	K486	DOE	25	148.8	5.9	60	121.9	5
3	5753	26	3328857	K695	DOE	Not Available	Not Available	Not Available	Not Available	89.7	4.6
3	5774	1	3143190	K176	DOE	88	87.9	3.6	80	89	3.7
3	5778	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	5799	38	3143927	K971	DOE	Not Available	Not Available	Not Available	63	129.5	4
3	5817	55	3144156	68th Precinct	NYPD	Not Available	267.8	9.9	Not Available	171.6	5.6
3	5850	30	3144482	K485, K977 Campus: K485	DOE	26	210.1	7.3	47	162.3	5.9
3	5853	45	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	5873	84	3145771	K940	DOE	Not Available	Not Available	Not Available	99	47.4	1.2
3	5890	1	3146491	K102	DOE	81	119.8	4.4	72	107.7	4.5
3	5891	48	3146550	K331	DOE	Not Available	Not Available	Not Available	5	230.1	7
3	5899	1	3146921	K170, K954 Campus: K170	DOE	71	131.4	4.8	57	128.8	4.7
3	5907	1	3147279	Bay Ridge Branch Library	BPL	Not Available	228.9	6.7	Not Available	161.2	5.1
3	5923	1	3148031	K259	DOE	37	168.8	6.9	34	162.6	6.2
3	5973	1	3150481	K127	DOE	79	113.5	4.8	80	98	4.8
3	6013	1	3397296	Russell Pederson Playground Comfort Station	DPR	76	150.3	6.4	58	137.4	5.1
3	6013	1	3152318	K490, K934 Campus: K490	DOE	76	150.3	6.4	58	137.4	5.1
3	6013	1	3152318	K490, K934 Campus: K934	DOE	76	150.3	6.4	58	137.4	5.1
3	6036	1	3153196	Bay Ridge Municipal Garage	DOT	Not Available	76	2	Not Available	37.3	1
3	6043	1	3153416	K185	DOE	71	107.4	4.4	86	74.2	3
3	6062	141	3413664	K264	DOE	Not Available	Not Available	Not Available	18	203.9	6.4
3	6065	28	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	6065	43	3154215	K989	DOE	55	237	8.2	7	257.7	10
3	6088	1	3154775	K104	DOE	90	97.2	4.3	59	111.4	5.8
3	6103	42	3424828	K613	DOE	Not Available	Not Available	Not Available	Not Available	82.1	2.7
3	6140	1	3340027	Lehman Ballfield Fieldhouse Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	3.2	0.1
3	6174	36	3157466	K247	DOE	94	112.6	4	61	135.8	5.5
3	6175	48	3157508	K491	DOE	Not Available	Not Available	Not Available	Not Available	80.7	2.6
3	6180	1	3157760	K112, K961 Campus: K112	DOE	96	95.9	3.4	47	116.3	4.4
3	6202	6	3253521	K768	DOE	Not Available	Not Available	Not Available	18	152.9	5.7
3	6239	1	3160923	K186	DOE	81	119.6	4.7	53	123.7	5.1
3	6254	53	3161800	Engine Co. 284 and Ladder Co. 149	FDNY	Not Available	244.2	9	Not Available	216.5	8.4
3	6271	1	3162711	K445, K446 Campus: K445	DOE	80	129.5	4.6	73	120	4.5
3	6271	1	3162711	K445, K446 Campus: K446	DOE	80	129.5	4.6	73	120	4.5
3	6278	22	3162973	K201	DOE	85	92	3.6	74	103.4	4.3
3	6294	1	3163702	K204	DOE	68	119.6	4.4	45	129.8	5.1
3	6309	48	3335077	K762	DOE	Not Available	Not Available	Not Available	Not Available	74.9	2.7
3	6329	32	3165232	K128, K721 Campus: K721	DOE	52	117.1	5.1	86	91.1	3.7
3	6329	32	3165232	K128, K721 Campus: K128	DOE	52	117.1	5.1	86	91.1	3.7
3	6343	64	3165745	New Utrecht Branch Library	BPL	Not Available	237	6.7	Not Available	183.8	5.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	6391	24	3167212	K229	DOE	14	221.3	6.9	18	184.9	6.1
3	6399	26	3167623	K163	DOE	81	110.6	3.9	80	92.7	3.6
3	6399	40	3392297	K807	DOE	Not Available	Not Available	2	13	202.5	6.7
3	6406	45	3167815	62nd Precinct	NYPD	Not Available	208.1	7.4	Not Available	184.3	6.1
3	6407	8	3167818	K200	DOE	29	106.5	4.1	60	107.6	4.2
3	6418	1	3402739	Dyker Beach Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	37.7	1.1
3	6418	1	3390961	Junior Golf Course	DPR	Not Available	Not Available	Not Available	Not Available	37.7	1.1
3	6535	11	3171478	K099	DOE	88	93.7	3.7	51	108.7	4.6
3	6549	24	3172071	K226	DOE	56	102.9	3.7	41	119.2	5
3	6595	33	3174076	K096	DOE	78	97.9	3.8	66	115.2	4.6
3	6618	1	3396829	K237	DOE	4	267.1	7.8	16	205.9	6.3
3	6631	1	3175834	K177	DOE	63	103.5	3.8	68	99.6	4.2
3	6640	13	3176229	K238	DOE	77	107.5	4	75	95	3.8
3	6642	45	3176314	Council Center for Senior Citizens	DFTA	13	322.9	8.6	Not Available	251	6.7
3	6667	24	3177680	K097, K937 Campus: K097	DOE	6	229.3	13.2	57	110.4	5.3
3	6681	169	3178584	K215	DOE	83	119.3	4.8	73	93.7	3.8
3	6709	54	3179706	Midwood Branch Library	BPL	Not Available	261.4	7.3	Not Available	164.8	4.6
3	6734	109	3180673	K525	DOE	87	123.7	5.5	92	73	3.5
3	6739	77	3180747	K997	DOE	73	257.5	6.9	76	191.2	5.2
3	6740	25	3180761	K199	DOE	98	60.7	1.9	61	102	4.3
3	6769	18	3182169	K197	DOE	95	61.4	2.5	53	87.7	3.8
3	6783	68	3182576	Kings Highway Branch Library	BPL	Not Available	218.1	6.6	Not Available	148.5	4.8
3	6788	1	3182721	K425, K426 Campus: K425	DOE	63	153.9	8.3	72	112.1	5.8
3	6788	1	3182721	K425, K426 Campus: K426	DOE	63	153.9	8.3	72	112.1	5.8
3	6821	123	3184034	K255	DOE	70	110.8	5.9	57	111.8	6.7
3	6821	142	3184035	Homecrest Health Center	DOHMH	Not Available	160.7	5.8	Not Available	132.7	5.6
3	6821	244	3184057	K234	DOE	71	126	4.6	57	106.6	4.4
3	6875	32	3185973	K101	DOE	82	113.5	4.6	63	109.8	4.2
3	6883	1	3186454	K400, K401 Campus: K400	DOE	91	105.4	5.5	94	69.6	2.8
3	6883	1	3186454	K400, K401 Campus: K401	DOE	91	105.4	5.5	94	69.6	2.8
3	6891	1	3186626	K281	DOE	94	75.4	3	94	74.8	3.8
3	6917	1	3187407	K212	DOE	27	109.3	5.7	89	67.2	3.4
3	6943	30	3378180	Brooklyn 11 District Garage; BK Boro Office	DSNY	Not Available	55.9	1.4	Not Available	144.3	5.7
3	6943	30	3415007	SW Brooklyn Marine Transfer Station	DSNY	Not Available	55.9	1.4	Not Available	144.3	5.7
3	6965	140	3188221	K239	DOE	74	84.4	3.6	72	96.9	4.3
3	7006	1	3188726	K188	DOE	87	101.4	4.2	51	119.6	4.3
3	7018	1	3188979	Brooklyn South 13 District Garage	DSNY	Not Available	82.5	2.1	Not Available	390.4	23.4
3	7019	43	3189001	Coney Island Branch Library and Learning Ctr.	BPL	Not Available	223.4	6.9	Not Available	138.8	4.3
3	7051	1	3189517	K329	DOE	50	133.9	6.1	91	76.5	2.8
3	7054	45	3189538	Coney Island Maintenance Facility and Surf Playground Comfort Station	DOE	38	147.5	7.2	73	96.3	3.8
3	7054	45	3385304	Surf Playground Comfort Station	DPR	38	147.5	7.2	73	96.3	3.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	7054	45	3189538	K288	DOE	38	147.5	7.2	73	96.3	3.8
3	7061	16	3414199	New Ida G. Israel Community Health Center	H+H	Not available	Not Available	Not Available	Not Available	282.6	8.1
3	7065	1	3189617	KBQM (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	Not Available	0
3	7069	14	3329347	Poseidon Playground Maintenance Building	DPR	Not Available	116.8	3	Not Available	43.7	1.2
3	7071	123	3189654	Coney Island Job Center	HRA	Not Available	Not Available	Not Available	77	113.6	3.4
3	7071	130	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	7073	101	3189656	Abe Stark Ice Rink	DPR	Not Available	405.2	13.5	Not Available	238.9	6.8
3	7073	101	3424020	Coney Island Boardwalk - W 33rd Street Comfort Station	DPR	Not Available	405.2	13.5	Not Available	238.9	6.8
3	7084	1	3190273	K228	DOE	47	115.5	4.4	52	108.2	4.5
3	7123	66	3192661	K095, K951 Campus: K951	DOE	73	109.1	5.2	77	100.9	5.3
3	7123	66	3192661	K095, K951 Campus: K095	DOE	73	109.1	5.2	77	100.9	5.3
3	7185	20	3194998	K540, K541 Campus: K540	DOE	83	118.1	5.7	89	83.8	3.9
3	7185	20	3194998	K540, K541 Campus: K541	DOE	83	118.1	5.7	89	83.8	3.9
3	7185	20	3385667	K722	DOE	83	118.1	5.7	89	83.8	3.9
3	7192	57	3195027	K687	DOE	Not Available	Not Available	Not Available	Not Available	159.9	5.6
3	7196	1	3195175	K216	DOE	86	85.5	3.3	73	92.1	3.8
3	7226	62	3196054	Classified Location	NYPD	5	433	11.3	4	199.5	5.4
3	7239	1	3337274	Coney Island Hospital	H+H	100	220	5.7	92	308.2	11.3
3	7244	1	3196224	K209, K941 Campus: K941	DOE	77	113.3	4.3	66	106.4	4.6
3	7244	1	3196224	K209, K941 Campus: K209	DOE	77	113.3	4.3	66	106.4	4.6
3	7250	25	3196292	K303	DOE	96	89.7	3.9	91	82.4	3.2
3	7254	1	3196293	K410, K411 Campus: K410	DOE	83	118.1	4.5	72	95.2	3.9
3	7254	1	3196293	K410, K411 Campus: K411	DOE	83	118.1	4.5	72	95.2	3.9
3	7261	47	3196353	Classified Location	NYPD	55	158	6.9	Not Available	135.7	6
3	7261	201	3196378	K620	DOE	87	103.7	5.3	83	82.5	3.4
3	7266	40	3196558	K090	DOE	68	100.6	4.6	63	82.8	3.4
3	7274	107	3196587	K370	DOE	41	174.9	6	54	137.3	5
3	7279	290	3196591	60th Precinct and Engine Company 245	NYPD	Not Available	371.4	12.4	Not Available	258.2	11.8
3	7279	290	3394728	60th Precinct Garage (LL84)	FDNY	Not Available	371.4	12.4	Not Available	258.2	11.8
3	7281	1	3196595	K100	DOE	70	115.3	6	76	93.8	5.4
3	7291	30	3196677	K153	DOE	82	96.2	3.5	73	91.9	3.6
3	7371	52	3200556	61st Precinct	NYPD	Not Available	354.4	11.8	Not Available	237.3	7.9
3	7381	201	3201080	K206	DOE	66	103.2	4	74	84.2	3.6
3	7393	1	3201629	K194, K959 Campus: K194	DOE	66	102.8	3.9	49	118.1	4.4
3	7396	44	3395412	K787	DOE	Not Available	Not Available	Not Available	Not Available	104.8	3.7
3	7405	920	3202630	Kings Bay Branch Library	BPL	Not Available	263.6	7.2	Not Available	190.5	5.8
3	7420	26	3203132	K254	DOE	25	165.3	5.3	36	133.5	4.6
3	7424	1	3203617	K014	DOE	86	83.4	4.4	94	63.3	2.6
3	7425	2	3411256	Yak Playground Comfort Station	DPR	86	88.7	4.2	90	65.8	3.3
3	7425	2	3203631	K495, K496 Campus: K495	DOE	86	88.7	4.2	90	65.8	3.3
3	7425	2	3999999	K495, K496 Campus: K496	DOE	86	88.7	4.2	90	65.8	3.3
3	7442	11	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	7447	1	3204767	K286	DOE	22	129.3	6	94	90.2	4.1
3	7447	1	3386003	Comfort Station to K286	DPR	22	129.3	6	94	90.2	4.1
3	7474	1	3205435	PS 52 Playground Comfort Station	DPR	86	97.2	3.7	67	101.9	4.3
3	7474	1	3205435	K052	DOE	86	97.2	3.7	67	101.9	4.3
3	7551	26	3205780	K152, K927 Campus: K152	DOE	42	143.4	4.9	22	156.2	6.1
3	7552	54	3805828	Annex to K705	DOE	Not Available	Not Available	Not Available	42	242.9	7.9
3	7552	54	3805828	K705 (Main Building)	DOE	Not Available	Not Available	Not Available	42	242.9	7.9
3	7552	100	3347325	Brooklyn College: Chiller Plant	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7552	100	3347325	Brooklyn College: Heating Plant	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7552	100	3205787	Brooklyn College: Roosevelt Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7552	100	3205787	Brooklyn College: Roosevelt Hall Extension	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7552	100	3346969	Brooklyn College: West End Building	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7552	100	3391507	Brooklyn College: West Quad Building	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7552	100	3347326	Brooklyn College: William James Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7553	41	3205788	K405, K407 Campus: K405	DOE	100	58.9	1.6	98	52.7	1.7
3	7553	41	3205788	K405, K407 Campus: K407	DOE	100	58.9	1.6	98	52.7	1.7
3	7555	27	3205803	Brooklyn College: Student Union	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327322	Brooklyn College: Boylan Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327317	Brooklyn College: Ingersoll Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327317	Brooklyn College: Ingersoll Hall Extension	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327319	Brooklyn College: LaGuardia Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327318	Brooklyn College: Whitehead Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327321	Brooklyn College: Whitman / Gershwin Hall	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7556	150	3327321	Brooklyn College: Whitman / Tow	CUNY SC > BKC	Not Available	319.2	11.6	Not Available	271.1	10.5
3	7564	47	3206141	K042	DOE	Not Available	Not Available	Not Available	Not Available	102.4	3.9
3	7599	67	3207376	63rd Precinct	NYPD	Not Available	238.7	8	Not Available	223.1	7.5
3	7625	1	3208461	K193, K952 Campus: K193	DOE	67	113.4	4.1	63	104.3	4.4
3	7629	30	3208638	K240	DOE	82	89.5	4.4	69	83.6	4.7
3	7664	41	3337357	K063	DOE	Not Available	Not Available	Not Available	Not Available	107.9	3.9
3	7706	1	3212254	K222	DOE	80	102.3	3.7	74	94.8	3.9
3	7758	1	3386437	Fox Playground Pool Comfort Station	DPR	61	110.6	5.3	30	118	6.4
3	7758	1	3214729	K251	DOE	61	110.6	5.3	30	118	6.4
3	7775	1	3215550	K852	DOE	92	79.8	2.4	87	70.6	2.7
3	7782	34	3215797	K995	DOE	68	170.6	4.5	99	89.1	2.5
3	7786	1	3215816	K119	DOE	87	103.3	4.5	84	73.4	2.6
3	7849	1	3218626	K203	DOE	66	87.3	3.3	64	105.6	4.5
3	7860	17	3345177	K729	DOE	83	88.6	3.7	86	72.4	3.2
3	7868	39	3219626	Flatlands Branch Library	BPL	Not Available	237.8	7.1	Not Available	103	3.6
3	7893	52	3220944	Brooklyn South 15a District Garage	DSNY	Not Available	730.6	34.6	Not Available	184.7	7.4
3	7916	1	3221964	K855	DOE	88	86.7	2.9	88	68.4	2.5
3	7918	114	3221976	EMS 58	FDNY	Not Available	269.3	10.2	Not Available	142.4	5.6
3	7918	145	3221978	Brooklyn South 14 District Garage	DSNY	Not Available	245.7	9.9	Not Available	202.6	8.9

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	7998	5	3224139	K515	DOE	95	96.2	5.3	85	82.3	4.4
3	8012	400	3325350	Fleet Services, BK Street Maintenance	DOT	Not Available	64.3	2.7	Not Available	192	7.6
3	8018	1	3386872	Bildersee Playground Comfort Station	DPR	87	78.3	3.1	71	89	4.9
3	8018	1	3224947	K068	DOE	87	78.3	3.1	71	89	4.9
3	8034	1	3225637	K276, K923 Campus: K276	DOE	53	128.6	5.4	89	73.7	2.8
3	8116	1	3397904	Brooklyn Repair - Remsen Yard	DEP	Not Available	Not Available	Not Available	Not Available	157.4	5.6
3	8129	60	3325418	K066	DOE	39	177	5.5	39	146.7	5
3	8138	1	3256921	Brooklyn South 17 and 18 District Garage	DSNY	Not Available	244.3	10	Not Available	245.5	10.2
3	8147	26	3229075	69th Precinct	NYPD	Not Available	389.8	12.5	Not Available	348.6	11.4
3	8149	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8149	300	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8158	35	3229155	K260	DOE	67	92.1	4.4	65	78	4.1
3	8160	22	3229159	K114	DOE	49	116.9	3.9	73	95.6	3.6
3	8182	52	3229624	K818	DOE	25	204.3	9.4	33	188.9	9.2
3	8188	1	3229773	K242	DOE	62	110.9	4.1	56	114	5
3	8215	12	3396940	K366	DOE	8	295.7	8.7	19	174.4	5.8
3	8222	1	3230949	K500, K501 Campus: K500	DOE	90	94.2	4.3	67	101.7	4
3	8222	1	3999999	K500, K501 Campus: K501	DOE	90	94.2	4.3	67	101.7	4
3	8227	1	3326732	K211	DOE	83	88.5	4.8	84	78	3
3	8230	1	3326733	K279	DOE	67	117.3	5.2	98	47.4	2.2
3	8256	1	3232559	K115	DOE	41	150.6	5.4	67	103.3	3.9
3	8300	1	3234514	Jamaica Bay Branch Library	BPL	Not Available	Not Available	Not Available	Not Available	176	6.3
3	8329	250	3235261	Bay View Playground Comfort Station	DPR	73	111.5	5.3	82	72.7	3.9
3	8329	250	3235262	K272, K922 Campus: K272	DOE	73	111.5	5.3	82	72.7	3.9
3	8363	9	3235910	Mill Basin Branch Library	BPL	Not Available	Not Available	Not Available	Not Available	124.1	3.9
3	8388	2	3236496	K078	DOE	70	85.8	3.9	86	65.2	3.4
3	8393	1	3236665	K905	DOE	77	118.4	5	47	120.2	4.5
3	8393	1	3236665	K312	DOE	77	118.4	5	47	120.2	4.5
3	8464	1	3326821	K236, K975 Campus: K236	DOE	89	93.3	3.4	92	70	3
3	8470	150	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8484	1	3239388	K207	DOE	89	93.7	3.5	80	84.1	3.2
3	8496	100	3239889	K278	DOE	88	97.9	4.5	87	74.7	4
3	8590	600	3332516	Highway District Unit 2	NYPD	Not Available	183	5.8	Not Available	157.2	6.4
3	8590	600	3242368	Marine Park - Salt Marsh Nature Center	DPR	Not Available	183	5.8	Not Available	157.2	6.4
3	8590	600	3423330	Seba Comfort Station	DPR	Not Available	183	5.8	Not Available	157.2	6.4
3	8590	600	3332516	Flatbush Arterial Division	DOT	Not Available	183	5.8	Not Available	157.2	6.4
3	8590	600	3397329	Marine Park Golf Course Clubhouse	DPR	Not Available	183	5.8	Not Available	157.2	6.4
3	8590	650	3242369	K277	DOE	75	104.9	5.4	43	117.2	5.7
3	8591	980	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8666	610	3244470	K253, K964 Campus: K253	DOE	34	149.9	7.6	64	108.8	4
3	8698	1	3412857	NY Aquarium: HP Ozone Shed	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3412857	NY Aquarium: Hudson River	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	8698	1	3397351	NY Aquarium: AAHC Filter Building	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3397348	NY Aquarium: Aqua Theater	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3421603	NY Aquarium: Aqua Theater Pump Room	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3245160	NY Aquarium: Aquatic Animal Health Center	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3397351	NY Aquarium: Cart Depot	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3397345	NY Aquarium: Conservation Hall	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3397352	NY Aquarium: Comfort Station	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Dive Bunker	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3397355	NY Aquarium: Dive Shower	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: East Ticket Booth	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: East Well	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Grounds, Transformers	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3421600	NY Aquarium: HP Facility Pump Room	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3397354	NY Aquarium: Main Feed Room	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3115623	NY Aquarium: Native Sea Life	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3245159	NY Aquarium: Operations Building	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Sea Cliffs	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Tunnel Holding Facility	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: West Ticket Booth	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3115623	NY Aquarium: West Well	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Aquatheater Chlorine Shed	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: SeaCliffs Chlorine Shed	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Operations Hazardous Waste Storage	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Seawater Intake	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Animal Care	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8698	1	3999999	NY Aquarium: Ocean Wonders: Sharks	CIG > WCS NYA	Not Available	832.8	24.5	Not Available	723.2	21
3	8712	56	3245498	K225	DOE	50	148.4	5.6	63	142.7	6.2
3	8725	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8752	35	3246519	K195	DOE	36	162.1	6.8	46	110.2	4.4
3	8760	60	3326938	K535	DOE	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3326936	Kingsborough CC: Regina S Peruggi Academic Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3326937	Kingsborough CC: Administration Building	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3326934	Kingsborough CC: Arts and Sciences Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3326939	Kingsborough CC: Central Services	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3347727	Kingsborough CC: College Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3347725	Kingsborough CC: Health and Physical Education Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3326938	Kingsborough CC: Leon M. Goldstein High School	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3226937	Kingsborough CC: Leon M. Goldstein Performing Arts Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3326935	Kingsborough CC: Marine and Academic Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3348024	Kingsborough CC: Robert J. Kibbee Library and Media Center	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
3	8760	60	3347726	Kingsborough CC: Security Guard House	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852579	Kingsborough CC: Temporary Building #1	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852580	Kingsborough CC: Temporary Building #2	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852581	Kingsborough CC: Temporary Building #3	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852582	Kingsborough CC: Temporary Building #4	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852583	Kingsborough CC: Temporary Building #5	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852584	Kingsborough CC: Temporary Building #6	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852585	Kingsborough CC: Temporary Building #7	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3852586	Kingsborough CC: Temporary Building #8	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3347724	Kingsborough CC: West Academic Cluster - Wing C	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3347724	Kingsborough CC: West Academic Cluster - Wing D	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3347724	Kingsborough CC: West Academic Cluster - Wing E	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	60	3347724	Kingsborough CC: West Academic Cluster - Wing F	CUNY CC > KCC	Not Available	293.6	10.4	Not Available	196.5	7.2
3	8760	110	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8760	485	3347138	Manhattan Beach Bath Houses Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	53.7	2.2
3	8760	485	3347257	Manhattan Beach Park - Ocean Avenue Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	53.7	2.2
3	8767	26	3246958	K043	DOE	19	118.8	5.9	81	79.9	3
3	8813	170	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
3	8923	920	3343823	Gerritsen Beach Branch Library	BPL	Not Available	Not Available	Not Available	Not Available	146.4	4.6
4	6	8	4538588	Q404	DOE	Not Available	Not Available	Not Available	56	136.3	4.4
4	6	130	4617653	Q375	DOE	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	19	21	4594151	Hunters Point Community Library	QPL	Not available	Not Available	Not Available	Not Available	229.6	6.9
4	21	30	4542629	Q312	DOE	Not Available	Not Available	Not Available	55	117.1	3.7
4	24	7	4000025	5-40 44th Drive Garage	DOT	Not available	Not Available	Not Available	Not Available	85.5	3.1
4	32	6	4000126	108th Precinct	NYPD	Not Available	368.6	13.4	Not Available	426.7	19.5
4	46	34	4000333	Engine Co 258 and Ladder Co. 115	FDNY	Not Available	254.2	8.4	Not Available	133.2	5
4	68	2	4000526	Classified Location	DHS	Not Available	334.2	11.4	Not Available	178.3	5.7
4	75	1	4000548	MoMA PS1 Contemporary Art Center	CIG > MoMA PS1	Not Available	80.2	2.8	Not Available	79.8	2.1
4	83	1	4000698	Long Island City Courthouse	DCAS	68	179.8	6.7	79	111.1	4.9
4	83	18	4000699	Court Square Garage	DOT	Not Available	37.5	1	Not Available	14.9	0.4
4	98	9	4436638	Classified Location	NYPD	96	95.1	3.9	71	55.8	1.5
4	98	11	4436642	Classified Location	NYPD	48	79.3	2.7	35	121.4	6.3
4	100	1	4000744	Q667	DOE	17	196.4	5.4	14	182.8	5.3
4	158	25	4436667	Q797	DOE	69	70.6	3.8	86	67.8	3.8
4	169	6	4540402	Q313	DOE	Not Available	Not Available	Not Available	17	166.5	5.4
4	185	1	4002387	Q150	DOE	36	182.4	7	34	153.1	6.1
4	206	3	4002915	Q199, Q938 Campus: Q938	DOE	54	112.4	5.6	69	107.9	5.2
4	206	3	4002915	Q199, Q938 Campus: Q199	DOE	54	112.4	5.6	69	107.9	5.2
4	226	1	4436685	Q610	DOE	85	97.6	4.9	74	89	4.6
4	228	20	4003259	Q600	DOE	39	160.4	5	92	70.9	2.1
4	228	46	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	249	1	4003442	Q520	DOE	7	176	4.6	37	205.7	6.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	254	1	4003451	Transportation Repair Shop	FDNY	Not Available	306.9	9.5	Not Available	152.4	5.5
4	277	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	295	45	4307187	FDNY Fleet Services	FDNY	Not Available	246.9	10.1	Not Available	164.7	6.8
4	307	33	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	343	1	4004156	Q204	DOE	78	87.9	3.2	98	51.1	2
4	344	1	4004170	Q112	DOE	1	493.1	24	96	51.4	2
4	354	1	4518850	Spirit Playground Comfort Station	DPR	93	79.9	2.6	100	22.8	0.7
4	354	1	4004331	Q076	DOE	93	79.9	2.6	100	22.8	0.7
4	363	1	4463561	Long Island City Community Library	QPL	56	113.2	6	54	114.7	4.3
4	363	1	4004419	Q111	DOE	56	113.2	6	54	114.7	4.3
4	386	7	4004679	Catholic Charities Neighborhood Services Inc.	ACS	Not Available	119.8	4	Not Available	94	3.4
4	404	1	4004874	Q450	DOE	83	129.7	6.2	84	93.4	3.8
4	417	2	4005022	DOT Office	DOT	93	159	4.8	99	95.7	3
4	417	2	4005022	Q800	DOE	93	159	4.8	99	95.7	3
4	438	26	4005184	Q725	DOE	18	171.4	5.1	64	120.4	3.9
4	477	7	4005413	42-00 Vernon Boulevard	DOT	Not Available	Not Available	Not Available	Not Available	Not Available	0
4	488	11	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	489	1	4005429	Q801	DOE	79	108.6	4.4	84	80.8	3.3
4	489	23	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	518	30	4005758	Astoria Health Center	DOHMH	Not Available	150.5	5.9	Not Available	136.9	5.6
4	523	12	4005787	Queens West 1 District Garage	DSNY	Not Available	314.6	11.2	Not Available	301.2	12.1
4	529	2	4467709	Q452, Q453 Campus: Q452	DOE	24	223.8	6.7	41	157.8	4.9
4	529	2	4467709	Q452, Q453 Campus: Q453	DOE	24	223.8	6.7	41	157.8	4.9
4	537	14	4006046	Q171	DOE	82	53.4	2.6	81	77.1	3.7
4	553	1	4006382	Q126	DOE	43	114.6	5.8	80	78.6	4.5
4	592	15	4007619	Q234	DOE	45	145.2	4.6	57	115.7	3.9
4	594	1	4442467	Athens Square Park	DPR	91	83.2	3.8	89	74	3.7
4	594	1	4007663	Q017	DOE	91	83.2	3.8	89	74	3.7
4	610	1	4008220	Q166	DOE	11	157.5	5.7	57	108	4.1
4	632	30	4009361	114th Precinct	NYPD	Not Available	272.3	8.1	Not Available	200.9	6.3
4	634	36	4009499	Q798	DOE	7	269.1	8.7	32	155.4	4.9
4	639	16	4009594	Q570	DOE	Not available	Not Available	Not Available	2	367.8	11.2
4	640	24	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
4	643	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
4	644	1	4439074	Museum of the Moving Image	CIG > MMI	Not Available	174.5	5.6	Not Available	180.9	5.3
4	647	16	4436898	Q397	DOE	Not Available	Not Available	Not Available	91	84.7	4.2
4	676	50	4011018	Broadway Community Library	QPL	Not Available	265.3	7.9	Not Available	387.6	16.1
4	696	14	4442503	Q070, Q970 Campus: Q970	DOE	30	153.6	6.3	28	112.9	3.8
4	696	14	4442503	Q070, Q970 Campus: Q070	DOE	30	153.6	6.3	28	112.9	3.8
4	714	1	4012664	Q010	DOE	73	101.8	3.7	88	77.4	3.2
4	738	2	4013655	Q445, Q446, Q949 Campus: Q445	DOE	74	99.3	5.2	73	86.6	5.3
4	738	2	4013655	Q445, Q446, Q949 Campus: Q446	DOE	74	99.3	5.2	73	86.6	5.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	752	1	4014094	Q151, Q925 Campus: Q151	DOE	44	135.8	6.1	93	66.3	3.3
4	777	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	791	16	4015250	Prison Health Warehouse	DOHMH	2	172.7	6.1	1	242.5	7.9
4	794	17	4015334	Q084	DOE	85	93.9	3.3	64	72.4	2.9
4	810	1	4016102	Q141	DOE	93	83.6	3.4	88	64	2.7
4	831	15	4016923	Steinway (ALC) Community Library	QPL	Not Available	Not Available	Not Available	Not Available	174.9	7.5
4	842	31	4017485	Q085, Q981 Campus: Q085	DOE	59	112.4	4.1	77	87.4	3.9
4	880	1	4019633	Q122	DOE	74	100	3.9	47	92.9	4.1
4	971	1	4021375	Q002	DOE	85	96.1	3.3	89	81.6	3.6
4	1016	45	4022499	TLC Inspections Facility	TLC	Not Available	92.1	3	Not Available	283.9	10.6
4	1090	1	4023781	Q389	DOE	Not Available	Not Available	Not Available	Not Available	118.1	3.9
4	1109	16	4519618	East Elmhurst Playground Comfort Station	DPR	57	116.3	4.6	31	127.6	5.7
4	1109	16	4024487	Q127	DOE	57	116.3	4.6	31	127.6	5.7
4	1184	14	4027102	Q152	DOE	60	127.6	5.6	29	119.5	5.8
4	1228	48	4543408	Q339	DOE	Not Available	Not Available	Not Available	9	176.8	5.9
4	1239	1	4532004	Q011, Q810, Q932 Campus: Q011	DOE	14	176.2	7.7	45	125.1	4.2
4	1242	32	4028492	Q398 (LL84)	DOE	Not Available	Not Available	Not Available	95	51.6	2.6
4	1247	41	4028697	Q297 (Annex)	DOE	Not Available	Not Available	Not Available	1	270.7	9.7
4	1252	1	4442764	Q145	DOE	65	92.8	4	73	82.1	2.9
4	1260	1	4028931	Q230	DOE	22	175.6	5.6	54	130.7	4.5
4	1288	1	4029892	Q069, Q869 Campus: Q869	DOE	58	141.4	4.6	36	133.5	4.9
4	1288	1	4029892	Q069, Q869 Campus: Q069	DOE	58	141.4	4.6	36	133.5	4.9
4	1317	85	4030847	Woodside Community Library	QPL	Not Available	379.9	13.6	Not Available	166.7	5.7
4	1349	28	4031853	Q012	DOE	48	125.4	5.2	35	148.4	5.7
4	1375	1	4437122	East Elmhurst Community Library	QPL	Not Available	240.7	7.4	Not Available	207.2	5.9
4	1377	16	4437125	Q329	DOE	Not Available	Not Available	Not Available	46	133.1	5.1
4	1419	1	4519910	Playground 90 Comfort Station	DPR	81	98.2	3.8	64	105.8	4.3
4	1419	1	4034841	Q148	DOE	81	98.2	3.8	64	105.8	4.3
4	1422	34	4034862	115th Precinct	NYPD	Not Available	222.9	6.8	Not Available	184.2	5.9
4	1423	1	4034891	Q227	DOE	66	84.2	3.5	86	79.6	2.8
4	1423	57	4034892	Q228	DOE	66	130	3.8	77	84.1	3.1
4	1441	15	4546688	Northern Playground Comfort Station	DPR	81	115.3	4.1	71	106.6	4
4	1441	15	4035441	Q149	DOE	81	115.3	4.1	71	106.6	4
4	1443	19	4437128	Q212	DOE	53	149.9	4.7	40	143	4.8
4	1454	18	4035799	Q280	DOE	Not Available	Not Available	0	86	88.4	4.4
4	1460	34	4035854	Q222	DOE	63	136.3	4.3	90	121.6	4.1
4	1497	1	4037028	Elmhurst Hospital: Hope Pavilion	H+H	93	317.4	10.3	96	391.7	13.3
4	1500	2	4437132	Elmhurst Hospital: Main Building	H+H	93	317.4	10.3	96	391.7	13.3
4	1500	2	4834805	Elmhurst Hospital: Parking Garage	H+H	93	317.4	10.3	96	391.7	13.3
4	1500	2	4539651	Elmhurst Hospital: Women's Health Pavilion	H+H	93	317.4	10.3	96	391.7	13.3
4	1500	2	4539650	Elmhurst Hospital: H Building	H+H	93	317.4	10.3	96	391.7	13.3
4	1500	2	4539654	Elmhurst Hospital: Annex G	H+H	93	317.4	10.3	96	391.7	13.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	1500	2	4539653	Elmhurst Hospital: Annex O	H+H	93	317.4	10.3	96	391.7	13.3
4	1500	100	4540117	Frank D. O'Connor Park Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	202.2	8.4
4	1514	1	4037370	Q089	DOE	21	203.8	7.1	67	110.3	4.3
4	1529	73	4038257	Q378	DOE	Not Available	Not Available	Not Available	Not Available	160.6	5.5
4	1538	75	4467710	Q007	DOE	40	157.3	5	49	152.3	5.1
4	1538	75	4467710	Q855	DOE	40	157.3	5	49	152.3	5.1
4	1571	19	4439251	Q322	DOE	61	130.8	4.5	32	154.4	5.4
4	1592	72	4445296	110th Precinct	NYPD	Not Available	285.5	9.4	Not Available	233	7.4
4	1600	61	4437166	Q744	DOE	21	210.6	5.7	7	246.3	7.8
4	1607	1	4437176	Q019, Q914, Q819 Campus: Q019	DOE	74	124.3	4.4	51	108.8	4.2
4	1608	58	4040271	Q260	DOE	6	254.3	7.4	21	211.4	6.5
4	1613	17	4439257	Q315	DOE	Not Available	Not Available	Not Available	15	200.2	6.4
4	1628	21	4547623	Q311	DOE	Not Available	Not Available	Not Available	28	154.4	5
4	1695	39	4437193	Langston Hughes Community Library	QPL	Not Available	260.9	8	Not Available	214.9	6.8
4	1705	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	1714	18	4042496	Q292, Q997 Campus: Q292	DOE	39	163	4.9	56	101.5	3.9
4	1714	18	4042496	Q292, Q997 Campus: Q292 Addition	DOE	39	163	4.9	56	101.5	3.9
4	1722	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	1722	12	4042761	Louis Armstrong Recreation Center	DPR	Not Available	173.5	5.5	Not Available	151.2	5.4
4	1725	1	4540038	Q287	DOE	Not Available	Not Available	Not Available	5	253.1	8.6
4	1729	27	4042887	Corona District Health Center	DOHMH	Not Available	464.4	15.8	Not Available	364.8	12
4	1749	7	4043525	The Child Center of NY Inc	ACS	Not Available	158.9	4.2	Not Available	111.5	3
4	1756	25	4539663	Louis Armstrong Playground Comfort Station	DPR	89	106	4	1	361	13.6
4	1756	25	4043827	Q843	DOE	89	106	4	1	361	13.6
4	1756	25	4043827	Q143, Q937 Campus: Q143	DOE	89	106	4	1	361	13.6
4	1761	35	4043936	Q908	DOE	Not Available	Not Available	Not Available	84	96.7	3.4
4	1790	1	4444576	North Fleet Depot (Harper St. Yard Facility)	DOT	Not Available	235.6	8.8	Not Available	147.3	7.2
4	1791	52	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	1820	1	4045013	126-02 34th Ave	HPD	Not available	Not Available	Not Available	Not Available	Not Available	0
4	1837	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	1849	1	4045629	Q455	DOE	90	94.2	3.7	72	108.3	4.5
4	1873	50	4462647	Q722	DOE	44	155.4	4.7	84	109.8	3.8
4	1891	1	4046832	Q298	DOE	Not Available	Not Available	Not Available	35	125	3.8
4	1891	32	4046834	Q061	DOE	54	122.3	4.9	83	85.2	4
4	1901	40	4437297	Q013	DOE	95	76.1	2.6	52	118.7	4.2
4	1954	37	4437311	Q014	DOE	44	105.2	3.7	56	102.1	3.8
4	1963	5	4048306	Q456	DOE	68	158.4	4.9	64	114.2	3.8
4	1985	1	4048820	Q721, Q906 Campus: Q721	DOE	38	122	4	75	102.3	3.5
4	1985	1	4048820	Q721, Q906 Campus: Q906 (TCU)	DOE	38	122	4	75	102.3	3.5
4	2003	23	4529578	Q028	DOE	35	174.9	5.8	46	138.2	4.4
4	2003	23	4529578	Q974	DOE	35	174.9	5.8	46	138.2	4.4
4	2018	1	4541444	E/O 51st Ave at Grand Central Pkwy Comfort Station	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	2018	1	4439845	Flushing Meadows Corona Park - 56th Ave Comfort Station	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4541445	FMCP Children's Farm	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4458851	Queens Museum of Art	CIG > QM	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4541458	Worlds Fair Marina	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4441124	New York Hall of Science	CIG > NYHS	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4540092	Al Oerter Recreation Center	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4540093	Playground for All Children	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4464056	Flushing Meadows: Queens Theatre in the Park	CIG > QT	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4541450	Flushing Meadows Corona Park Irrigation	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4540097	Flushing Meadows: FMCP Aquatic Center	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4540095	Flushing Meadows: Queens Zoo Concession and Admin Bldgs	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4541447	Flushing Meadows: Allied Building I	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	1	4540096	Flushing Meadows: Allied Building II	DPR	Not Available	208.5	6.2	Not Available	204.3	6.8
4	2018	500	4050124	Olmsted Center Campus: Olmsted Center	DPR	30	284.1	8.8	Not Available	204.3	6.8
4	2018	500	4541448	Olmsted Center: FMCP Garage	DPR	30	284.1	8.8	Not Available	204.3	6.8
4	2077	50	4999999	Lost Battalion Pumping Station	DEP	Not Available	135	4.6	Not Available	114.3	3.7
4	2077	50	4050408	Lost Battalion Hall Recreation Center	DPR	Not Available	135	4.6	Not Available	114.3	3.7
4	2083	123	4050414	Q206, Q956 Campus: Q956	DOE	66	116.2	5.6	59	114.7	5.4
4	2083	123	4050414	Q206, Q956 Campus: Q206	DOE	66	116.2	5.6	59	114.7	5.4
4	2126	14	4442846	Q157	DOE	86	103.8	5.1	82	81.9	3.3
4	2128	14	4520762	Annadale Playground Comfort Station	DPR	9	115.8	5.9	57	97.9	5.3
4	2128	14	4051200	Q175	DOE	9	115.8	5.9	57	97.9	5.3
4	2143	1	4520767	Playground 62 Comfort Station	DPR	27	132.1	6	55	113.4	5.3
4	2143	1	4051290	Q220	DOE	27	132.1	6	55	113.4	5.3
4	2189	2	4052143	Q440, Q441 Campus: Q440	DOE	78	126.3	6.7	66	107.2	6.3
4	2189	2	4052143	Q440, Q441 Campus: Q441	DOE	78	126.3	6.7	66	107.2	6.3
4	2209	10	4520795	Flushing Meadows Corona Park - 73rd Avenue Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	137	6.8
4	2209	10	4541452	Triassic Playground Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	137	6.8
4	2209	10	4541443	Worlds Fair Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	137	6.8
4	2209	10	4541454	Meadow Lake Boathouse	DPR	Not Available	Not Available	Not Available	Not Available	137	6.8
4	2218	21	4052265	Q003	DOE	54	172.2	6.3	9	159.5	5.7
4	2223	54	4052345	Forest Hills Community Library	QPL	Not Available	256.8	7.8	Not Available	111.8	3.6
4	2248	100	4520795	Willow Lake Playground Comfort Station	DPR	74	131.1	6.1	63	106.3	4.2
4	2248	100	4052713	Q196	DOE	74	131.1	6.1	63	106.3	4.2
4	2274	2	4052812	Queens Borough Hall	DCAS	68	208.5	6.5	8	280.8	11
4	2284	6	4052874	Q125, Q825, Q947 Campus: Q125	DOE	40	114.5	4.1	63	92.6	3.3
4	2284	6	4052874	Q125, Q825, Q947 Campus: Q125 Addition	DOE	40	114.5	4.1	63	92.6	3.3
4	2344	30	4054168	Classified Location	NYPD	1	2464.3	116.4	32	295.1	10.3
4	2347	55	4054170	Queens Borough Repair Shop	DSNY	Not Available	246.8	7.8	Not Available	191.2	6.9
4	2351	23	4054172	EMS 45	FDNY	Not Available	Not Available	Not Available	Not Available	257.3	8.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	2361	150	4054276	Classified Location	NYPD	Not Available	287.7	7.7	Not Available	201.6	5.4
4	2361	151	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	2361	268	4462505	Queens West 2,3,4 District Garages; Central Repair Shop	DSNY	Not Available	424	17.3	Not Available	283.6	12.1
4	2423	1	4440274	Q229	DOE	43	135.2	5.2	61	112.8	4.1
4	2450	17	4454423	Q005	DOE	9	205.8	6.4	28	168.9	5.6
4	2451	21	4056455	Q877	DOE	53	188.8	6.1	42	157.6	5.6
4	2503	31	4058611	Q073, Q873 Campus: Q873	DOE	23	107.3	4.8	87	71.6	3.5
4	2503	31	4058611	Q073, Q873 Campus: Q073	DOE	23	107.3	4.8	87	71.6	3.5
4	2600	1	4307983	Queens West 5 and 5A District Garages	DSNY	Not Available	351.2	14.5	Not Available	308.8	13.1
4	2611	447	4462340	Sanitation Police Enforcement	DSNY	Not Available	143	3.7	Not Available	214	9.1
4	2631	106	4059130	Q009	DOE	96	90.6	3.2	80	88.2	3.3
4	2646	18	4440960	Engine Co. 291 and Ladder Co. 140	FDNY	Not Available	Not Available	Not Available	Not Available	250.1	9.2
4	2675	15	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	2732	18	4060987	Q153	DOE	74	115	4	37	121.6	4.6
4	2802	1	4607309	Q058	DOE	66	126.1	4	59	150.3	4.9
4	2803	1	4062864	Q585	DOE	Not Available	Not Available	Not Available	25	179.1	6.4
4	2864	36	4064938	Q269	DOE	84	46.5	2.4	58	89.9	3.5
4	2879	31	4437597	Q102	DOE	4	228.8	7.1	27	144.2	4.5
4	2990	45	4069253	Q049	DOE	15	220	7.2	27	163.4	5.2
4	3027	37	4070445	Q247	DOE	1	412	12.7	12	220	6.3
4	3095	50	4072457	Q139	DOE	65	118.5	4.3	85	87.2	3.4
4	3134	24	4073904	Q174, Q935 Campus: Q174	DOE	54	77	3.6	64	91.9	4.8
4	3172	2	4521435	Russell Sage Playground Comfort Station	DPR	73	72.5	3.1	85	70	3.5
4	3172	2	4075214	Q190	DOE	73	72.5	3.1	85	70	3.5
4	3212	1	4076870	Q144	DOE	55	117.2	4.9	70	75.9	3.8
4	3234	22	4077446	112th Precinct	NYPD	Not Available	425	13.7	Not Available	314.8	10.1
4	3270	1	4078312	Q101	DOE	79	128.4	5	60	117.1	5.1
4	3294	20	4078827	Engine Co. 305 and Ladder Co. 151	FDNY	Not Available	Not Available	Not Available	Not Available	397	15.6
4	3354	39	4437660	Q866	DOE	47	153	4.7	33	146.8	5
4	3360	1	4080168	Q099	DOE	16	166.5	8.2	7	160.9	9.4
4	3360	9001	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	3363	1	4080227	Q485, Q487 Campus: Q485	DOE	85	93.2	3.6	85	84.2	3.6
4	3363	1	4080227	Q485, Q487 Campus: Q487	DOE	85	93.2	3.6	85	84.2	3.6
4	3365	27	4080234	Q290	DOE	Not Available	Not Available	Not Available	10	187.9	6.3
4	3425	7	4597303	Q320	DOE	Not Available	Not Available	Not Available	52	120.4	4.1
4	3428	15	4538307	Q245	DOE	7	354	10.5	1	340.4	10.1
4	3434	1	4081987	Q848	DOE	92	48.8	1.8	60	64.3	2.6
4	3437	1	4082076	Q081, Q917 Campus: Q081	DOE	90	89.8	3.4	90	77.4	3.1
4	3490	1	4083511	Q093	DOE	96	98.9	3.8	69	98.7	4.5
4	3491	1	4083512	Ridgewood Community Library	QPL	Not Available	245.2	9.1	Not Available	209.3	6.6
4	3492	7	4083519	Q071	DOE	90	83.8	3.5	91	72.9	3
4	3534	12	4085173	Q088	DOE	12	258.1	8.6	74	93.8	3.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	3549	44	4085584	Q075	DOE	91	95.8	4.2	93	72.6	2.8
4	3560	4	4085866	Q876	DOE	6	216	7.4	45	156.4	5.6
4	3561	1	4435561	Q239	DOE	48	142	4.4	22	146.9	4.8
4	3563	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	3563	23	4085922	Q849	DOE	6	116.5	3.7	53	99	3.6
4	3579	1	4437837	Q068	DOE	55	147.4	5	51	110.3	3.9
4	3632	1	4088186	104th Precinct	NYPD	Not Available	217.2	7	Not Available	188.6	6.5
4	3683	1	4089566	Q091	DOE	71	111.2	4.8	60	94.4	4.1
4	3696	47	4090100	Glendale Community Library	QPL	Not Available	Not Available	Not Available	Not Available	160.9	5.5
4	3696	47	4090100	Glendale Community Library	QPL	Not Available	Not Available	Not Available	Not Available	160.9	5.5
4	3782	27	4091737	Q087	DOE	91	93.9	3.3	18	163.6	6
4	3812	20	4092660	Q119	DOE	92	95.6	3.8	78	89.1	3.6
4	3846	40	4094055	Q113	DOE	5	208.6	6.5	19	178.5	5.5
4	3866	70	4439150	Forest Park Greenhouse	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3866	70	4558619	Forest Hills Park Comfort Station (Oak Ridge Bldg)	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3866	70	4558621	Forest Park - 87th Street Comfort Station	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3866	70	4558618	Forest Park - 89th Street Comfort Station	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3866	70	4442874	Forest Park Admin Building - The Overlook	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3866	70	4439147	Forest Park DPR Shops	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3866	70	4566234	Forest Park 80th St Comfort Station	DPR	Not Available	71.5	2.1	Not Available	97.1	4.4
4	3886	800	4447233	Q686	DOE	Not Available	Not Available	2	16	205.3	6
4	3976	1	4096774	Q129, Q924 Campus: Q129	DOE	68	111	4	67	107.6	4.1
4	4089	45	4098406	Q336	DOE	Not available	Not Available	Not Available	6	173.6	6.1
4	4167	1	4099233	Q454	DOE	Not Available	Not Available	Not Available	Not Available	143.8	6.1
4	4229	14	4099925	Q029, Q952 Campus: Q029	DOE	64	123.2	5.5	42	120.6	4.4
4	4301	1	4539693	Ulmer Street	EDC	Not Available	Not Available	Not Available	100	0.4	0
4	4301	1	4539693	26-02 Ulmer St	PRIV	Not Available	Not Available	Not Available	100	0.4	0
4	4327	1	4537931	Police Academy	NYPD	Not Available	Not Available	Not Available	Not Available	304.1	9.9
4	4327	100	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	4346	75	4438018	Queens 7 Garage and Boro Office	DSNY	Not Available	131.9	5.1	Not Available	238	7.9
4	4346	75	4802407	North Shore Marine Transfer Station	DSNY	Not Available	131.9	5.1	Not Available	238	7.9
4	4350	1	4570021	Queens 7 District Garage Annex	DSNY	Not Available	651.2	26.8	Not Available	582.7	26.7
4	4350	15	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	4370	50	4100749	Q859	DOE	78	171.9	4.7	81	126.5	3.6
4	4371	173	4462993	Q242	DOE	56	166.7	5.1	70	94.9	3.3
4	4382	1	4605716	Classified Location	NYPD	Not Available	Not Available	Not Available	Not Available	207.2	7
4	4413	20	4462266	Cadwallader Colden Playground Comfort Station	DPR	27	113.4	5.7	62	101.7	5.9
4	4413	20	4100846	Q214	DOE	27	113.4	5.7	62	101.7	5.9
4	4538	1	4610410	Whitestone Playground Comfort Station	DPR	71	76.8	3.9	81	86.7	4.8
4	4538	1	4443652	Elder Terrace Comfort Station	DPR	71	76.8	3.9	81	86.7	4.8
4	4538	1	4103056	Q193, Q967 Campus: Q193	DOE	71	76.8	3.9	81	86.7	4.8
4	4647	1	4105232	Q079, Q766 Campus: Q079	DOE	58	102.3	4.8	64	86.9	4.6

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	4729	1	4522749	Clintonville Playground Comfort Station	DPR	65	81.4	3.7	100	31.7	0.9
4	4729	1	4107342	Q194	DOE	65	81.4	3.7	100	31.7	0.9
4	4802	1	4108664	Q185	DOE	49	77.8	3.7	89	75.4	3.9
4	4803	1	4108665	Q021	DOE	53	105	4.4	61	107.5	5.1
4	4956	55	4112106	Q023	DOE	92	141.1	4.8	75	116.6	4.4
4	4960	1	4112147	Flushing Town Hall	CIG > FTH	Not Available	299.5	10.2	Not Available	137.8	4.8
4	4977	39	4112351	Flushing Armory	NYPD	Not Available	110.3	3.8	Not Available	134.4	6
4	5002	1	4113172	Q460	DOE	78	114.4	5.4	83	91.1	5.2
4	5011	6	4113348	109th Precinct	NYPD	Not Available	173	5.2	Not Available	171.5	5.6
4	5043	11	4114282	Flushing (ALC) Community Library	QPL	Not Available	302	9.7	Not Available	191.8	5.8
4	5047	1	4522986	Bowne Playground Comfort Station	DPR	73	126.1	4.3	46	112	4.1
4	5047	1	4114657	Q020	DOE	73	126.1	4.3	46	112	4.1
4	5051	27	4114763	Q189	DOE	84	105.3	4.8	93	70.1	3.5
4	5107	200	4518265	FMCP Comfort Station	DPR	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5107	200	4439683	QBG: Administration Building	CIG > QBG	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5107	200	4999999	QBG: Greenhouse	CIG > QBG	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5107	200	4999999	QBG: Propagation Building	CIG > QBG	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5107	200	4439683	QBG: Education Building	CIG > QBG	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5107	200	4999999	QBG: Maintenance and Horticulture	CIG > QBG	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5107	200	4439682	QBG: Greenhouse/Maintenance Building	CIG > QBG	Not Available	213.1	6.8	Not Available	299.5	9.6
4	5137	43	4541682	Q244	DOE	3	319.4	9	2	299.4	8.7
4	5147	1	4116436	Q237	DOE	31	75	3.5	100	45.5	2.3
4	5201	21	4117403	Q024, Q936 Campus: Q024	DOE	75	129.2	5	46	116.2	4.3
4	5201	21	4117403	Q024, Q936 Campus: Q024 Addition	DOE	75	129.2	5	46	116.2	4.3
4	5256	1	4523133	Auburndale Playground Comfort Station	DPR	70	101.4	5.4	66	104.6	5.9
4	5256	1	4118954	Q032, Q922 Campus: Q032	DOE	70	101.4	5.4	66	104.6	5.9
4	5261	1	4119139	Q025	DOE	46	146.5	6.7	83	93.8	4.5
4	5328	1	4438184	Q022, Q959 Campus: Q022	DOE	86	101.5	4.4	83	85.9	4.4
4	5443	49	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	5446	18	4123454	Q107	DOE	65	111.7	5.2	35	135.8	6.4
4	5674	2	4128231	Q177, Q979 Campus: Q979	DOE	14	191.4	7.9	81	166.8	5.7
4	5674	2	4128231	Q177, Q979 Campus: Q177	DOE	14	191.4	7.9	81	166.8	5.7
4	5734	1	4128717	Q209	DOE	92	77.2	3.4	95	69.1	3.6
4	5756	1	4129072	Q184	DOE	61	102.3	4.7	91	65.7	2.6
4	5775	100	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	5865	50	4131147	Q169	DOE	13	114.5	5.6	60	91.4	4.5
4	5917	1	4999999	Guard Booth	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453946	Fort Totten: Building 422	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453928	Fort Totten: Building 508	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453929	Fort Totten: Building 509	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453930	Fort Totten: Building 510	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4864635	Fort Totten: Building 511	DPR	Not Available	71.7	2	Not Available	64	2.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	5917	1	4453898	Fort Totten: Building 512	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453898	Fort Totten: Building 513	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453899	Fort Totten: Building 514	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539861	Fort Totten: Building 604	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539841	Fort Totten: Building 633	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539900	Fort Totten: Building 634	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539850	Fort Totten: Building 635	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 416	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539842	Fort Totten: Building 637	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539870	Fort Totten: Building 610 Coast Guard Facility	NYPD	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539871	Fort Totten: Building 611 Coast Guard Facility	NYPD	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539866	Fort Totten: Building 103 (EMS Marine 4/Training)	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539860	Fort Totten: Building 107	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539869	Fort Totten: Building 316	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539814	Fort Totten: Building 325	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539847	Fort Totten: Building 336	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4459162	Fort Totten: Building 418	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539831	Fort Totten: Building 411	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453919	Fort Totten: Building 406	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 209	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539838	Fort Totten: Building 405	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4538415	Fort Totten: Building 413	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 327	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539821	Fort Totten: Building 409	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539893	Fort Totten: Building 130	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453937	Fort Totten: Building 131	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453939	Fort Totten: Building 132	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539851	Fort Totten: Building 133	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453941	Fort Totten: Building 129	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453907	Fort Totten: Building 135	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453908	Fort Totten: Building 136	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453901	Fort Totten: Building 137	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453902	Fort Totten: Building 138	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539877	Fort Totten: Building 139	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453903	Fort Totten: Building 140	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453904	Fort Totten: Building 141	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453904	Fort Totten: Building 142	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453906	Fort Totten: Building 145	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539832	Fort Totten: Building 146	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539866	EMS 53 (Fort Totten Bldg 103)	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539836	Fort Totten: Building 304	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539908	Fort Totten: Building 305	FDNY	Not Available	71.7	2	Not Available	64	2.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	5917	1	4539839	Fort Totten: Building 306	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539878	Fort Totten: Building 307	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539879	Fort Totten: Building 308	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539830	Fort Totten: Building 309	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539853	Fort Totten: Building 311	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 342	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453917	Fort Totten: Building 400	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 315	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539837	Fort Totten: Building 331	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453914	Fort Totten: Building 317	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453921	Fort Totten: Building 401	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453948	Fort Totten: Building 415	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539899	Fort Totten: Building 322	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539835	Fort Totten: Building 323	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453940	Fort Totten: Building 134	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539897	Fort Totten: Building 326	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539855	Fort Totten: Building 410	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539845	Fort Totten: Building 340	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453916	Fort Totten: Building 318	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539895	Fort Totten: Building 332	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 101	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 412	NYPD	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539865	Fort Totten: Building 207	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4549760	Fort Totten: Building 423	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 636	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 344	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539876	Fort Totten: Building 638	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539834	Fort Totten: Building 333	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539822	Fort Totten: Building 402	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539846	Fort Totten: Building 403	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453931	Fort Totten: Building 310	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453935	Fort Totten: Building 312	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453934	Fort Totten: Building 314	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539862	Fort Totten: Building 334	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539880	Fort Totten: Building 100	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 106	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539898	Fort Totten: Building 414	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 108	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539910	Fort Totten: Building 417	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 105	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539833	Fort Totten: Building 419	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4538413	Fort Totten: Building 420	FDNY	Not Available	71.7	2	Not Available	64	2.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	5917	1	4453943	Fort Totten: Building 203	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539849	Fort Totten: Building 208	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539896	Fort Totten: Building 211	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 104	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539873	Fort Totten: Building 313	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 303	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539840	Fort Totten: Building 338	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 321	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 324	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 328	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 337	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453920	Fort Totten: Building 407	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4864639	Fort Totten: Building 421	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 404	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453895	Fort Totten: Building 424	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453896	Fort Totten: Building 425	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453947	Fort Totten: Building 426	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4538413	Fort Totten: Building 427	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453947	Fort Totten: Building 428	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453944	Fort Totten: Building 429	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453945	Fort Totten: Building 430	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539884	Fort Totten: Building 431	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4999999	Fort Totten: Building 432	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453925	Fort Totten: Building 505	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453926	Fort Totten: Building 506	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4539889	Fort Totten: Building 507	DPR	Not Available	71.7	2	Not Available	64	2.8
4	5917	1	4453907	Fort Totten Operation Bldg #135B	FDNY	Not Available	71.7	2	Not Available	64	2.8
4	6038	13	4134525	Q159	DOE	50	94.6	4	56	100.3	5.2
4	6044	1	4134578	Q405, Q761 Campus: Q761	DOE	100	71.2	3.2	99	67.6	3.2
4	6044	1	4134578	Q405, Q761 Campus: Q405	DOE	100	71.2	3.2	99	67.6	3.2
4	6121	1	4135975	Q041, Q728 Campus: Q728	DOE	54	123.3	5.1	97	71	3.5
4	6121	1	4135975	Q041, Q728 Campus: Q041	DOE	54	123.3	5.1	97	71	3.5
4	6185	1	4438249	Q809	DOE	29	152.2	6.4	3	249.7	11.6
4	6203	1	4137034	Q130	DOE	41	126.9	5.5	62	120.3	5.8
4	6373	1	4139491	Q120	DOE	43	121.1	4.4	61	114.8	4.3
4	6507	1	4439900	Q425, Q426, Q951 Campus: Q951	DOE	87	112.3	4.8	76	104.6	4.8
4	6507	1	4448708	Q219	DOE	87	112.3	4.8	76	104.6	4.8
4	6507	1	4439900	Q425, Q426, Q951 Campus: Q425	DOE	87	112.3	4.8	76	104.6	4.8
4	6507	1	4439900	Q425, Q426, Q951 Campus: Q426	DOE	87	112.3	4.8	76	104.6	4.8
4	6507	30	4141868	Queens College: Queens Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6507	100	4141870	Queens College: Athletic Field House	CUNY SC > QC	Not Available	Not Available	Not Available	Not Available	163.5	7.4
4	6507	150	4467571	Q499	DOE	27	160.6	5	39	164.9	5.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	6507	200	4538714	Q515	DOE	100	29	1.6	62	115.4	3.8
4	6517	1	4467560	Queens College: Dining Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4467567	Queens College: Dining Hall Addition	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439916	Queens College: Fitzgerald Gymnasium	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439915	Queens College: Fuel Oil Pump House	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4467561	Queens College: G Building	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439920	Queens College: Gertz Speech Clinic	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439918	Queens College: Goldstein Theatre	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4141870	Queens College: Irrigation Pump House	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439910	Queens College: Jefferson Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439921	Queens College: King Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4467565	Queens College: Main Gate - Security	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439915	Queens College: Heating Plant	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4543598	Queens College: Honors Center	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439912	Queens College: Hortense Powdermaker Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4467562	Queens College: I Building	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439909	Queens College: L-1 B and G Admin	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439907	Queens College: L-2 B and G Lockers	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439908	Queens College: L-3 B and G Laborers and Station Engineers	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439906	Queens College: L-4 B and G Shop and Storage	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439905	Queens College: L-5 B and G Equipment	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4442884	Queens College: Laura Arthur Colwin Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4442883	Queens College: Lloyd T. Delany Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4141870	Queens College: Margaret Kiely Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439911	Queens College: Paul Klapper Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439919	Queens College: Rathaus Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439902	Queens College: Remsen Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4467563	Queens College: School of Music	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439904	Queens College: Science Building	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439914	Queens College: Virginia Frese Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4467564	Queens College: Alumni Entrepreneurship Center	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439913	Queens College: Benjamin Rosenthal Library	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439912	Queens College: Campbeel Dome	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4543598	Queens College: CEP - 1	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4543598	Queens College: CEP - 2	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439917	Queens College: Colden Auditorium	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	1	4439905	Queens College: DASNY Trailer	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	50	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	6517	200	4467570	Queens College: Student Union	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6517	250	4467569	Queens College: Gregory Razran Hall	CUNY SC > QC	Not Available	229	7.5	Not Available	163.5	7.4
4	6606	2	4523885	PS 164 Playground (Queens Valley) Comfort Station	DPR	35	94.9	4.6	57	98.7	5.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	6606	2	4142980	Q164	DOE	35	94.9	4.6	57	98.7	5.4
4	6629	35	4438284	Q792	DOE	88	91.9	4	94	65.1	2.9
4	6661	5	4144059	Kew Gardens Hills Community Library	QPL	Not available	Not Available	Not Available	Not Available	221.4	6.5
4	6697	12	4523902	Vleight Playground Comfort Station	DPR	71	121.8	5.8	49	120	6.1
4	6697	12	4144881	Q165	DOE	71	121.8	5.8	49	120	6.1
4	6726	70	4146042	Q163, Q968 Campus: Q163	DOE	94	58.2	2.8	21	130.9	4.6
4	6743	29	4146646	Queens College: Kissena Hall	CUNY SC > QC	Not Available	Not Available	Not Available	Not Available	163.5	7.4
4	6789	1	4523931	Emerald Playground Comfort Station	DPR	39	127.6	6.8	45	116	6.3
4	6789	1	4523931	PS 200 Playground Comfort Station	DPR	39	127.6	6.8	45	116	6.3
4	6789	1	4146990	Q200	DOE	39	127.6	6.8	45	116	6.3
4	6792	100	4146992	Q201	DOE	57	79.6	4.1	82	66	3
4	6809	56	4147452	Q707	DOE	8	145.6	5.2	76	107.6	4.2
4	6826	1	4147847	Q168	DOE	73	131.4	6.6	81	96.9	3.9
4	6834	1	4546276	Playground 75 Comfort Station	DPR	71	105.4	3.9	73	102.1	4.1
4	6834	1	4148003	Q154	DOE	71	105.4	3.9	73	102.1	4.1
4	6858	1	4442431	Queens Chief Medical Examiner	OCME	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4442433	Queens Hospital: Main Building	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4607928	EMS 50	FDNY	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4835154	Queens Hospital: N Building	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4859742	Queens Hospital: Pavilion	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4834611	Queens Hospital: Queens Hospital T Building	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4538167	Queens Hospital: Queens Hospital Modular Building	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4442432	Queens Hospital: Queens Hospital S Building	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	1	4442431	Queens Hospital: Queens Hospital E & F Building	H+H	Not Available	Not Available	Not Available	99	335.9	12.4
4	6858	50	4539721	Q695	DOE	Not Available	Not Available	2	9	214.8	6.9
4	6858	100	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	6882	1	4148763	Q430, Q966 Campus: Q966	DOE	82	98	4.2	87	90.1	4.4
4	6882	1	4148763	Q430, Q966 Campus: Q430	DOE	82	98	4.2	87	90.1	4.4
4	6903	1	4149078	Q216	DOE	96	74.9	3.5	91	69.1	3.2
4	6927	22	4524004	Fresh Meadows Playground Comfort Station	DPR	42	97	4.6	61	99.4	5.9
4	6927	22	4149690	Q173, Q723 Campus: Q173	DOE	42	97	4.6	61	99.4	5.9
4	7117	421	4415329	Farm Playground/PS 26 Comfort Station	DPR	70	93.5	4.8	57	93.1	4.7
4	7117	421	4153296	Q026	DOE	70	93.5	4.8	57	93.1	4.7
4	7128	10	4153407	Q179	DOE	94	46.6	2.1	99	40.5	2.1
4	7277	1	4156558	Q178	DOE	3	168	7.7	66	99.6	4
4	7290	1	4539747	Cunningham Park - 193rd Street Comfort Station	DPR	Not Available	339.9	15.4	Not Available	249.4	11
4	7290	1	4539746	Cunningham Park - Avon Rd Comfort Station	DPR	Not Available	339.9	15.4	Not Available	249.4	11
4	7290	1	4156608	Cunningham Park Maintenance Building	DPR	Not Available	339.9	15.4	Not Available	249.4	11
4	7290	1	4539740	Cunningham Park Refreshment Building	DPR	Not Available	339.9	15.4	Not Available	249.4	11
4	7290	1	4616168	Cunningham Park Tennis Center	DPR	Not Available	339.9	15.4	Not Available	249.4	11
4	7312	1	4524097	Marie Curie Park Comfort Station	DPR	58	68.7	3.4	81	70.9	3.9
4	7312	1	4438325	Q158	DOE	58	68.7	3.4	81	70.9	3.9

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	7316	18	4156949	Q031	DOE	2	161.5	7.8	9	148.1	7.8
4	7327	28	4596229	Q332	DOE	Not Available	Not Available	Not Available	4	189.8	6.7
4	7333	221	4157390	111th Precinct	NYPD	Not Available	303.3	10.3	Not Available	225.7	7.4
4	7410	1	4524149	Saul Weprin Playground Comfort Station	DPR	24	71.6	3.4	22	123.6	6.5
4	7410	1	4159363	Q162	DOE	24	71.6	3.4	22	123.6	6.5
4	7442	1	4438331	Q361 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	7442	1	4438331	Q361 (Main Building) (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	7482	317	4161005	Q203	DOE	82	89.7	4.5	84	83.3	4.4
4	7490	2	4439437	Queensborough CC: Y2 Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4539248	Queensborough CC: Z Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439437	Queensborough: Administration / Business Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4539249	Queensborough CC: Annex A - TR1	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4539249	Queensborough CC: Annex B - TR2	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439435	Queensborough CC: Boiler Room	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439439	Queensborough CC: C Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439436	Queensborough CC: Cafeteria / Student Union Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439431	Queensborough CC: Humanities Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439435	Queensborough CC: Kennedy Hall Gymnasium	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439440	Queensborough CC: Kurt Schmeller Library	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439438	Queensborough CC: Medical Arts Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439433	Queensborough CC: Oakland Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439434	Queensborough CC: Science Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4539247	Queensborough CC: Service Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439432	Queensborough CC: Technology Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4439438	Queensborough CC: Temporary #5 - Garage	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7490	2	4458074	Queensborough CC: W Building	CUNY CC > QCC	Not Available	303.5	11.3	Not Available	264.4	10.1
4	7502	11	4161098	ASAP Center (Future) (LL84)	CUNY CC > QCC	Not Available	Not Available	Not Available	Not Available	264.4	10.1
4	7529	1	4161735	Q415, Q416, Q943 Campus: Q943	DOE	86	107.2	5.2	77	102.2	5.5
4	7529	1	4161735	Q415, Q416, Q943 Campus: Q415	DOE	86	107.2	5.2	77	102.2	5.5
4	7529	1	4161735	Q415, Q416, Q943 Campus: Q416	DOE	86	107.2	5.2	77	102.2	5.5
4	7570	1	4999999	Old Douglaston Pumping Station	DEP	Not Available	Not Available	Not Available	Not Available	13032.4	343.4
4	7619	1	4524205	Tall Oak Playground Comfort Station	DPR	81	121.6	6.3	72	109.7	5.9
4	7619	1	4162449	Q046	DOE	81	121.6	6.3	72	109.7	5.9
4	7621	12	4162454	Engine Co. 326 and Ladder Co. 160, Batt. 53	FDNY	Not Available	Not Available	Not Available	Not Available	295.4	9.7
4	7677	1	4163698	Q213	DOE	35	82.8	4	80	82.4	4.6
4	7723	1	4163953	Q074	DOE	86	108.6	4.9	72	88.5	4.6
4	7753	1	4164007	Q205	DOE	23	82	4.7	75	79.8	4.1
4	7774	165	4164350	Q188	DOE	32	103.1	4	59	92.3	3.9
4	7870	70	4529898	Q208	DOE	1	304.5	9.2	16	246.5	8.2
4	7870	72	4529899	Q566	DOE	46	142.1	4.4	74	100	3.1
4	7870	74	4529900	Q266	DOE	26	123.3	3.6	5	241.7	8
4	7930	2	4166101	Q435	DOE	95	71	3.5	96	57.3	3.1

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	7955	2	4166561	Q018	DOE	95	75.5	3.8	77	87.8	4.3
4	8082	285	4168629	Q098	DOE	89	107.6	4.1	35	132.1	5.8
4	8126	87	4169275	Douglaston/Little Neck Community Library	QPL	Not Available	234.6	6.7	Not Available	79.2	2.6
4	8135	29	4169468	Q094	DOE	63	121.6	5	64	113.7	4.8
4	8221	12	4524428	Louis Pasteur Park Comfort Station	DPR	92	71.6	3.4	90	68.2	3.5
4	8221	12	4170797	Q067	DOE	92	71.6	3.4	90	68.2	3.5
4	8276	620	4171759	Q221	DOE	81	70.5	3.3	79	77.2	4.3
4	8310	125	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	8361	1	4524456	Challenge Playground Comfort Station	DPR	22	153.1	7.6	79	132.4	6.6
4	8361	1	4173060	Q811	DOE	22	153.1	7.6	79	132.4	6.6
4	8401	375	4524465	Castlewood Playground Comfort Station	DPR	24	122	6	60	115.2	6.5
4	8401	375	4173640	Q186	DOE	24	122	6	60	115.2	6.5
4	8616	1	4524549	Bellerose Playground Comfort Station	DPR	74	78.7	3.4	1	201.9	9.6
4	8616	1	4175739	Q133	DOE	74	78.7	3.4	1	201.9	9.6
4	8717	1	4524659	Playground 80 Comfort Station	DPR	86	87.6	4.7	81	73.8	2.8
4	8717	1	4178127	Q115	DOE	86	87.6	4.7	81	73.8	2.8
4	8731	4	4178464	Q172	DOE	35	82.6	3.6	77	74	3.7
4	8801	14	4180083	Q191	DOE	95	80.9	5.3	89	91.6	5
4	8834	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	8855	20	4181565	Q097	DOE	90	97.5	3.5	35	109.1	4.2
4	8925	26	4438404	Q477 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	68.7	2.3
4	8929	5	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	8929	58	4184144	Q060, Q860 Campus: Q860	DOE	94	96.9	3.2	72	90.3	3.7
4	8929	58	4184144	Q060, Q860 Campus: Q060	DOE	94	96.9	3.2	72	90.3	3.7
4	8975	100	4538070	Q262	DOE	52	277.5	7.8	11	205.8	6.3
4	9053	14	4524990	Ampere Playground Comfort Station	DPR	81	122.4	5.9	44	118.7	5.9
4	9053	14	4188214	Q064	DOE	81	122.4	5.9	44	118.7	5.9
4	9064	31	4541381	Q316	DOE	Not Available	Not Available	Not Available	11	141.9	5.1
4	9067	1	4188567	Q210	DOE	61	91.8	4	88	66.7	2.4
4	9102	27	4189324	Q439 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	103.6	3.1
4	9121	11	4438525	Q884	DOE	58	143.3	4.2	18	161.1	5.3
4	9155	25	4190727	Q063	DOE	63	127.4	4.8	70	109.2	4.4
4	9172	1	4467457	Q137	DOE	41	145.8	4.5	65	108.2	3.8
4	9177	23	4191296	Q254	DOE	20	181.9	6	41	143.9	4.9
4	9183	1	4191497	Q066, Q989 Campus: Q066	DOE	86	111.8	3.9	55	107.5	4
4	9204	28	4192167	Q090	DOE	74	79.4	2.8	73	84.8	3.3
4	9226	57	4192689	Q056, Q995 Campus: Q056	DOE	82	120.8	4.3	30	117.6	5.1
4	9280	1	4193916	Q054, Q864 Campus: Q054	DOE	82	102.8	3.7	59	104	4.3
4	9280	1	4193916	Q054, Q864 Campus: Q864	DOE	82	102.8	3.7	59	104	4.3
4	9288	101	4539360	Q273	DOE	Not Available	Not Available	Not Available	7	241.8	7.2
4	9321	1	4195688	Q475, Q944 Campus: Q475	DOE	61	151.5	8.2	71	109.8	6.5
4	9327	21	4195880	102nd Precinct	NYPD	Not Available	385.6	12.2	Not Available	336.4	12.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	9327	26	4449704	Q051	DOE	60	163.9	5.2	32	139	5.2
4	9340	104	4196343	Q383	DOE	Not Available	Not Available	Not Available	Not Available	121.7	4
4	9375	7	4196913	Squad 270 and Division 13	FDNY	Not Available	Not Available	Not Available	Not Available	283.6	9.7
4	9375	261	4196969	Queens West 9 District Garage	DSNY	Not Available	143.3	5.6	Not Available	167.9	6.9
4	9381	44	4438609	Q650	DOE	22	209.2	6.1	7	232.2	7.1
4	9410	1	4197909	Q062	DOE	77	103.9	3.6	56	116.1	4.3
4	9435	16	4441342	Q636	DOE	Not Available	Not Available	Not Available	73	112.7	4.3
4	9477	1	4200233	Q055, Q865, Q953 Campus: Q865	DOE	75	121.6	4.5	60	100.1	3.9
4	9477	1	4200233	Q055, Q865, Q953 Campus: Q055	DOE	75	121.6	4.5	60	100.1	3.9
4	9491	1	4200748	Q161	DOE	51	139.9	4.1	34	126.4	4.3
4	9505	61	4201325	106th Precinct	NYPD	Not Available	269.4	8.9	Not Available	274.6	9.5
4	9540	2	4529513	Q480, Q481, Q726 Campus: Q480	DOE	Not available	Not Available	Not Available	62	106	5.9
4	9657	1	4206524	Queens Borough Hall Parking Garage	DOT	Not Available	Not Available	Not Available	Not Available	1.6	0
4	9662	20	4314908	Classified Location	DHS	Not Available	202.1	7.3	Not Available	58.5	2.1
4	9679	67	4448758	Q882	DOE	72	71.9	1.9	86	71.4	3.3
4	9679	67	4448758	Q883	DOE	72	71.9	1.9	86	71.4	3.3
4	9680	1	4448759	Queens Civil Court	DCAS	63	234.9	7	86	98.7	3.1
4	9684	8	4206905	Q082	DOE	51	142.5	5.4	49	117.6	4.6
4	9691	1	4207071	Queens Supreme Court	DCAS	74	191.4	6.5	84	113.2	4
4	9707	48	4207510	Q680	DOE	80	86.8	2.5	56	102.5	3.5
4	9723	150	4208040	Q117	DOE	62	113.8	4.4	56	93.4	4.6
4	9724	173	4208124	Q217, Q994 Campus: Q994	DOE	86	102.4	4.8	72	95.5	3.4
4	9724	173	4208124	Q217, Q994 Campus: Q217	DOE	86	102.4	4.8	72	95.5	3.4
4	9756	6	4208836	Jamaica Health Center Main	DOHMH	Not Available	220.1	6.9	Not Available	190.8	6.7
4	9756	6	4595378	Jamaica Health Center Annex	DOHMH	Not Available	220.1	6.9	Not Available	190.8	6.7
4	9756	40	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
4	9756	54	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	9763	23	4594831	Q277	DOE	Not Available	Not Available	Not Available	13	170.9	4.6
4	9768	22	4209031	Q595, Q969 Campus: Q595	DOE	25	116.7	4.5	70	89.6	3.2
4	9768	22	4209031	Q595, Q969 Campus: Q969	DOE	25	116.7	4.5	70	89.6	3.2
4	9774	1	4448767	Q505, Q086, Q506 Campus: Q505	DOE	98	78.1	3.7	96	56.6	3.1
4	9774	1	4448767	Q505, Q086, Q506 Campus: Q506	DOE	98	78.1	3.7	96	56.6	3.1
4	9774	1	4438678	Q505, Q086, Q506 Campus: Q086	DOE	98	78.1	3.7	96	56.6	3.1
4	9798	6	4209635	Queens Central Library	QPL	Not Available	230.1	7.2	Not Available	203.4	6.1
4	9799	27	4209646	103rd Precinct	NYPD	Not Available	227.4	7.5	Not Available	223.9	8.2
4	9813	33	4310514	Q314	DOE	Not Available	Not Available	Not Available	8	221.5	6.9
4	9833	4	4448804	Classified Location	DHS	Not Available	260.8	10.8	Not Available	88.3	3.8
4	9858	100	4448806	Q470	DOE	78	113	6.3	85	87	3.7
4	9867	2	4525850	Joseph Austin Playground Comfort Station	DPR	95	78.2	3.7	98	48.7	2.3
4	9867	2	4211027	Q620	DOE	95	78.2	3.7	98	48.7	2.3
4	9875	1	4211112	Q131, Q911 Campus: Q131	DOE	Not Available	Not Available	Not Available	65	95.8	3.9
4	9914	1	4446042	Q095, Q910 Campus: Q910	DOE	86	108.2	4.1	69	98.8	4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	9914	1	4446042	Q095, Q910 Campus: Q095	DOE	86	108.2	4.1	69	98.8	4
4	9919	6	4212425	Q238	DOE	24	79.3	3.2	82	70.7	3.2
4	9993	3	4439745	Queens Business Center	DOF	89	130.7	3.7	95	93.6	3
4	9994	38	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	10021	1	4214446	Clifford Glover Day Care Center Inc.	ACS	Not Available	146.3	3.8	Not Available	143.7	3.8
4	10024	12	4214461	Q050, Q850 Campus: Q050	DOE	68	154.4	5.7	6	189.8	6.8
4	10092	1	4215602	Queens Family Court Parking Garage	DOT	Not Available	38.5	1	Not Available	29.8	0.8
4	10092	6	4215603	Classified Location	NYPD	Not Available	611.2	21.4	Not Available	465.4	15.3
4	10093	1	4438731	Queens Family Court	DCAS	39	289.1	8.7	Not Available	272.8	8.6
4	10093	1	4448847	OCSS Queens Family Court	HRA	39	289.1	8.7	Not Available	272.8	8.6
4	10097	10	4315254	JCAL, Jamaica Performing Arts Center	CIG > JCAL	Not Available	283.8	9.2	Not Available	235.1	7.6
4	10100	1	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
4	10101	11	4215617	Jamaica Center for Arts and Learning	CIG > JCAL	Not Available	46.2	1.2	Not Available	140.6	4.3
4	10103	16	4448849	York College: Classroom Building	CUNY SC > YC	Not Available	33.1	0.9	Not Available	110.2	2.9
4	10103	16	4439752	York College: St. Monicas / Child Care Center	CUNY SC > YC	Not Available	33.1	0.9	Not Available	110.2	2.9
4	10115	45	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	10144	42	4216099	Q048	DOE	56	175.9	6.6	70	110.7	4.9
4	10144	47	4590626	Q276	DOE	Not Available	Not Available	Not Available	5	246.8	9
4	10155	29	4216225	Dual Center ACS Administrative Site	ACS	74	179.4	5.1	57	197	5.7
4	10178	1	4216655	Q008	DOE	32	121.3	5.3	79	91.5	4.4
4	10193	1	4216947	All My Children Daycare and Nursery School	ACS	Not Available	136	3.7	Not Available	69.8	2.2
4	10215	1	4217573	Q268	DOE	18	188	5.7	29	142.3	4.9
4	10250	1	4218416	Q116, Q930 Campus: Q930	DOE	71	114.9	4.4	59	99.6	4.1
4	10250	1	4218416	Q116, Q930 Campus: Q116	DOE	71	114.9	4.4	59	99.6	4.1
4	10447	7	4222137	Q035, Q929 Campus: Q035	DOE	72	120.9	4.3	7	168.6	6.1
4	10540	5	4224473	Q483	DOE	Not Available	Not Available	Not Available	Not Available	174	6.2
4	10582	16	4225816	Q135	DOE	48	135.7	4.8	40	121.5	4.8
4	10626	1	4226839	Q109	DOE	87	98.2	3.9	78	89.3	3.8
4	10737	1	4230132	105th Precinct	NYPD	Not Available	272.8	9.6	Not Available	234.4	7.6
4	10756	1	4230589	Q033, Q931 Campus: Q033	DOE	73	100.8	4	51	102.7	4.6
4	10813	5	4231378	Q263	DOE	3	300.4	8.2	4	243.2	7
4	10906	1	4438829	Q134, Q835 Campus: Q835	DOE	46	141.8	5	74	87.1	3.7
4	10906	1	4440330	Q134, Q835 Campus: Q134	DOE	46	141.8	5	74	87.1	3.7
4	10917	29	4233644	Charles R Drew Early Learning Center	ACS	Not Available	182.7	5	Not Available	176.6	4.8
4	10926	50	4233850	Q118	DOE	56	141.2	5.3	66	102.7	4.3
4	10941	206	4234212	Blanche Day Care Center	ACS	Not Available	162.8	5.6	Not Available	153.6	5.3
4	10944	301	4526677	Hollis Playground Comfort Station	DPR	70	84.4	3.2	84	68.4	3.6
4	10944	301	4234318	Q192	DOE	70	84.4	3.2	84	68.4	3.6
4	10975	1	4235252	Q892	DOE	Not available	Not Available	Not Available	16	186.5	7
4	11018	21	4236757	Q822	DOE	74	100.2	4.1	81	78.2	3.3
4	11018	21	4236757	Q136	DOE	74	100.2	4.1	81	78.2	3.3
4	11049	1	4238003	Q490, Q491 Campus: Q490	DOE	94	90.3	3.6	82	85.3	3.7

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	11049	1	4238003	Q490, Q491 Campus: Q491	DOE	94	90.3	3.6	82	85.3	3.7
4	11067	40	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	11151	81	4240503	Q034, Q834 Campus: Q834	DOE	54	122.8	4.5	59	97	3.8
4	11151	81	4240503	Q034, Q834 Campus: Q034	DOE	54	122.8	4.5	59	97	3.8
4	11300	1	4575120	East Springfield Playground Comfort Station	DPR	95	83.9	2.6	27	129.8	5.2
4	11300	1	4243743	Q851	DOE	95	83.9	2.6	27	129.8	5.2
4	11300	1	4243743	Q147	DOE	95	83.9	2.6	27	129.8	5.2
4	11368	20	4539787	Sunrise Yard	DOT	Not Available	238.8	9.6	Not Available	170.4	6.7
4	11403	1	4245993	Q202	DOE	87	80.6	3.8	94	61.3	3.1
4	11445	1	4527022	Harold Schneiderman Playground Comfort Station	DPR	93	77.3	3.7	64	95.7	4.3
4	11445	1	4247454	Q232, Q983 Campus: Q983	DOE	93	77.3	3.7	64	95.7	4.3
4	11445	1	4247454	Q232, Q983 Campus: Q232	DOE	93	77.3	3.7	64	95.7	4.3
4	11475	11	4247572	Q108	DOE	53	125.6	4.4	39	119.7	4.6
4	11558	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	11607	1	4249769	Q121, Q915 Campus: Q121	DOE	75	123.1	5.7	34	110.9	4.4
4	11623	1	4250416	Q100	DOE	75	112	3.9	41	120.4	5
4	11673	1	4252357	Q155, Q976 Campus: Q155	DOE	86	94.9	5	56	84.7	4.6
4	11694	27	4253028	Q096, Q986 Campus: Q986	DOE	91	112.8	4.8	46	119	5.1
4	11694	27	4253028	Q096, Q986 Campus: Q096	DOE	91	112.8	4.8	46	119	5.1
4	11714	100	4253607	Q226, Q923 Campus: Q226	DOE	51	139	5	81	94.1	3.7
4	11882	1	4257530	Q124	DOE	45	191.1	8.2	44	138.7	6.3
4	11884	1	4257531	Queens East 8,10,12 District Garage;12A Broom	DSNY	Not Available	345	14.8	Not Available	447.1	20.7
4	11900	120	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
4	11942	302	4258143	Q160, Q958 Campus: Q160	DOE	71	112.4	5.5	58	106	5.8
4	11972	70	4259200	Q142, Q875 Campus: Q875	DOE	49	132	4.9	73	116.3	4.7
4	11972	70	4259200	Q142, Q875 Campus: Q142	DOE	49	132	4.9	73	116.3	4.7
4	12019	10	4260828	Q123, Q965 Campus: Q965	DOE	63	106.4	3.9	86	57.2	2.5
4	12019	10	4260828	Q123, Q965 Campus: Q123	DOE	63	106.4	3.9	86	57.2	2.5
4	12033	10	4261207	Q781	DOE	68	137.9	5.3	58	101.7	3.4
4	12039	44	4261337	Omega PSI PHI Fraternity	ACS	Not Available	214.3	5.7	Not Available	148.3	4
4	12051	1	4261713	Q223	DOE	9	141.3	6.1	27	112.8	5
4	12062	51	4261925	Alpha Kappa Alpha Sorority Child Care Center	ACS	Not Available	144.5	3.7	Not Available	147.5	3.9
4	12104	1	4262725	Q045	DOE	92	91.9	3.6	25	111	4.4
4	12151	1	4263341	Q040, Q988 Campus: Q040	DOE	64	125.4	5.1	52	109.1	4.6
4	12200	52	4264631	South Jamaica Multi Service Center	HRA	28	240.8	7.7	95	79.5	2.7
4	12261	1	4265978	Q400, Q401 Campus: Q401 (Athletic field)	DOE	90	94.8	5.2	84	76.3	3.5
4	12261	1	4265978	Q400, Q401 Campus: Q400	DOE	90	94.8	5.2	84	76.3	3.5
4	12335	49	4464077	Q690	DOE	13	193.4	5.8	9	179.3	5.4
4	12341	31	4267260	Q140, Q954 Campus: Q140	DOE	61	131	4.9	50	113	4.8
4	12393	1	4268543	Q633	DOE	Not Available	Not Available	Not Available	47	141.9	4.7
4	12406	180	4268835	Roy Wilkins Recreation Center	DPR	Not Available	230.4	7.8	Not Available	168.4	6.3
4	12406	180	4594533	Shea Stadium Parking Lot	DPR	Not Available	230.4	7.8	Not Available	168.4	6.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	12406	180	4594533	Roy Wilkens Park Comfort Station	DPR	Not Available	230.4	7.8	Not Available	168.4	6.3
4	12439	32	4268900	Q036, Q836 Campus: Q836	DOE	17	191.5	8.8	33	116	4.1
4	12439	32	4268900	Q036, Q836 Campus: Q036	DOE	17	191.5	8.8	33	116	4.1
4	12495	45	4270044	113th Precinct	NYPD	Not Available	477.7	16.7	Not Available	344.5	12.1
4	12495	65	4539792	North Rochdale Playground Comfort Station	DPR	92	105.6	5	77	90.2	4.3
4	12495	65	4270045	Q030, Q962 Campus: Q030	DOE	92	105.6	5	77	90.2	4.3
4	12495	166	4270056	Q080	DOE	78	99.5	4.6	71	92.4	5.3
4	12495	270	4270059	Q072	DOE	71	109.1	4.9	94	64.4	3.1
4	12599	8	4271346	Babove Worldwide Institute Inc.	ACS	Not Available	137.5	5.4	Not Available	78.4	2.9
4	12672	1	4527852	Locust Manor Playground Comfort Station	DPR	40	185.9	6.9	13	203.8	8.7
4	12672	1	4273142	Q015	DOE	40	185.9	6.9	13	203.8	8.7
4	12723	76	4274083	Q059	DOE	96	63.1	2.2	86	74.1	3
4	12820	1	4539793	Delphin Greene Playground Comfort Station	DPR	28	112.1	5	40	132.2	5.5
4	12820	1	4276382	Q176, Q992 Campus: Q176	DOE	28	112.1	5	40	132.2	5.5
4	12820	1	4276382	Q176, Q992 Campus: Q176 Addition	DOE	28	112.1	5	40	132.2	5.5
4	12927	28	4278380	Q132, Q996 Campus: Q132	DOE	77	125.6	4.4	65	96.2	4
4	12973	1	4529511	Q270	DOE	44	165.4	5.1	43	136.3	5
4	12993	118	4279864	Q037	DOE	26	144.1	6.6	76	88.3	3.5
4	13057	56	4280845	Q420, Q421 Campus: Q420	DOE	81	104.9	5.3	77	88.8	4.6
4	13057	56	4999999	Q420, Q421 Campus: Q421	DOE	81	104.9	5.3	77	88.8	4.6
4	13170	12	4283015	Q156, Q957 Campus: Q156	DOE	65	139.5	5.6	24	114.8	4.8
4	13222	1	4284236	Q038, Q946 Campus: Q038	DOE	62	141.6	5.1	50	105.3	5.7
4	13265	30	4518258	Classified Location	NYPD	3	384.4	12.4	Not Available	77	3.4
4	13265	30	4518258	116th Precinct	NYPD	3	384.4	12.4	Not Available	77	3.4
4	13307	91	4430508	Classified Location	DHS	Not Available	438.9	16.5	Not Available	346	13.2
4	13331	1	4285682	Q231, Q251 Campus: Q231	DOE	71	82.5	3.2	79	75.1	3.1
4	13331	1	4285682	Q231, Q251: Q251	DOE	71	82.5	3.2	79	75.1	3.1
4	13331	1	4286092	Springfield Park North Playground Comfort Station	DPR	71	82.5	3.2	79	75.1	3.1
4	13353	20	4285972	Q052, Q960 Campus: Q052	DOE	85	128	4.7	43	101	4.2
4	13430	2	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
4	13578	1	4288640	Q138	DOE	37	161.3	6.4	42	120.5	4.6
4	13640	1	4289717	Q374	DOE	Not available	Not Available	Not Available	78	93.5	3.1
4	13655	1	4290116	Q195	DOE	80	107.7	4.6	71	85.1	3
4	13718	1	4291453	Q181	DOE	78	99.5	4.2	35	107	5.4
4	14009	60	4293311	Q207	DOE	83	81.9	4.4	96	58.1	2.3
4	14168	16	4295163	Q146, Q987 Campus: Q146	DOE	70	135.4	5.2	69	85.9	3.2
4	14260	1	4607238	Springfield Gardens Auto Pound	NYPD	Not Available	Not Available	Not Available	18	299.2	8
4	15000	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	15001	73	4433112	Queens East 13 District Garage	DSNY	Not Available	198.3	7.9	Not Available	183.1	7.5
4	15010	28	4296631	Queens Library Operations Center	QPL	Not available	Not Available	Not Available	44	151.3	6.4
4	15313	485	4448968	Q047	DOE	31	594.2	25.4	95	66.8	2.5
4	15350	1	4823422	Broad Channel American Park Ballfield House	DPR	Not Available	Not Available	Not Available	Not Available	0.1	0

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	15541	1	4297972	Q253	DOE	36	177.8	5.3	36	158.3	4.8
4	15557	4	4298231	101st Precinct	NYPD	Not Available	225.5	7.9	Not Available	203.3	7.2
4	15557	25	4298234	Q053	DOE	27	130.5	5.8	53	112.7	5.5
4	15559	25	4529057	Engine Co. 264 and Ladder Co. 134, Engine Co. 328	FDNY	Not Available	196.3	6.8	Not Available	183.1	6.3
4	15560	50	4298254	Sorrentino Recreation Center	DPR	Not Available	58.8	1.5	Not Available	240	9.7
4	15597	1	4298856	Q197	DOE	77	92.7	4.2	73	82	4.3
4	15597	1	4615795	PS 197 Playground Comfort Station	DPR	77	92.7	4.2	73	82	4.3
4	15693	1	4529138	P.S. 104 Playground Comfort Station	DPR	82	109.8	5.8	75	85.7	4.3
4	15693	1	4442313	Q104	DOE	82	109.8	5.8	75	85.7	4.3
4	15736	1	4300730	Q465, Q466 Campus: Q465	DOE	71	118.6	4.7	91	98.2	4
4	15736	1	4300730	Q465, Q466 Campus: Q466	DOE	71	118.6	4.7	91	98.2	4
4	15772	31	4301194	Q215	DOE	73	90.9	4.9	70	91	5.6
4	15819	148	4531136	Q907	DOE	70	107.7	3.9	52	100	2.9
4	15820	1	4467711	Q043, Q920 Campus: Q043	DOE	14	197.7	6.7	51	141.9	5.1
4	15840	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	15861	35	4441244	Q106, Q727, Q806 Campus: Q727	DOE	50	202.1	6.7	45	126.3	5
4	15861	35	4441244	Q106, Q727, Q806 Campus: Q806	DOE	50	202.1	6.7	45	126.3	5
4	15861	35	4441244	Q106, Q727, Q806 Campus: Q106	DOE	50	202.1	6.7	45	126.3	5
4	15894	11	4301929	Q198	DOE	61	100.2	5.4	58	113.8	4.5
4	15900	8	4301932	Rockaway Job and SNAP Centers	HRA	9	319.8	9.2	45	208.3	7.1
4	15974	3	4302397	Q105	DOE	92	104.6	4.6	48	114.6	4.4
4	15980	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	15980	100	4616026	Queens 14 District Garage	DSNY	Not Available	891.3	39.2	Not Available	169.4	5.3
4	16039	14	4302817	Q042	DOE	78	96	4.8	10	188.7	6.8
4	16109	70	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	16112	1	4303354	Q183	DOE	60	121.7	6	36	111.7	6
4	16127	1	4439014	100th Precinct: Engine Co. 266	FDNY	Not Available	153.5	5.5	Not Available	105.7	4.7
4	16127	1	4445329	100th Precinct: 100th Precinct	NYPD	Not Available	153.5	5.5	Not Available	105.7	4.7
4	16127	1	4439013	100th Precinct: 100th Precinct Annex	NYPD	Not Available	153.5	5.5	Not Available	105.7	4.7
4	16135	13	4303629	Peninsula (ALC) Community Library	QPL	Not Available	206.8	6.9	Not Available	152.8	4.9
4	16159	12	4303722	Q180	DOE	87	92	4.3	84	74.3	2.9
4	16167	99	4303773	Q410, Q411 Campus: Q410	DOE	68	122.6	4.6	86	82.7	3.3
4	16167	99	4303773	Q410, Q411 Campus: Q411	DOE	68	122.6	4.6	86	82.7	3.3
4	16181	1	4529315	Rockaway Beach 110	DPR	49	116.3	5.9	63	90.9	3.6
4	16181	1	4303853	Q225	DOE	49	116.3	5.9	63	90.9	3.6
4	16184	1	4303856	Q593 (Main Building) (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	100	18.4	1
4	16189	50	4549352	Rockaway Beach 97 Multi-Purpose Building	DPR	Not Available	Not Available	Not Available	Not Available	107.9	3.3
4	16189	50	4549357	Rockaway Beach Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	107.9	3.3
4	16189	50	4616285	Lifeguard Station	DPR	Not Available	Not Available	Not Available	Not Available	107.9	3.3
4	16212	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	16212	17	4304442	Engine Co. 268 and Ladder Co. 137	FDNY	Not Available	194.3	7.2	Not Available	197.1	7.4
4	16257	1	4305615	Q114	DOE	93	123.5	4.8	71	113.5	4.5

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
4	16258	6	4305631	Q816	DOE	61	126.8	6.2	89	67.7	2.2
4	16258	6	4305631	Q438 (New Construction) (LL84)	DOE	61	126.8	6.2	89	67.7	2.2
4	16325	227	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
4	16330	2	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	1	60	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
5	1	68	5131766	Ferry Maintenance Shop	DOT	Not Available	3789.2	267.5	Not Available	380.5	12.7
5	1	70	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
5	2	1	5141706	St. George Ferry Terminal	DOT	Not Available	850.4	27.6	Not Available	429.4	14.2
5	2	15	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
5	2	22	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
5	5	74	5000030	St. George Library Center	NYPL	Not Available	206.1	6.6	Not Available	179.5	6.1
5	6	14	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	6	21	5151735	Richmond County Supreme Court	DCAS	Not Available	Not Available	Not Available	Not Available	215.2	7
5	6	21	5151736	Staten Island Court House Parking Garage	DOT	Not Available	Not Available	Not Available	Not Available	215.2	7
5	7	1	5000063	Staten Island Borough Hall	DCAS	57	214.1	7.9	Not Available	145.3	5.5
5	7	12	5000064	Staten Island Supreme Court	DCAS	4	386.8	12.4	Not Available	145.3	5.5
5	8	70	5000085	130 Stuyvesant Place Office	DCAS	49	254.7	8.3	71	158.3	5.3
5	9	9	5000089	Richmond Health Center	DCAS > NA	Not Available	126	5.3	Not Available	5.1	0.1
5	9	22	5000090	Staten Island Family Court	DCAS	20	247.1	8	51	186.1	6.3
5	9	28	5106476	120th Precinct	NYPD	Not Available	547.4	19.8	Not Available	507.4	19.3
5	14	32	5000126	R059	DOE	Not Available	Not Available	Not Available	76	83.5	3
5	18	6	5000290	R831	DOE	34	115.8	4.7	26	165.3	6.7
5	18	15	5000291	R016	DOE	83	84.7	3.5	91	70.1	3.2
5	19	4	5000314	R600	DOE	89	81.6	3	82	81.6	3.2
5	22	1	5106483	R450, R451, R453, R814 Campus: R451	DOE	32	155.2	8.3	48	146.7	7.4
5	22	1	5106483	R450, R451, R453, R814 Campus: R450	DOE	32	155.2	8.3	48	146.7	7.4
5	22	1	5106483	R450, R451, R453, R814 Campus: R453 (Addition)	DOE	32	155.2	8.3	48	146.7	7.4
5	34	1	5106487	Staten Island 1 District Garage	DSNY	Not Available	102.1	3	Not Available	199.4	9
5	49	182	5001150	R031	DOE	70	94.9	4.4	72	91.8	5.1
5	49	182	5001150	WT Davis Playground PS 31	DPR	70	94.9	4.4	72	91.8	5.1
5	73	64	5001823	R040, R973 Campus: R040	DOE	46	144.8	4.8	66	167.7	6.3
5	73	64	5001823	R040, R973 Campus: R973	DOE	46	144.8	4.8	66	167.7	6.3
5	76	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	76	200	5158369	Snug Harbor: D-F Hyphen	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146260	Snug Harbor: M-O Connector/SICM	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5999999	Snug Harbor: Chinese Scholar's Garden Pavilion	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146247	Snug Harbor: Bldg O - Staten Island Children's Museum	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5158367	Snug Harbor: A-B Hyphen	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5158368	Snug Harbor: B-C Hyphen	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113028	Snug Harbor: B-H Hyphen/SIM Lab	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113027	Snug Harbor: Bldg A - Staten Island Museum	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113029	Snug Harbor: Bldg C - Main Hall & Newhouse Center	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
5	76	200	5113030	Snug Harbor: Bldg D - Noble Collection	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113032	Snug Harbor: Bldg F	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113033	Snug Harbor: Bldg G	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146247	Snug Harbor: Bldg H	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146249	Snug Harbor: Bldg K - Matron's Cottage	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113034	Snug Harbor: Bldg L - Boiler & Chiller Plant	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5168664	Snug Harbor: Bldg M - SI Children's Museum	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146251	Snug Harbor: Bldg N - 9-11 Education Center	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146252	Snug Harbor: Bldg P - SHCC & BG Admin	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146248	Snug Harbor: M-O Connector/Staten Island Children's Museum	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113035	Snug Harbor: Bldg R - Great Hall	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113037	Snug Harbor: Bldg T - Music Hall	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5999999	Snug Harbor: Bldg U - East Gate House	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146254	Snug Harbor: Bldg V - North Gate House	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5158372	Snug Harbor: C-D Hyphen	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146258	Snug Harbor: Cottage A	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146259	Snug Harbor: Cottage B	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146260	Snug Harbor: Cottage C	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146261	Snug Harbor: Cottage D	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146262	Snug Harbor: Cottage E	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5158374	Snug Harbor: D-E Hyphen	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5113028	Snug Harbor: Bldg B - Staten Island Museum	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146257	Snug Harbor: Tuscan Garden Lemon House	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5999999	Snug Harbor: C-G Hyphen	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146255	Snug Harbor: Bldg W - West Gate House	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5146253	Snug Harbor: Bldg Q - Greenhouse	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	76	200	5999999	Snug Harbor: Snug Harbor Barn	CIG > SHCC	Not Available	166.8	6.3	Not Available	152.6	5.4
5	100	100	5002227	R061	DOE	29	77.7	4.1	92	72.6	3.7
5	159	65	5004530	Staten Island Civil Court	DCAS	37	215.1	7.1	65	155.5	5.5
5	174	6	5004830	Childrens Aide Society Inc.	ACS	Not Available	198.8	6.2	Not Available	130.7	4
5	176	10	5004877	R018	DOE	84	95	3.6	85	83	2.9
5	185	501	5005110	1893 Richmond Terrace	DOT	Not Available	158.7	6.3	Not Available	978	41.4
5	186	119	5106626	Thompson Park Building	DPR	Not Available	Not Available	Not Available	Not Available	390.7	11.4
5	186	119	5106627	Thompson Park Poolhouses	DPR	Not Available	Not Available	Not Available	Not Available	390.7	11.4
5	215	46	5106681	R-2 Water and Sewer Maintenance Yard	DEP	Not Available	146.6	4.9	Not Available	209	5.5
5	215	100	5104536	Castleton Depot	DOT	Not Available	144	5.6	Not Available	172.2	7.8
5	227	24	5006175	R019, R817 Campus: R019	DOE	86	80	2.6	51	125.3	5.2
5	227	24	5006175	R019, R817 Campus: R817	DOE	86	80	2.6	51	125.3	5.2
5	239	1	5156182	Silver Lake Park Tennis Center	DPR	Not Available	Not Available	Not Available	Not Available	356.4	15.5
5	276	7	5007417	R045	DOE	43	93.8	3.5	46	131.6	5.6
5	308	1	5166121	Prall Playground Comfort Station	DPR	93	60.6	3.1	91	58.1	3.3

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
5	308	1	5008403	R027	DOE	93	60.6	3.1	91	58.1	3.3
5	314	70	5155297	Staten Island Zoo: Horse Barn	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	314	70	5106734	Staten Island Zoo: Hospital Building	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	314	70	5106733	Staten Island Zoo: Main Zoo Building	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	314	70	5141695	Staten Island Zoo: Maintenance - Commissary Building	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	314	70	5106733	Staten Island Zoo: Open Air Pavilion	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	314	70	5141696	Staten Island Zoo: Zoo Cafe & Gift Shop	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	314	70	5106733	Staten Island Zoo: Carousel	CIG > SIZS	Not Available	339	11.4	Not Available	305	10.5
5	319	1	5112426	Clove Lakes Park (Stonehenge)	DPR	Not Available	206.1	7.7	Not Available	510.4	15.8
5	319	1	5112422	Clove Lake Garage and Shops	DPR	Not Available	206.1	7.7	Not Available	510.4	15.8
5	319	1	5141707	Clove Lake Park Boathouse	DPR	Not Available	206.1	7.7	Not Available	510.4	15.8
5	319	1	5112427	Staten Island Central Office	FDNY	Not Available	206.1	7.7	Not Available	510.4	15.8
5	319	1	5112428	Staten Island War Memorial Ice Rink	DPR	Not Available	206.1	7.7	Not Available	510.4	15.8
5	331	1	5009028	R029	DOE	87	96	4.3	71	94.4	3.5
5	423	9	5113069	R030	DOE	72	103.3	3.9	77	93.5	4
5	487	100	5162231	DOT Warehouse	DOT	Not Available	Not Available	Not Available	Not Available	58.2	2.7
5	487	100	5999999	Marine Co. 9	FDNY	Not Available	Not Available	Not Available	Not Available	58.2	2.7
5	489	48	5013187	DOT Sign Shop	DOT	Not Available	94.9	3.9	Not Available	86.7	3.9
5	503	32	5013302	Department of Probation Offices	DOP	42	192.5	6.2	72	152.6	5.1
5	504	49	5013317	Staten Island Lot Cleaning	DSNY	Not Available	372.3	15	Not Available	41.9	1.9
5	506	81	5013382	R829	DOE	1	338.4	10	3	285.5	8.8
5	526	63	5013792	Stapleton Branch Library	NYPL	Not available	Not Available	Not Available	Not Available	364.4	11.6
5	534	61	5169148	Gotham Health Vanderbilt	H+H	Not Available	Not Available	Not Available	3	321.1	8.6
5	534	75	5013955	R722	DOE	72	113.2	3.6	84	113.7	4.6
5	542	9	5014078	Staten Island Criminal Court	DCAS	29	244.6	7.7	97	62.8	2.5
5	543	17	5106870	R082	DOE	Not available	Not Available	Not Available	65	106.6	4.4
5	545	110	5158382	Stapleton Playground Comfort Station	DPR	29	112.4	4.1	75	116	4.2
5	545	110	5014176	R014	DOE	29	112.4	4.1	75	116	4.2
5	556	80	5014184	R049	DOE	87	76.7	3.8	90	68.3	3.7
5	610	127	5143126	Terrace Playground Comfort Station	DPR	42	119.5	5.7	72	102	3.4
5	610	127	5015603	R035	DOE	42	119.5	5.7	72	102	3.4
5	635	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	683	301	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	683	302	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	707	183	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	939	1	5112436	High Rock Park Buildings	DPR	Not Available	57.4	1.5	Not Available	80	3.1
5	955	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	955	100	5141697	Sea View Robitzek Building	H+H	91	95.9	4.9	Not Available	95.9	4
5	955	100	5141697	EMS 22 (Sea View Hospital Staten Island)	FDNY	91	95.9	4.9	Not Available	95.9	4
5	955	100	5146639	R460, R461: R460	DOE	91	95.9	4.9	Not Available	95.9	4
5	955	100	5113197	R460, R461: R461	DOE	91	95.9	4.9	Not Available	95.9	4
5	955	100	5154937	Blood Root Valley Park House	DPR	91	95.9	4.9	Not Available	95.9	4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
5	955	100	5146639	R460, R461 Campus: R462 (Annex)	DOE	91	95.9	4.9	Not Available	95.9	4
5	955	170	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	1020	1	5106979	R020	DOE	8	190.3	8.3	44	171.9	7.9
5	1121	1	5026076	R445, R446, R815 Campus: R445	DOE	44	145.6	5.4	64	122.4	4.8
5	1135	1	5026335	R021	DOE	72	119.2	4.1	87	94.9	3.5
5	1158	103	5155172	R094 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	280	7.4
5	1218	1	5027641	R044	DOE	15	148.3	5.5	90	73.4	3.2
5	1301	1	5999999	Port Ivory	DOT	Not available	Not Available	Not Available	Not Available	112.1	3
5	1410	250	Not Available	Not Available	Not Available	Not available	Not Available	Not Available	Not Available	Not Available	Not Available
5	1478	500	5107209	Markham Playground Comfort Station	DPR	92	54.2	2.1	80	87.4	3.7
5	1478	500	5107210	R051	DOE	92	54.2	2.1	80	87.4	3.7
5	1548	100	5151294	R090 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	96.2	3.2
5	1580	44	5031151	R060	DOE	71	96.4	3	76	86.1	3.2
5	1653	1	5032481	R861	DOE	8	242.9	7.5	8	259.9	8.8
5	1704	1	5165197	121st Precinct	NYPD	Not Available	Not Available	Not Available	Not Available	360.7	10.5
5	1706	1	5107239	R022	DOE	64	124.3	4.3	33	120.8	4.6
5	1955	1	5107273	Greenbelt Recreation Center	DPR	Not Available	Not Available	Not Available	Not Available	253.4	8.8
5	1955	225	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	1987	104	5034476	R054	DOE	67	97.8	4.6	69	94.5	4.8
5	2040	1	5107296	CSI: Astrophysical Observatory	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5131066	CSI: Biology & Chemistry	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107294	CSI: Business School	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107291	CSI: Campus Center / Cafeteria	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107288	CSI: Campus Services & Central Plant	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107297	CSI: Center for the Arts	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107289	CSI: Children's Center	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107292	CSI: Computer Science, Engineering Science & Physics	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107304	CSI: Education School	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107295	CSI: Engineering Technologies	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107303	CSI: English, World Languages and Literatures	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107293	CSI: Marchi Hall	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107301	CSI: Library / Cyber Cafe	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5130987	CSI: Marcus Hall - Nursing	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107302	CSI: Mathematics Building	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107299	CSI: North Administration Building	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5131067	CSI: Health Sciences, Physical Therapy	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107305	CSI: Psychology, Sociology, Anthropology	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107298	CSI: South Administration Building	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107289	CSI: Sports and Recreation Center	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107293	CSI: School of Business	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5107300	CSI: West Administration Building	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8
5	2040	1	5130988	CSI: Pump House	CUNY SC > CSI	Not Available	Not Available	Not Available	Not Available	266.2	8.8

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
5	2099	24	5035399	R093 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	224.3	5.9
5	2364	1	5037524	R072	DOE	67	85.9	3.5	87	73.5	3.4
5	2366	73	5037541	R069	DOE	58	95.5	4	91	80.8	3
5	2380	600	5146581	R100	DOE	Not Available	Not Available	Not Available	Not Available	61.1	2.5
5	2450	305	5145698	R058	DOE	21	193	5.5	31	184.8	6.3
5	2450	320	5149609	R043	DOE	4	303.4	8.7	14	205	5.9
5	2520	1	5041599	Staten Island 2 District Garage	DSNY	Not Available	216.2	7.8	Not Available	256	10.6
5	2610	27	5127019	Greenbelt Native Plant Center	DPR	Not Available	408.8	18.2	Not Available	463.5	21.1
5	2634	1	5107386	R026	DOE	69	108.1	3.7	70	93.2	3.2
5	2665	25	5041882	Engine Co. 154 Communications Garage	FDNY	Not Available	261	8.6	Not Available	180.6	6.5
5	2685	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	2685	100	5141714	Staten Island Rail Transfer Station	DSNY	Not Available	16.2	0.8	Not Available	238.8	6.5
5	2790	1	5999999	South Avenue Salt Storage	DSNY	Not Available	Not Available	Not Available	79	29.3	0.8
5	2852	1	5042776	R013	DOE	47	146.1	4.7	37	155.5	5.6
5	2885	1	5043479	R470	DOE	95	92.9	3.6	83	84	3.7
5	2888	40	5043519	R057	DOE	63	96.8	3.3	90	77.4	2.9
5	2965	64	5999999	Tompkins Avenue Salt Storage	DSNY	Not available	Not Available	Not Available	88	21.9	0.6
5	3087	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	3097	14	5144214	Arrochar Playground Comfort Station	DPR	33	116.9	4.7	59	118.5	4.6
5	3097	14	5045488	R039	DOE	33	116.9	4.7	59	118.5	4.6
5	3125	3	5156998	South Beach Comfort Station	DPR	Not available	Not Available	Not Available	Not Available	102.7	3.8
5	3125	3	5107495	Roosevelt Boardwalk - Doty Avenue Comfort Station	DPR	Not available	Not Available	Not Available	Not Available	102.7	3.8
5	3125	3	5843360	Roosevelt Boardwalk - Sand Ln Bathhouse & Office	DPR	Not available	Not Available	Not Available	Not Available	102.7	3.8
5	3153	38	5046179	Engine Co. 160 and Rescue 5, Division 8	FDNY	Not Available	238.2	7.7	Not Available	174.8	6
5	3168	4	5046367	R071	DOE	Not Available	Not Available	Not Available	33	170.7	5.4
5	3171	1	5046419	R048	DOE	85	128.9	6.3	78	97.6	5.3
5	3243	1	5047613	R046	DOE	68	65.4	2.6	96	54.3	2.3
5	3303	18	5048647	R011	DOE	94	72.5	2.1	60	105	4.3
5	3355	1	5151793	Ocean Breeze Indoor Horseback Riding Facility	DPR	Not available	Not Available	Not Available	Not Available	44.5	1.6
5	3355	70	5159404	Ocean Breeze Indoor Athletic Facility	DPR	Not Available	Not Available	Not Available	Not Available	196.5	5.8
5	3525	200	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	3643	5	5052750	New Dorp Branch Library	NYPL	Not Available	250.6	8.5	Not Available	141.1	4.7
5	3645	7	5052791	R041	DOE	38	119.6	5.9	62	102.4	5.5
5	3696	100	5053571	R002	DOE	81	65.2	3	95	61.5	2.5
5	3705	1	5144600	Dongan Playground Shed	DPR	69	137.3	5.8	99	52.9	2.3
5	3705	1	5053746	R052	DOE	69	137.3	5.8	99	52.9	2.3
5	3732	6	5054213	R038, R816 Campus: R038	DOE	68	102.1	4.6	86	75.9	3.5
5	3732	6	5054213	R038, R816 Campus: R816	DOE	68	102.1	4.6	86	75.9	3.5
5	3847	30	5110732	R113 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	146.6	3.9
5	3851	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	3906	1	5107580	122nd Precinct	NYPD	Not Available	246.5	8	Not Available	227.3	8
5	3930	10	5055367	R435	DOE	95	105.6	4.2	85	89.9	4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology

Borough	Block	Lot	BIN	Building	Agency	2010*			2021		
						Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*	Score*	Source EUI (kBtu/ft²)*	GHG Emissions Intensity (kgCO2e/ft²)*
5	3983	80	5055379	R091 (LL84) (Leased)	DOE	Not Available	Not Available	Not Available	Not Available	139.5	4.5
5	4244	1	5107621	R440, R441 Campus: R440	DOE	85	91	3.5	81	92	3.7
5	4373	1	5059927	R023	DOE	47	124.9	5.7	90	80.6	3.2
5	4444	35	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	4586	1	5061911	R840, R819 Campus: R840	DOE	86	103.4	2.7	Not Available	Not Available	Not Available
5	4716	60	5063495	R050	DOE	68	87.8	4	89	65	2.5
5	5067	1	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	5106	1	5065016	Greencroft Playground Comfort Station	DPR	42	99.8	4.8	82	92.7	5
5	5106	1	5065016	R053	DOE	42	99.8	4.8	82	92.7	5
5	5153	108	5065854	R024	DOE	75	80	3.9	91	64.8	3.8
5	5221	1	5066295	R008	DOE	31	104.2	4	67	99.4	4.2
5	5336	1	5144987	Double Nickel Playground Comfort Station	DPR	68	117.4	5.4	68	95.4	5.1
5	5336	1	5069075	R055	DOE	68	117.4	5.4	68	95.4	5.1
5	5411	40	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	5444	12	5070651	R032	DOE	75	91.3	4.2	68	93.7	5
5	5605	1	5074394	R042	DOE	56	135.8	6.6	54	106.4	5.3
5	5605	1	5130512	R848	DOE	56	135.8	6.6	54	106.4	5.3
5	5900	500	5130986	Richmond Boro Repair Shop / SI 3 District Garage	DSNY	Not Available	Not Available	Not Available	Not Available	245	10.8
5	5900	500	5130986	Plant 1: Tractor Shops	DSNY	Not Available	Not Available	Not Available	Not Available	245	10.8
5	6025	30	5079499	R004	DOE	81	72.3	3.2	97	55.2	2.6
5	6050	2	5079651	R075	DOE	53	107.2	5.2	78	107.4	6
5	6110	32	5079727	South Shore Golf Course Comfort Station	DPR	Not Available	Not Available	Not Available	Not Available	Not Available	0
5	6169	37	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	6169	200	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available	Not Available
5	6262	12	5107742	R036	DOE	33	113.2	5.1	78	98.3	3.9
5	6262	12	5107743	R844	DOE	33	113.2	5.1	78	98.3	3.9
5	6544	1	5154336	Prescott Playground Comfort Station	DPR	78	64.5	3.4	95	67.3	3.6
5	6544	1	5082345	R007	DOE	78	64.5	3.4	95	67.3	3.6
5	6566	1	5082407	R005	DOE	68	82.3	2.5	77	93.7	3.6
5	6613	1	5082634	R455, R456 Campus: R455	DOE	89	98	4.5	96	62	2.7
5	6613	1	5082634	R455, R456 Campus: R456	DOE	89	98	4.5	96	62	2.7
5	6796	44	5083311	R003	DOE	31	127.8	5.9	82	88.9	3.8
5	7044	1	5128148	R056	DOE	4	237.1	7.9	53	131.9	4.6
5	7067	252	5154879	Engine Co. 168	FDNY	Not Available	198	6.7	Not Available	138.4	4.8
5	7092	39	5158758	R062	DOE	Not Available	Not Available	Not Available	74	85.1	1.8
5	7760	1	5131697	R006	DOE	17	192.1	5.6	8	188.1	6.3
5	7894	1	5088090	R034	DOE	61	105.6	5.8	71	120.1	6.2
5	7898	1	5107854	R001, R802 Campus: R001	DOE	62	131.5	4.7	98	103.9	4.4
5	7898	1	5107854	R001, R802 Campus: R802	DOE	62	131.5	4.7	98	103.9	4.4

* Score of "Not Available" indicates building use types for which EPA PM does not provide ENERGY STAR Score or required information is not available

* Source EUI and GHG Emissions Intensity calculations performed by U.S. EPA methodology