

RESCINDED BY
BUILDINGS BULLETIN 2023-001

DEPARTMENTAL MEMORANDUM

DATE April 28, 1981

TO: Borough Superintendents

FROM: Irwin Fruchtman, P.E. *IF*
Commissioner

SUBJECT: Installation of Gas Piping 3 PSig or less

Screwfittings may be used in gas installations,
regardless of pipe sizes, providing the gas pressure
is 3 PSig or less (See 115.0 Gas Piping).

This is an amendment to a memorandum of December 12, 1980.

IF:LD:mh

1773